

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request   | Installation Location                            | Status   | Fee    |
|--|--------------|---|---|--|----------|--------|
| 46915CO2   | 06A0031CO2   | Michael Mazzeo Electric Corp.<br>41-24 24th Street<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed  | 375 Park Avenue<br>New York NY                   | Hold     | \$0.00 |
| Carry over from March 15, 2006 meeting. 1) Need east side fire pump information. 2) Provide distance between generator and switchgear. 3) Encase feeder to emergency board. 4) Breakers to fire pump and fire alarm switch must be tapped ahead of switchgear. |              |   |   |  |          |        |
| 46933CO  | 06A0062CO    | MechoShade Systems, Inc.<br>42--03 35th Street<br>Long Island City NY 11101     | Requested approval for use in New York City of your Motorized Shading System. Model/Series Numbers: MechoShade's Electro1, Electro2, Electro3 Motorized Shading Solutions including MechoShade E-Switch Line Voltage Switch solutions and a variety of Line Voltage Motor |  | Approved | \$0.00 |
| Carry over from January 25, 2006 meeting.  |              |   |   |  |          |        |
| 46998CO  | 06A0110CO    | Highland Associates<br>228 East 45th Street<br>New York NY 10017                | Requested approval for the electric service equipment proposed to be installed  | 183 Madison Avenue<br>New York NY                | Approved | \$0.00 |
| Carry over from March 15, 2006 meeting. Submit in Advisory Board format.   |              |   |   |  |          |        |
| 47002CO  | 06A0125CO    | Jim Electric Corp.<br>223 52nd Street<br>Brooklyn NY 11220                      | Requested approval for the electric service equipment proposed to be installed  | 920 Broadway<br>New York NY                      | Approved | \$0.00 |
| Carry over from March 15, 2006 meeting.  |              |   |   |  |          |        |
| 47022CO  | 06A0160CO    | Royal Electric and Wiring Corp.<br>27-07 BQE West<br>Woodside NY 11377          | Requested approval for the electric service equipment proposed to be installed  | Silver Leaf<br>480 East 176th Street<br>Bronx NY | Approved | \$0.00 |
| Carry over from March 15, 2006 meeting. 1) 1-Line too small can't read. 2) Provide heavy duty/service rated safety switch for fire pump. 3) Run neutral to fire pump service switch and bond. Job finalized 5/15/06.   |              |   |   |  |          |        |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|--|--------------|---|--|--|----------|----------|
| 47023CO  | 06A0165CO    | Gallant Electric Co.<br>141 Beach 116th Street<br>Rockaway Park NY 11694                    | Requested approval for the electric service equipment proposed to be installed | 568 Broadway<br>New York NY                                    | Hold     | \$0.00   |
| Carry over from March 15, 2006 meeting..   |              |   |  |  |          |          |
| 47028CO  | 06A0114CO    | Adco Electrical Corporation<br>201 Edward Curry Avenue<br>Staten Island NY 10314            | Requested approval for the electric service equipment proposed to be installed | Morgan Stanley<br>1 NYP-1st Floor<br>New York NY               | Approved | \$0.00   |
| Carry over from March 15, 2006 meeting.  |              |   |  |  |          |          |
| 47069  | 06A0213      | Gilston Electrical Contg Corporation<br>338 East 95th Street<br>New York NY 10128           | Requested approval for the electric service equipment proposed to be installed | Newtown Creek W.P.C.P.<br>301 Greenpoint Avenue<br>Brooklyn NY | Hold     | \$650.00 |
| 1) Bus undersized for 4000A breakers( 800A square inch required within 48"). 2) Show all bus sizes. 3) Provide short circuit and coordination study. 4) Show fire alarm connections past XFMRS. 5) Show means of egress on room layout. 6) Bus in 5KV switch and 480V switchgear must be 12" above slab. |              |   |  |  |          |          |
| 47070  | 06A0209      | Irwol Electric Corp.<br>41 Clinton Avenue<br>Brooklyn NY 11205                              | Requested approval for the electric service equipment proposed to be installed | 123 West 44th Street<br>New York NY                            | Approved | \$650.00 |
| Fuses not coordinated in 2000A switchboard. Job finalized 6/20/06.   |              |   |  |  |          |          |
| 47071  | 06A0211      | DiRusso Electrical Contracting Inc.<br>63-23 Metropolitan Avenue<br>Middle Village NY 11379 | Requested approval for the electric service equipment proposed to be installed | 234 Skillman Avenue<br>Brooklyn NY                             | Approved | \$650.00 |
| 1) Fire pump feeder must be fire rated. 2) Provide short circuit current at meter bank mb breakers rated 22KAIC. 3) Clarify tap connections in 60" trough. 4) Provide 2nd means of egress. 5) Provide Siemens factory cuts. Job finalized 8/06.  |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                       | Status   | Fee      |
|--|--------------|--|--|---|----------|----------|
| 47072  | 06A0208      | D.J. Electrical Contractors, Inc.<br>217 Fordham Street<br>Bronx NY 10464            | Requested approval for the electric service equipment proposed to be installed | 418-420 West 25th Street<br>New York NY                     | Approved | \$650.00 |
| 1) Provide code compliant grounding and bonding on left-hand portion of service switchboard. 2) Fire pump feeder undersized. 3) Provide GE factory cuts. Job finalized 8/06. |              |  |  |   |          |          |
| 47073  | 06A0210      | Queensboro Electrical Contracting Corp.<br>217-22 Northern Blvd.<br>Bayside NY 11361 | Requested approval for the electric service equipment proposed to be installed | United Homes<br>13-11 Jackson Avenue<br>Long Island City NY | Approved | \$650.00 |
| 1) Provide Siemens factory cuts. 2) Service tap for 200A service switch undersized. Job finalized 8/06.  |              |  |  |   |          |          |
| 47074  | 06A0212      | Crossland Electrical Systems, Inc.<br>846 East 52nd Street<br>Brooklyn NY 11203      | Requested approval for the electric service equipment proposed to be installed | 599 Kingston Avenue<br>Brooklyn NY                          | Hold     | \$650.00 |
| Tap on tap   |              |  |  |   |          |          |
| 47075  | 06A0204      | J.A. Lee Electric, Inc.<br>23-30 50th Avenue<br>Long Island City NY 11101            | Requested approval for the electric service equipment proposed to be installed | 303 Vernon Avenue<br>Brooklyn NY                            | Approved | \$650.00 |
|  |              |  |  |   |          |          |
| 47076  | 06A0201      | Mage Electrical Contractors<br>158 Perry Street<br>New York NY 10014                 | Requested approval for the electric service equipment proposed to be installed | 500 Eighth Avenue<br>New York NY                            | Approved | \$650.00 |
| Rectifier feeder (#3) undersized. Job finalized 4/27/06.   |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

April 12, 2006

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                      | Status   | Fee      |
|---|--------------|--|--|--|----------|----------|
| 47077   | 06A0196      | James F. Volpe Electl Contracting Corp.<br>81 Sackett Street<br>Brooklyn NY 11231  | Requested approval for the electric service equipment proposed to be installed | 610-630 West 48th Street<br>New York NY                    | Ok, but  | \$650.00 |
| 1) Five pump feed not tapped prior to the through bus. 2) 1000 amp generator switch not bonded 4 pole ATS used. 3) Provide 2nd means of egress. 4) ATS ? Improperly labeled "N" & "E" .<br>5) Provide Siemens factory cuts. |              |  |  |  |          |          |
| 47078   | 06A0175      | Spieler & Ricca Electrical Co. Inc.<br>52-09 Van Dam Street<br>Long Island City NY | Requested approval for the electric service equipment proposed to be installed | 455 Main Street<br>Roosevelt NY                            | Approved | \$650.00 |
| 47079   | 06A0171      | Judd Electric, Inc.<br>41-41 38th Street<br>Long Island City NY 11101              | Requested approval for the electric service equipment proposed to be installed | 110 West 20th Street<br>New York NY                        | Approved | \$650.00 |
| 47080   | 06A0206      | Tom Fitzpatrick Electl Contg Corporation<br>1643 Utica Avenue<br>Brooklyn NY 11234 | Requested approval for the electric service equipment proposed to be installed | Riverbank Residence<br>560 West 43rd Street<br>New York NY | Approved | \$650.00 |
| 47081   | 06A0178      | A & M Electrical Service Inc.<br>5309 2nd Avenue<br>Brooklyn NY 11220              | Requested approval for the electric service equipment proposed to be installed | 358 Grove Street<br>Brooklyn NY                            | Approved | \$650.00 |
| Relocate fire pump tap to service end box. Job finalized on 4/27/06.  |              |  |  |  |          |          |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #            | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                      | Status   | Fee      |
|-----------------------|--------------|--|--|--|----------|----------|
| 47082                 | 06A0177      | Queens Hospital Center<br>82-62 164th Street<br>Jamaica NY 11432                     | Requested approval for the electric service equipment proposed to be installed | Queens Hospital Center<br>82-62 164th Street<br>Jamaica NY | Approved | \$650.00 |
|                       |              |  |  |  |          |          |
| 47083                 | 06A0179      | Skyline Electrical Contracting Corp.<br>1725 Richmond Road<br>Staten Island NY 10306 | Requested approval for the electric service equipment proposed to be installed | 235 West 46th Street<br>New York NY                        | Approved | \$650.00 |
|                       |              |  |  |  |          |          |
| 47084                 | 06A0180      | Schlesinger Electrical Contractors, Inc.<br>664 Bergen Street<br>Brooklyn NY 11238   | Requested approval for the electric service equipment proposed to be installed | Saks Fifth Avenue<br>611 Fifth Avenue<br>New York NY       | Approved | \$650.00 |
|                       |              |  |  |  |          |          |
| 47085                 | 06A0195      | Shorr Electrical Contracting Inc.<br>34-13 10th Street<br>Long Island City NY 11106  | Requested approval for the electric service equipment proposed to be installed | 422 Fulton Street<br>Brooklyn NY                           | Approved | \$650.00 |
|                       |              |  |  |  |          |          |
| Job finalized 5/1/06. |              |  |  |  |          |          |
| 47086                 | 06A0184      | Michael Mazzeo Electric Corp.<br>41-24 24th Street<br>Long Island City NY 11101      | Requested approval for the electric service equipment proposed to be installed | 1320 Broadway<br>New York NY                               | Approved | \$650.00 |
|                       |              |  |  |  |          |          |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                                       | Status   | Fee      |
|---|--------------|---|--|---|----------|----------|
| 47087   | 06A0191      | Sigma Electric, Inc.<br>52-32 83rd Street, Suite 1-M<br>Elmhurst NY 11373                 | Requested approval for the electric service equipment proposed to be installed | 88 9th Avenue<br>New York NY                                | Approved | \$650.00 |
|   |              |   |  |   |          |          |
| 47088   | 06A0190      | Barbaro Electric Co., Inc.<br>331 38th Street<br>Brooklyn NY 11232                        | Requested approval for the electric service equipment proposed to be installed | 440 9th Avenue<br>New York NY                               | Approved | \$650.00 |
|   |              |   |  |   |          |          |
| 47089   | 06A0188      | Queens Electrical Contractors, Inc.<br>32-17 Broadway<br>Astoria NY                       | Requested approval for the electric service equipment proposed to be installed | 555 Prospect Place<br>Brooklyn NY                           | Approved | \$650.00 |
|   |              |   |  |   |          |          |
| 47090   | 06A0187      | Livingston Electrical Assoc., Inc.<br>162-20 77th Road<br>Flushing NY 11366               | Requested approval for the electric service equipment proposed to be installed | 210 Lafayette Street<br>New York NY                         | Approved | \$650.00 |
|   |              |   |  |   |          |          |
| 47091   | 06A0214      | Coastal Electric Construction Corp.<br>232 Madison Avenue, Suite 200<br>New York NY 10016 | Requested approval for the electric service equipment proposed to be installed | Columbia University<br>615 West 131st Street<br>New York NY | Hold     | \$650.00 |
| 1) Verify existing versus new equipment. 2) Verify fire pump tap. 3) Verify ground fault protection on 2500 amp service switch. |              |   |  |   |          |          |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                           | Status   | Fee      |
|--|--------------|---|--|---|----------|----------|
| 47092  | 06A0181      | Sage Electrical Contracting Inc.<br>651 Willowbrook Road, Suite 201<br>Staten Island NY 10314 | Requested approval for the electric service equipment proposed to be installed | 250 East 53rd Street<br>New York NY             | Approved | \$650.00 |
| Increase bus size in panel that feeds the 2 1200 amp switches. Job finalized April 17, 2006.                       |              |   |  |   |          |          |
| 47093  | 06A0169      | Antoher Nycer Electric Corp<br>652 Sackett Street<br>Brooklyn NY 11217                        | Requested approval for the electric service equipment proposed to be installed | Alpha Plastics<br>10203 Avenue D<br>Brooklyn NY | Hold     | \$650.00 |
| 1) Appear at next meeting to explain job. 2) Is it all new?  |              |   |  |   |          |          |
| 47094  | 06A0200      | Riteway Electrical Corp.<br>285 Kent Avenue<br>Brooklyn NY 11211                              | Requested approval for the electric service equipment proposed to be installed | 84-100 Maspeth Avenue<br>Brooklyn NY            | Approved | \$650.00 |
| 1) Verify FLA of fire pump. 2) Provide a 2nd means of egress on other side of service room. Job finalized 4/27/06. |              |   |  |   |          |          |
| 47095  | 06A0205      | J.A. Lee Electric, Inc.<br>23-30 50th Avenue<br>Long Island City NY 11101                     | Requested approval for the electric service equipment proposed to be installed | 403 Powell Street<br>Brooklyn NY                | Approved | \$650.00 |
| 47096  | 06A0203      | J.A. Lee Electric, Inc.<br>23-30 50th Avenue<br>Long Island City NY 11101                     | Requested approval for the electric service equipment proposed to be installed | 65 Norfolk Street<br>New York NY                | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|--|--|--|----------|----------|
| 47097   | 06A0202      | T.R. Ricotta Electric Inc.<br>224-38 Braddock Avenue<br>Queens Village NY          | Requested approval for the electric service equipment proposed to be installed | Forest Hills Hospital<br>102-01 66th Road<br>Forest Hills NY   | Approved | \$650.00 |
|   |              |  |  |  |          |          |
| 47098   | 06A0183      | Axcel Electric Company, Inc.<br>636 11th Avenue, 10th Floor<br>New York NY 10036   | Requested approval for the electric service equipment proposed to be installed | 547 West 27th Street<br>New York NY                            | Approved | \$650.00 |
|   |              |  |  |  |          |          |
| 47099   | 06A0174      | Patagonia Electrical Contracting Inc.<br>1722 Crosby Avenue<br>Bronx NY 10464      | Requested approval for the electric service equipment proposed to be installed | Manhattan Beer Distributors<br>4712 Grand Avenue<br>Maspeth NY | Ok, but  | \$650.00 |
| 1) Provide ground fault protection on 1200 amp 480V switch. 2) Clarify that transformer bond is going to building steel. 3) Provide second means of egress in service room. Verify room size. |              |  |  |  |          |          |
| 47100   | 06A0176      | Fried Electric Co., Inc.<br>250 West 77th Street, Suite 430<br>New York NY 10024   | Requested approval for the electric service equipment proposed to be installed | 48-05 Metropolitan Avenue<br>Maspeth NY                        | Approved | \$650.00 |
|   |              |  |  |  |          |          |
| 47101   | 06A0172      | Spieler & Ricca Electrical Co. Inc.<br>52-09 Van Dam Street<br>Long Island City NY | Requested approval for the electric service equipment proposed to be installed | NYU Dental<br>421 First Avenue<br>New York NY                  | Approved | \$650.00 |
|   |              |  |  |  |          |          |



# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|--|--------------|---|--|--|----------|----------|
| 47102  | 06A0170      | Judd Electric, Inc.<br>41-41 38th Street<br>Long Island City NY 11101         | Requested approval for the electric service equipment proposed to be installed | 49 West 38th Street<br>New York NY                           | Approved | \$650.00 |
|  |              |   |  |  |          |          |
| 47103  | 06A0182      | Gateway Electric Group, LLC<br>11-02 37th Avenue<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 45 Park Avenue<br>New York NY                                | Approved | \$650.00 |
| Verify fire pump feed between 2500 amp service switch and C.T. Job finalized April 17. 2006. |              |   |  |  |          |          |
| 47104  | 06A0197      | S.J. Electric, Inc.<br>601 Union Street<br>Brooklyn NY 11215                  | Requested approval for the electric service equipment proposed to be installed | Avalon<br>Parcel 9-Avalon River Court<br>Long Island City NY | Approved | \$650.00 |
| Provide barrier between back of fire pump cabinet. Job finalized 6/29/06                     |              |   |  |  |          |          |
| 47105  | 06A0185      | AC Electrical Services, Inc.<br>142 West 19th Street<br>New York NY 10011     | Requested approval for the electric service equipment proposed to be installed | 20-22 Mercer Street<br>New York NY                           | Approved | \$650.00 |
|  |              |   |  |  |          |          |
| 47106  | 06A0186      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416        | Requested approval for the electric service equipment proposed to be installed | 20 Pine Street<br>New York NY                                | Approved | \$650.00 |
| Verify the bus sizes in TDP-3. Job finalized 5/1/06.   |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

April 12, 2006

| Calendar # | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|------------|--------------|--|--|--|----------|----------|
| 47107      | 06A0189      | Barbaro Electric Co., Inc.<br>331 38th Street<br>Brooklyn NY 11232           | Requested approval for the electric service equipment proposed to be installed | 260 West 39th Street<br>New York NY  | Approved | \$650.00 |
| 47108      | 06A0192      | RNH Electric Company, Inc.<br>45-46 11th Street<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | P.S. 78 Annex<br>4-74 48th St. aka 48-09 Center Blvd.<br>Long Island City NY | Approved | \$650.00 |
| 47109      | 06A0193      | Izzo Electric, Inc.<br>2522 E. Tremont Avenue<br>Bronx NY 10461              | Requested approval for the electric service equipment proposed to be installed | 2040 White Plains Road<br>Bronx NY   | Approved | \$650.00 |
| 47110      | 06A0194      | Norway Electric Corp.<br>1205 Jerome Avenue<br>Bronx NY 10452                | Requested approval for the electric service equipment proposed to be installed | 804 East 138th Street<br>Bronx NY  | Approved | \$650.00 |
| 47111      | 06A0173      | A.C. Morgan Electric<br>3601 Riverdale Avenue<br>Bronx NY 10463              | Requested approval for the electric service equipment proposed to be installed | 315 West 36th Street<br>New York NY  | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                       | Status   | Fee      |
|---|--------------|--|--|---|----------|----------|
| 47112   | 06A0198      | Genergy Electric Services Company LLC<br>353 West 48th Street<br>New York NY 10036 | Requested approval for the electric service equipment proposed to be installed   | Jones Lang LaSalle, 18th Fl<br>2 Park Avenue<br>New York NY | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 47113   | 06A0199      | Michael Mazzeo Electric Corp.<br>41-24 24th Street<br>Long Island City NY 11101    | Requested approval for the electric service equipment proposed to be installed   | Verizon<br>375 Pearl Street<br>New York NY                  | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 47114   | #            | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416             | Requesting permission in a multi family building that has a separate laundry facility available to all occupants, to install one 30 ampere laundry branch circuit in lieu of the 20 ampere circuit as required in 210.11(c)(2). See exceptions 1 and 2 of 210.52(F). | 2628 Broadway<br>New York NY                                | Approved | \$0.00   |
|   |              |  |  |   |          |          |
| 47115   | ##           | Jim Electric Corp.<br>223 52nd Street<br>Brooklyn NY 11220                         | Requesting permission to leave as originally installed 5 sets of 500 MCM that feeds an existing 2400 amp service panel containing (4) 600 amp service switches.  | 920 Broadway<br>New York NY                                 | Approved | \$0.00   |
|   |              |  |  |   |          |          |
| 47116   | ###          | Blue Ribbon Electrical Contractors Inc.<br>500 Smith Street<br>Brooklyn NY 11231   | Requesting permission to leave as installed due to hardship to replace BX cable without an insulated equipment grounding conductor as a wiring method in a place of public assembly.   | 114-116 Ditmas Avenue<br>Brooklyn NY                        | Approved | \$350.00 |
| with the stipulation that ground fault circuit breakers must be installed on the branch circuit wiring. |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request   | Installation Location                            | Status   | Fee    |
|---|--------------|--|---|--|----------|--------|
| 47117   | ####         | Herbert L. Manel, P.C. Architect<br>443 Park Avenue South<br>New York NY 10016           | Requesting permission to leave as installed due to security and vandalism issues electrical service rooms that have only one double door for egress.  | Ocean Bay Apartments<br><br>Queens NY            | Approved | \$0.00 |
| with the stipulation that signage is provided in each switchgear room indicating the sequence of operation of the switchgear system plus the requirements of Section 230.2(E). The doors of each switchgear room shall open in the direction of egress and be equipped with panic bars, pressure plates, or other devices that are normally latched but open under simple pressure. |              |  |   |  |          |        |
| 47118   | #####        | Lewteck Electric Inc.<br>309 Clarkson Avenue<br>Brooklyn NY 11226                        | Requesting permission to install Schedule 80 non metallic conduit as underground service entrance conductors where the service equipment will be installed outdoors on 14 two family buildings located in a highly corrosive area, Far Rockaway Queens. | 3each 79th Street and Aquatic Drive<br>Queens NY | Approved | \$0.00 |
| 47119   | #####        | North Point Electrical Corporation<br>651 Bay Street<br>Staten Island NY 10304           | Requesting permission due to a highly corrosive area to install Schedule 80 non metallic conduits that will run exposed down a privately owned utility pole and then run underground into the building end box of a water front dwelling unit.          | 101 E. Harbor View Place<br>Staten Island NY     | Approved | \$0.00 |
| with the stipulation that each non metallic conduit installed on the utility pole is provided with a weather head.  |              |  |   |  |          |        |
| 47120   | #####        | Sage Electrical Contracting<br>651 Willowbrook Road, Suite 201<br>Staten Island NY 10314 | Requesting permission to install seven service switches where two of the service switches are for fire pumps.   | 250 East 53rd Street<br>New York NY              | Approved | \$0.00 |
| 47121   | #####        | Murray Diamond, Licensed Electrician<br>35-05 169th Street<br>Flushing NY 11358          | Requesting permission due to ground water conditions to run service entrance conductors in overhead troughs within a two hour fire rated room instead of concrete encased conduits (Cal. #42541).   | Fresh Direct<br>23-30 Borden Avenue<br>Queens NY | Hold     | \$0.00 |
| 1) Provide letter from switchgear manufacturer stating that the switchgear can be used to support the wireways. 2) The barriers inside of the wireways shall be supported independently of the wireways. 3) All sets of conductors inside of the wireway shall be bundled and tied into groups as per 300.20  |              |  |   |  |          |        |

# ADVISORY BOARD CALENDAR

April 12, 2006

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                             | Status   | Fee    |
|---|--------------|---|--|---|----------|--------|
| 47122   | #####        | A/C Electric of New York, Inc.<br>32 Union Square East<br>New York NY 10003                 | Requesting permission to retro fit an existing concrete encased back box with a new G.E. circuit breaker panel interior.   | 115 East 9th Street, Apt 21G<br>New York NY       | Approved | \$0.00 |
| with the stipulation that the required gutter space be maintained.    |              |   |  |   |          |        |
| 47123   | #####        | Lilker Associates Consulting Engs, P.C.<br>1001 Avenue of the Americas<br>New York NY 10018 | Requesting concept approval of a service room layout with only one means of egress.  | SCA School<br>225 West 24th Street<br>New York NY | Denied   | \$0.00 |
| A second means of egress must be provided on one of the other walls.  |              |   |  |   |          |        |
| 47124   | #####        | Edwards & Zuck, P.C.<br>315 Park Avenue South<br>New York NY 10010                          | Requesting permission to tap emergency power for the fire alarm system from the line side of a local emergency panel instead of tapping the line side of the main generator overcurrent protection device. | 20 West 50th Street<br>New York NY                | Approved | \$0.00 |
| with the stipulation that approval is subject to other jurisdictions. |              |   |  |   |          |        |
| 47125   | #####        | Edwards & Zuck, P.C. Consulting Engs.<br>315 Park Avenue South<br>New York NY 10010         | Requesting permission to tap emergency power for the fire alarm system from the line side of a local emergency panel instead of tapping the line side of the main generator overcurrent protection device. | 600 Fifth Avenue<br>New York NY                   | Approved | \$0.00 |
| with the stipulation that approval is subject to other jurisdictions. |              |   |  |   |          |        |
| 47126   | **           | K & G Electric Co., Inc.<br>3925 Broadway<br>New York NY 10032                              | Requesting permission not to file full Advisory Board drawings on a 1000 KVA service where a 30 amp service switch is needed to power Con-Edison's steam pump.   | 60 Sutton Place South<br>New York NY              | Approved | \$0.00 |
|   |              |   |  |   |          |        |

# ADVISORY BOARD CALENDAR

**April 12, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                 | Status   | Fee      |
|--|--------------|---|--|---------------------------------------|----------|----------|
| 47127  | ***          | Genmar Electrical Contracting Corp.<br>98-19 103rd Avenue<br>Ozone Park NY 11417          | Requesting permission in a building that is presently fed with four sets of 500 MCM old RHH service entrance conductors in rigid steel conduit to add two additional sets of 500 MCM RHW-2 conductors in non metallic conduit to increase the size of the service. | 251-21 Jamaica Avenue<br>Bellerose NY | Approved | \$0.00   |
| with the stipulation that all of the raceways shall have the same physical characteristics as per Section 310.4.   |              |   |  |                                       |          |          |
| 47128  | 06A0215      | ProtectConnect<br>8835 Research Drive<br>Irvine CA 92618                                  | Requested approval for use in New York City of your ProtectConnect Modular Integrated Wiring System.   |                                       | Hold     | \$200.00 |
| 1) Certificate of compliance not provided for all model number(s). 2) Box labels altered.  |              |   |  |                                       |          |          |
| 47129  | 06A0216      | Nordic Logistics<br>311 S. Arlington Heights Rd., Suite 102<br>Arlington Heights IL 60005 | Requested approval for use in New York City of your T5 Fluorescent Light Fixtures. MR16 Halogen Light Fixture.   |                                       | Denied   | \$200.00 |
| 1) The U.L. report does not list the fixtures that were submitted. 2) The T5 fluorescent fixtures are not listed for the purpose intended. 3) The halogen portable fixture is not listed as double insulated. The length of the power cord is too long and must be subject to mechanical injury. 4) The main support grid must be approved by MEA as a hung ceiling. |              |   |  |                                       |          |          |
| 47130  | 06A0217      | Capstone Turbine Corporation<br>10101-C Avenue D<br>Brooklyn NY 11236                     | Requested approval for use in New York City of your Capstone Microturbine Energy Systems. Model/Series Numbers: C60, C60-ICHP, C65, C65-ICHP.  |                                       | Approved | \$200.00 |
| 47131  | 06A0218      | Danfoss Inc.<br>7880 Tranmere Drive<br>Toronto ON L5S1L                                   | Requested approval for use in New York City of your Danfoss GX Snow Melting System complete with GX 850. Model/Series Number: GX Series O88L.  |                                       | Hold     | \$200.00 |
| 1) Need wiring diagram showing separation of low voltage and line voltage (cutsheet) 2) Mounting box for GX850   |              |   |  |                                       |          |          |

# ADVISORY BOARD CALENDAR

April 12, 2006

| Calendar # | Submission # | Applicant Name and Address                                       | Type of Request  | Installation Location | Status   | Fee      |
|------------|--------------|--|--|-----------------------|----------|----------|
| 47132      | 06A0219      | Global Finishing Solutions<br>12731 Norway Rd.<br>Osseo WI 54758 | Requested approval for use in New York City of<br>your Paint Spray Booth, Prep Station, Mix Rooms &<br>Components. |                       | Approved | \$200.00 |
|            |              |  |  |                       |          |          |