

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50293CO2	10A0323CO2	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	McCarren Pool 776 Lorimer Street Brooklyn NY	Approved	\$0.00
Carry over from October 13, 2010 meeting. 1) Show tap length from 1600 amp switch to 600 amp switch. 2) Install note on portable generator switch saying: Don't ground neutral of generator to enclosure." 4) ATS overfused or emergency side. Job finalized June 15, 2012.						
50344CO3	10A0365CO3	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Denied	\$0.00
Void. See Cal. #50641.						
50407CO3	10A0425CO3	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	18 Richmond Terrace Staten Island NY	Approved	\$0.00
1200A frame CB in MDB-SC must be set to 1000A to protect 1000A ATS-2. 9/13/13 job finalized.						
50452CO	10A0470CO	Market Electric Inc. 2526 50th Street, Suite 201A Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Hampshire Building 2329 Nostrand Avenue Brooklyn NY	Approved	\$0.00
Carry over from December 22, 2010 meeting.						
50537CO	11A0053CO	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Bush Terminal 4302 First Avenue Brooklyn NY	Ok, but	\$0.00
Continue coordination study downstream of new switchgear.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50538CO	11A0054CO	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$0.00
Carry over from February 18, 2011 meeting. Install barrier between service switches 2H & 3H. Job finalized 6/29/11.						
50602	11A0106	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	30 West 31st Street New York NY	Hold	\$650.00
50603	11A0105	A.S.M. Electric & Machine Corp. 333 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	589 8th Avenue New York NY	Hold	\$650.00
Submission not in Advisory Board format.						
50604	11A0111	Kramer Electric, LLC 336 West 37th Street, Suite 510 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Hold	\$650.00
1) Length of tap not provided. 2) Explain new additional set of 600 MCM splice. Cannot mix 500's and 600's. 3) Show how many sets of conductors are feeding "DBI". 4) Existing 10 sets of 500 MCM are overfused. 5) Egress in area of new equipment is inadequate. Provide 2nd door,						
50605	11A0112	Contract Electric Corp. 1275 43rd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	958 Nostrand Avenue Brooklyn NY	Approved	\$650.00
House meter bus undersized. Job finalized 6/29/11.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50606	11A0113	Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	2 Park Avenue New York NY	Approved	\$650.00
1) Room layout of existing dangerous, 2) Remove existing metal fence in the service room and replace it with a non conductive type barrier or fence. Job finalized 8/22/11.						
50607	11A0114	ECS Electrical Contracting Services, Inc. 351 Kent Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Trader Joes 90-30 Metropolitan Avenue Rego Park NY	Approved	\$650.00
50608	11A0115	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Seville Apartments 18-15 215th Street Bayside NY	Hold	\$650.00
1) Transformer cut sheet not provided. 2) Explain by others. 3) Transformer grounding electrode conductor undersized. 4) Confirm transformer primary switch has adequate closing rating for transformer ? 5) Provide code compliant oil containment for transformer.						
50609	11A0116	Fresh Meadow Electrical Contractors, LLC 65-01 Fresh Meadow Lane Fresh Meadows NY 11365	Requested approval for the electric service equipment proposed to be installed	Columbia Refrigeration Plant 119 Amsterdam Avenue New York NY	Approved	\$650.00
50610	11A0117	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Lehman High School 3000 East Tremont Avenue Bronx NY	Approved	\$650.00
The length of the tapped conductor not shown. Job finalized 6/20/11.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50611	11A0118	ALL-Phase Electl & Security Contrg Inc. 5014 16th Avenue, Suite 217 Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	1623 Flatbush Avenue Brooklyn NY	Approved	\$650.00
50612	11A0119	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	350 West 42nd Street New York NY	Approved	\$650.00
50613	11A0120	P2 Electric, Inc. 416 Graham Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	240 Park Avenue South New York NY	Approved	\$650.00
50614	11A0121	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	421 West 113th Street New York NY	Approved	\$650.00
50615	11A0122	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Barclays Center Arena 620 Atlantic Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50616	11A0123	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon Network 210 West 18th Street New York NY	Approved	\$650.00
1) Verify if conductors are copper or AL. 2) Neutral bonded often disconnect link. Job finalized 4/21/11.						
50617	11A0124	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Ventura 240 East 86th Street New York NY	Approved	\$650.00
50618	11A0125	J.J. Rosenberg Electrical Contrs, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC 47 West 66th Street New York NY	Approved	\$650.00
1) 1200 amp service switches overfused. 2) Size of through bus not shown on Switchboard "1". Job finalized 5/3/11.						
50619	11A0126	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	United Nations-Phase II 150 East 42nd Street New York NY	Approved	\$650.00
50620	11A0127	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rudin Management 345 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50621	11A0128	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	40 Prospect Street Staten Island NY	Approved	\$650.00
50622	11A0110	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Brooklyn College, James Hall 2910 Bedford Avenue Brooklyn NY	Ok, but	\$650.00
Verify that service room is mechanically ventilated.						
50623	11A0108	Churchtower Bible and Tract Society of NY Inc 25 Columbia Heights Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	98 Montague Street Brooklyn NY	Approved	\$650.00
50624	11A0129	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	The NYCDEP Pumping Station 84 West 11th Street Brooklyn NY	Hold	\$650.00
1) Drawings are too small to read. 2) Verify that Con-Ed is feeding the buildings, what is the voltage drop 280'. 3) Service entrance conductors undersized. 4) Neutral disconnect link not provided. 5) Provide grounding scheme. 6) Free air ratings of conductors can't be used when installed in conduit. 7) Confirm that generator feeders are 3 or 4 wire. 8) Provide updated coordination study.						
50625	11A0130	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	64 East 111th Street New York NY	Approved	\$650.00
1) Verify that Con-Ed is bringing in the service conductors. 2) FCO to be switches. 3) Tap conductors undersized. 4) Verify grounding scheme. Job finalized 5/18/11.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50626	11A0131	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU Catholic Center 58 Washington Square South New York NY	Denied	\$650.00
1) Switchboard #1 the through bus is undersized. 2) Switchboard #2 bus size not shown. 3) Fire pump feed to be taken from line side of medium voltage 600 amp switch. 4) Electrical contractor's name not in the title block. 5) Engineer to appear to explain the job to the Board when resubmitted. 6) Drawings not reviewed in entirety.						
50627	11A0132	Associated Electl Contrs of NY Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	420 East 62nd Street New York NY	Approved	\$650.00
Remove spare 600 amp service switch. Job finalized 6/29/11.						
50628	11A0133	Lizardos Mechanical & Electrical Eng 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	New York Hospital Queens 56-45 Main Street Flushing NY	Approved	\$650.00
50629	11A0134	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	91 5th Avenue New York NY	Approved	\$650.00
1) 2nd means of egress required or relocate equipment. 2) Is equipment front or rear accessible, if front accessible only barrier off back of board. Job finalized 6/28/11.						
50630	11A0135	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	851 Grand Concourse Bronx NY	Denied	\$650.00
1) Contractors name and job address is not in the title block. 2) Generator emergency board not grounded and bonded. 3) Generator room layout not provided. 4) Generator cut sheet not provided. 5) Show MI transition to copper bus or lower trip rating on circuit breaker. 6) Bus size missing in EMPP. 7) Are switchboards rear accessible? 8) Show all clearances in service room. 9) Section bus not shown on drawing.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50631	11A0136	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai Hospital 1468 Madison Avenue New York NY	Approved	\$650.00
50632	11A0137	Lektric Installations Corp. 3802 Church Avenue Brooklyn NY 11203	Requested approval for the electric service equipment proposed to be installed	Hunter College 695 Park Avenue New York NY	Approved	\$650.00
50633	11A0138	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	1800 Southern Blvd. Bronx NY	Approved	\$650.00
50634	11A0139	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	330 West 39th Street New York NY	Approved	\$650.00
1) ATS room to be 2 hour fire rated. 2) Clarify fire pump type. 3) Verify size of transformer. Job finalized 6/29/11. 7.22115 Swapped drawings 1,2 and 3, Revision 4s. 2/11/16 Swapped drawings 1,2,3-Revision 5.						
50635	11A0140	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	New York City Center 130 West 56th Street New York NY	Approved	\$650.00
1) Are feeders copper or AL. 2) Show tap detail in service trough. Job finalized 6/30/11.						

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50636	11A0141	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1585 Broadway New York NY	Approved	\$650.00
3000 amp service switch not GF protected Switchboard "D". Job finalized 5/18/11.						
50637	11A0142	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	470 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
3000 amp service switch not GF protected Switchboard "D". Job finalized 5/18/11.						
50638	11A0143	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	11 Broadway Brooklyn NY	Approved	\$650.00
3000 amp service switch not GF protected Switchboard "D". Job finalized 5/18/11.						
50639	11A0144	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Inwood Opportunity LLC 1500 Pelham Parkway South Bronx NY	Approved	\$650.00
Neutral to be installed in fire pump servcie switch #2. Job finalized 5/2/11.						
50640	11A0145	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NY Academy of Medicine 1216 Fifth Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50641	11A0107	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board format, circuit breakers and interlocking connections not identified, key interlocking scheme not shown on drawing. 2) Show all clearances between equipment walls and support columns. 3) Transformer cut sheets not provided. 4) Service room doors to open outwards. 5) Show that transformers can be worked on when deenergized. 6) Verify that room layout was approved by Con-Ed. 7) Coordination study not complete.						
50642	11A0109	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Steven and LIJ Alexandra 269-01 76th Avenue New Hyde Park NY	Approved	\$650.00
1) MCB's in SS-HV-B require GF tripping. Confirm this is provided. 2) Correct drafting on secondary of substation transformers-neutral and phase swapped. 3) Provide GF indication on 480V secondary main of emergency substation. Job finalized 7/22/11.						
50643	11A0146	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med 1225 Morris Park Avenue Bronx NY	Hold	\$650.00
Not Advisory Board format.						
50644		Altman Electric 283 West 11th Street New York NY 10014	Requesting permission to leave as installed as a wiring method in a place of assembly AC cable that does not contain an insulated equipment grounding conductor.	Gravy Restaurant 32 East 21st Street New York NY	Approved	\$0.00
50645		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission to leave as installed as a wiring method in a place of assembly AC cable that does not contain an insulated equipment grounding conductor.	112-03 101st Avenue Queens NY	Approved	\$350.00

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50646		M & M Electric Inc. 1076 Castleton Avenue Staten Island NY 10310	Requesting permission on a job where 6 existing circuit breaker panels and conduits are recessed in masonry walls will be retrofitted with new interiors by a listed shop, to allow 6 backboxes to remain in place where the center grip of the circuit breaker when in its highest position is 7'11" at the highest mounted panel.	PS 139 330 Rugby Road Brooklyn NY	Approved	\$0.00
50647		Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requesting permission to leave as installed two 208/480 volt transformers facing 2-208 volt panels with clearances of 3'8" and 3'10" between live parts on both sides of the working space	East River Science Park 450 East 29th Street, 4 & 5th Floors New York NY	Approved	\$0.00
50648		B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requesting permission to leave as installed under counter lighting connected to the small appliance branch circuit.	160 Schermerhorn Street Brooklyn NY	Denied	\$350.00
50649		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to waive coordination requirement between the 3500 amp service switch fuse and the 3000 amp second fuse and to fuse 10 sets of 600 MCM AL conductors at 3500 amps and not submit drawings on a 1000 KVA temporary service that will last approximately 1 year.	Madison Square Gdn Core & Shell New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**April 13, 2011**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50650		Abstract Electrical Contractors, Inc. 18--60 45th Street Astoria NY 11105	Requesting permission to leave as installed replacement service trough and C.T. cabinet where Con-Ed replaced the underground service lateral conductors on an existing 1000 KVA service where the equipment was damaged due to construction of the 2nd Avenue subway system.	1779 2nd Avenue New York NY	Approved	\$350.00
50651		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission for like and kind replacement of equipment operating in excess of 600 volts.	Fordham Preparatory School 441 East Fordham Road Bronx NY	Hold	\$0.00
Show in rush current of new 480 volt switch.						
50652		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission for like and kind replacement of feeders in excess of 600 volts	Fordham University 441 East Fordham Road Bronx NY	Approved	\$0.00
50653		Quenzer Electric Systems, Inc. 11 West 25th Street, 9th Floor New York NY 10010	Requesting permission to replace 2 existing circuit breaker panels with new panels that are listed for 60 circuits due to limited space.	Con ED 30 Flatbush Avenue Brooklyn NY	Approved	\$0.00
50654	11A0147	Melink Corporation 5140 River Valley Road Milford OH 45150	Requested approval for use in New York City of your Variable Speed Controller. Model/Series Numbers: REM-1 Intelli-Hood.		Approved	\$200.00
With the stipulation that the equipment bears the listing label.						