

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0720CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Queensboro Comm. College 222-05 56th Avenue Queens NY	Pending	\$0.00
Carry over from December 16, 2015 meeting. Equipment cut sheet do not show rear doors, layout drawing doesn't match manufacturer's cut sheets.						
54016	16A0003	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	424 East 34th Street New York NY	Approved	\$650.00
1) Indicate breaker size for CB 5-F1, and CB2--F1. 2) Correct GF sensors representation between oneline and the schematic. Rejected, Item #2 not addressed. 7/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53916	16A0017CO	Arc Electrical & Mechanical Cont. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	2858 Stillwell Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 10, 2016 meeting. 1) Equipment grounding conductor supplying fire pump undersized. 2) The emergency system must selectively coordinate. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/23/16 revision number is not correct ( Rev 3 instead of Rev 2). 1/11/17 Swapped drawing 2 of 3-Revision 3.						
	16A0020CO	Jemco Electrical Contractors, Inc. 21-71 Steinway Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	760 Broadway New York NY	On Hold	\$0.00
Carry over from March 9, 2016 meeting. 1) Fire alarm service switch to be fed from load side of CT not ATS. 2) All ATS' rated at 50,000 withstand rating with 180,000 incoming verify ratings. 3) Provide physical showing barriers in the twin 4000 amp switches. 4) Show fault current at devices on 1 Line. 5) GTB the breaker to be 4 pole type.						
	16A0021CO	I.P. Electrical Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	320 West 36th Street New York NY	On Hold	\$0.00
Carry over from January 13, 2016 meeting. 1) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable 2) MI transition conductors sizes and wiring methods not shown. 3) Main bonding jumper undersized. 4) Coordination study has seven point that must be addressed and coordinated. 5) Elev-PH2-1 must coordinate normal and emergency sides as per Article 620.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53938	16A0026CO	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	606 West 57th Street New York NY	Approved	\$0.00
<p>Carry over from February 10, 2016 meeting. 1) Verify that Time Warner service switch complies with 110.26(A)(2). 2) Identify fire pump transformer in service room. 3) DP-Gen panel undersized for parallel generators. 4) Fire pump to be identified as fire pump not special service fire pump. 5) Short circuit study does not show full curves. 6) Emergency system for elevators, exit signs voice communications required. 6/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0027	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	217 West 57th Street New York NY	On Hold	\$650.00
<p>1.Dwg K feeder to Switchboard – RI- FP undersized                  2.Swbd – em over fused , dwg K                  3.F.A. Transformer tap length not shown, dwg K                  4.Dwg K does not indicate feeders are installed in fire rated enclosure                  5.Dwg K does not show 600 amp fire pump switch or feeded                  6.Show bus size on 4000 amp on Substation 1 &amp; where is it located                  7.Switch board RI has more than 6 service switches                  8.Future switch boards to be identified on room layout                  9.Show substation room layout</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                  The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                  NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.                  Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PW1 as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer.</li> </ol>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53928	16A0058CO	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	IS 323 75 Morton Street New York NY	Approved	\$0.00
Carry over from February 10, 2016 meeting. 1) Verify 2 sets 500 MI to fire pump. 2) Verify amount of conductors between sections of EMDB panel. 3) Verify that no tails will be used for 4/0 MI conductors. 6/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53830	16A0073	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	111 Murray Street New York NY	Approved	\$650.00
<p>1.Fire Pump &amp; Fire Alarm service switches not shown on room layout</p> <p>2.If fire alarm service switch is mounted under its trans 5' front clearance is required</p> <p>3.Verify 5' front clearance in front of 5 KV switch FP40-1</p> <p>4.AB 20 – 1 – typo retail trough trans identified as Fire Alarm Trans S</p> <p>5.AB 20 – 1 – verify that no cable support boxes for service entrance conductors will be installed 6.Transformer primary conductors undersized for 750 KVA transformers</p> <p>7.Coordination study, signed, sealed and performed by a P.E. not provided. 5/23/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
	16A0106	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	203 Jay Street Brooklyn NY	On Hold	\$650.00
<p>1) Length of transformer secondary's not shown, DWG 1. 2) Emergency side EGC to panel "PPELR" undersized, Dwg 1. 3) Show short circuit current at fire pump, DWG 1. 4) Main 2 and 3 cond undersized, DWG 1. 5) Verify connector of 1200 amp switch on load side of Main 1, DWG 1. 6) DWG 2, length of transformer secondary's not shown. 7) EGC undersized on load side of DRRB main, and transformer. 8) F.A. transformer secondary is not protected. 9) Show coordination between s.s. and 1600 cb, and 1600A cb and meters. 10) Gen voltage has discrepancy.</p>						
53911	16A0107	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	239 10th Avenue New York NY	Approved	\$650.00
<p>1.Block off rear of switch board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0108	Freedom Electrical & Data, Inc. 20 Engert Street Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Pace University 41 Park Row New York NY	Pending	\$650.00
<p>1.Fire Alarm ATS and their emergency feeders shall not be located in the same room with the service equipment with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0119	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Tower A 500 West 33rd Street New York NY	Denied	\$650.00
<p>1) Emergency feeder to ED-DSFP-S2(B) undersized. 2) Verify that compact conductors will be used to feed switchboard. 3) Verify that 5000 amp generators switchboards are listed. 4) Equipment grounding conductors on load side of 5000 amp switches with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/28/16 Denied. 1) Emergency feeders to fire pumps fused 3 times. 2) Provide submission or approval # for normal fire pump feeders. 3) Show normal feeders to fire pumps or approval # from others with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53651	16A0129CO	GTS Electrical 218-14 Northern Blvd. Bayside NY 1136	Requested approval for the electric service equipment proposed to be installed	41-22 24th Street Queens NY	Approved	\$0.00
<p>Carry over from February 10, 2016 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53627	16A0178	RS Covello Electric 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	47-49 East 34th Street New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53915	16A0181CO	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	210 Livingston Street Brooklyn NY	Approved	\$0.00
<p>Carry over from March 9, 2016 meeting. Fire alarm emergency side EGC undersized. To ATS. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53657	16A0187	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	29-10 Thomson Avenue Long Island City NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0196	Verde Electric Corp. 811 Whittier Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	500 West 33rd Street New York NY	On Hold	\$650.00
<p>1) No coordination study. 2) Indicate the special permission or showhow complied with. 3) Show the co-gen protection and room layout.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site forinspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53908	16A0201CO	Folks Electrical Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	257 West 39th Street New York NY	Approved	\$0.00
<p>Carry over from March 9, 2016 meeting. New SS and distribution are mislabeled. 6/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/16 Swapped drawings 1 and 2-Revision 3s.</p>						
53633	16A0204	A & M Electrical Services, Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	100 Bogart Street New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53658	16A0210	M.R. Electrical Service LLC 204 Walworth Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	26 West Street Brooklyn NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/16 Swapped drawing 1-Revisin 1.</p>						
53628	16A0213	John Stassi, Licensed Electrician 4347 Hylan Boulevard Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	343 Gold Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53634	16A0216	1 Arlington Electric LLC 307 West 38th Street, Suite 907 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	45 East 45th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0232	EDM Electric 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	30 West 46th Street New York NY	Denied	\$650.00
<p>1) Bus on load side of 4000 amps to be 800 amps square inch for the first 4', 1 Line does not match physical. 2) Explain panel "PPR" between fire pump service switch and fire pump. 3) Fire pump feeders not fire rated. 4) Fire pump equipment ground undersized normal side. 5) Feeder and conduit size to load bank not shown. 6) Equipment grounding conductor to generator distribution panel undersized. 7) Equipment grounding conductor to service switch #2 undersized with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0245	Landmark Facilities Group, Inc. 252 East Avenue Norwalk Ct 06855	Requested approval for the electric service equipment proposed to be installed	32-42 Broadway New York NY	Denied	\$650.00
<p>1. Not in Advisory Board format 2. Verify MI Cables, Feeders</p>						
53632	16A0246	Kramer Electric, LLC 28 West 27th Street, Suite 701 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	170 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53844	16A0247	Control Spec Electrical System, Inc. 3060 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Plaza 163 445 East 163rd Street Bronx NY	Approved	\$650.00
<p>OR Panel MDP 10' tap rule exceeded. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This submittal voids out 52758. 5/25/16 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53629	16A0248	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1035 Third Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54029	16A0249	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	325 Kent Avenue Brooklyn NY	Approved	\$650.00
<p>Fire pump feeder to be fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/1/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53917	16A0252	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	444 Park Avenue South New York NY	Approved	\$650.00
1) Fire pump service entrance conductors, service switch, emergency switch and feeders undersized. 2) Tapped conductors undersized. 3) Emergency side EGC for tapped conductors undersized. 4) Fire alarm SEC feeders on normal and emergency sides overfused. Check voltage drop for "bar" panel located on 14th floor. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53659	16A0254	Allran Electric 120 Broadway,36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties 450 West 33rd Street New York NY	Approved	\$650.00
This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53609	16A0256	Hatzel & Buehler, Inc. 260 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	225 Liberty Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54059	16A0257	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	55 Water Street New York NY	Approved	\$650.00
OR 1) Move new equipment against wall to provide better access around switchboard. 2) Equipment grounding conductor for service entrance conductors undersized. 8/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53937	16A0259	M.C. Electrical NY Inc. 843 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	31-00 47th Avenue Long Island City NY	Approved	\$650.00
Block space between equipment. 6/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 Swapped drawing FP-01-Revision 2.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53927	16A0260	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1283 York Avenue New York NY	Approved	\$650.00
<p>1) Fire pump emergency fusing undersized. 2) Provide 1 Line coordination drawing. 3) Address discrepancies on short circuit study. 4) Add note that ATS' do not supply life safety loads with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/22/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53630	16A0261	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Israel Senior Citizen Housing 1925 Seagirt Boulevard Far Rockaway NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53631	16A0262	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Israel Senior Citizens Housing 155 Beach 19th Street Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53904	16A0263	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	640 5th Avenue New York NY	Approved	\$650.00
OR Switchboard MDP-1 section bus undersized where new 1200 amp switch is installed. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53626	16A0264	Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	201 West 21st Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Swapped Drawing 1-Revision1.						
53614	16A0265	Purcell Electrical Contractors, Ltd. 138-30 241 Street Rosedale NY 11422	Requesting permission to install Schedule 80 non-metallic conduit as a wiring method for overhead services conductors and branch circuit wiring in a corrosive area close to the water front in Far Rockaway, Queens for 12 two family homes..	See job addresses in comments	Approved	\$0.00
62-07, 62-03, 62-13, 62.-15, 62-19, 62-21, 62-25, 62-27, 62-31, 62-33, 62-39 and 62-43 Decosta Avenue, Far Rockaway, Queens Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53660	16A0266	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Culture Shed 545 West 30th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0267	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	30-02 Queens Blvd., Bldg. B2 Queens NY	Pending	\$650.00
OR 1) There is no 3000 amp switch on Approval #53466. 2) Bonding and grounding to comply with 250.32(B). 3) Electrical equipment room to be ventilated. 4) Tap conductor to 800A disconnect switch undersized. 5) Secondary of 300 KVA transformer not bonding and grounding.						
	16A0268	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	28-34 Jackson Avenue, Bldg 1 Queens NY	Pending	\$650.00
OR 1) There is no 2500 amp switch on Approval #53466. 2) Bonding and grounding to comply with 250.32(B).						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53661	16A0269	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	280 St. Marks Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0271	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1711 First Avenue New York NY	Rejected	\$650.00
<p>Correct ground at Gen emergency board with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/20/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/16 Rejected 1) When is 40 HP fire pjp splice box located, 3M interam mat cannot be used to wrap individual conductors. Note not clear (cable?). Fire pump splice not 2 hour fire rated. 2) Coordination study to be updated reflecting changes. 3) Explain comment 1A.</p>						
53615	16A0273	Southheights Electric 30 Havemeyer Street Brooklyn NY 11211	Requesting permission to leave as installed service equipment mounted on the outside of a building that was replaced due to flooding from hurricane Sandy where the old service was located in a 4' crawl space subject to flooding..	217 Van Brunt Street Brooklyn NY	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53641	16A0274	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	945 Madison Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/24/16 Swapped drawing 1-Revision 1						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0276	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	28-30 Jackson Avenue Long Island City NY	Denied	\$650.00
<p>1.Approval #15A0735 is Denied                  2.Switch Sizes &amp; over current devices feeders equipment for this submittal not shown on this drawing                  3.MOS-2 middle section switch &amp; fuse size not shown                  4.Show length of transformer secondary taps for A2 &amp; B2                  5.Transformer secondary's do not comply with tap rules                  6.Transformer A2 conductors &amp; conduits not shown                  7.Fire alarm to be tapped ahead of service switched with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                  The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                  NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53926	16A0277	Striano Electric Co., Inc. 246 Park Avenue Garden City Park NY 11040	Requested approval for the electric service equipment proposed to be installed	Bank of China 7 Bryant Park New York NY	Approved	\$650.00
<p>1) Verify that rear doors of paralleling switchgear can fully open with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                  The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the North field evaluation report is to be kept on site for inspector review.                  NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Fire alarm panel to have 3' front clearance. 3) AB50-2 #6 tap conductors undersized for 25' taps. 4) Address the double neutral rerternce on the double ended substation. 6/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53646	16A0278	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1133 6th Avenue New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53654	16A0279	Hugh O Kane Electric Co., LLC 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1221 Avenue of the Americas New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/16 Swapped drawings AB sheets 1 and 2-Revision 3. FP-Revision 1. SB sheets 1,2,3 and 4-Revision 2s.						
53662	16A0281	M.R. Electrical Service LLC 204 Walworth Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	37-14 36th Street Long Island City NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53951	16A0282	Contact Electric Corp. 1252 53rd Street Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	94 North 3rd Street Brooklyn NY	Approved	\$650.00
1.MSB - Service entrance conductors and service Bus from Con-Ed box to first section containing 1200 & 800 amp service switches under sized 2.Provide cut sheets of meter banks & breakers. 6/28//16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53663	16A0283	Heso Electrical Inc. 30-36 41st Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	211 West 14th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing 1-Revision 1.						
53788	16A0284	Metropolis Electric Corp. 11-36 31st Avenue Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	30 East 62nd Street New York NY	Approved	\$650.00
OR 1) New loads can't be connected to a switch containing fuse links. 2) Show coordination between first and second fusing. 3) Incoming short circuit current not shown, 4/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53664	16A0285	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	1024-1036 White Plains Road Bronx NY	Approved	\$650.00
<p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53934	16A0287	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	50-51 98th Street Queens NY	Approved	\$650.00
<p>1.ATS - SDP to be 4 Pole with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
54020	16A0288	Megarix Electrical Contracting 21-20 45th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	555 Broome Street New York NY	Approved	\$650.00
<p>1) MI cable for fire pump undersized. 2) Show detail of how MI cable will be transitioned into ATS and service switch and emergency disconnect switch. 4) Correct typo in ATS supplying DP-OSB with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0291	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue, 6th Floor New York NY 10017	Requested approval for the electric service equipment proposed to be installed	309 West 49th Street New York NY	Denied	\$650.00
<p>1. Water damage equipment to be replaced or tested by an NETA certified Testing Agency and witnessed by a P.E. who will Sign, Stamp the test report 2. Is the existing equipment manufactured by Lincoln Electric</p>						
	16A0293	Jorob Contracting and Electrical Co. Inc. 040 Avenue of the Americas, Lower Level New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1050 Avenue of the Americas New York NY	Denied	\$650.00
<p>1) Identify service switches in service room. 2) Service switch clearances to comply with 230.64(B)(1). 3) Verify that the utility is supplying 10 sets of service laterals. 4) Fire pump wiring methods not shown. 5) Fire pump fire rated conductors to be installed as per manufacturer's installation instructions. 6) Verify fire pump fire rated conductors to service switch. 7) Fire pump service entrance conductors and feeders undersized. 8) Neutral in 30 amp F.A. switch not bonded to enclosure. 9) Remove 2nd 30 amp F.A. switch on emergency side. 10) Lengths of taps not shown. 11) Tap conductor undersized. 12) Verify bus sizes in switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0294	Azen and Sawyer Environ. Eng's & Scientists 498 Seventh Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	3701 Jerome Avenue Bronx NY	On Hold	\$650.00
53948	16A0295	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	Brooklyn Bridge Park Pier 5 334 Furman Street Brooklyn NY	Approved	\$650.00
<p>1) Secondary of transformer to be grounded SEC. 2) 1200 amp 480 volt switch to be ground fault type. 3) Bus feeding 2000 amp service switch undersized. 4) 2000A S.S. GCE and water/supplemental. 5/25/16 Rejected 1) Secondary of transformer to be bonded and grounded in one location not two. 2) Item #3 not addressed. 3) Equipment grounding conductor to transformer undersized. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53665	16A0297	Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	51-2359 Adam Clayton Powell Jr. Bl New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53635	16A0299	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	245 7th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53923	16A0300	NYC Electrical Contractors Inc. 150 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1040 Dean Street Brooklyn NY	Approved	\$650.00
1. Service Bus feeding 2000 & 400amp service switcher undersized. 6/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/25/16 Swapped drawings 1, 2, & 3-Revision 2s.						
53924	16A0301	NYC Electrical Contractors Inc. 150 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	436 Albee Square Brooklyn NY	Approved	\$650.00
<p>1.Fire pump feeder not fire rated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/21/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53666	16A0302	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	60 West 23rd Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1 and 2-Revision 1.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53775	16A0304	Power Masters Electrical Contracting Inc, 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	420 Madison Avenue New York NY	Approved	\$650.00
1.TAP Conductor to 100 amp disconnect switch under sized. 4/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53668	16A0305	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	123/125 Parkside Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/16 Swapped drawings 1,2 and 3-Revision 1s.						
53669	16A0306	Horsepower Electric 821 McDonald Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	200 East 95th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53644	16A0307	Noble Electrical Contracting Co., Inc. 1794 Clinton Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	804 East 138th Street Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0308	MJC Electric Inc. 10-11 46th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	5655 Arlington Avenue Bronx NY	Rejected	\$650.00
<p>1) Show clearance in front of new pull box in service room and indicate the height of pull box. 2) Fire rated fire pump conductors not installed as per manufacturer's installation instructions. 3) Fire pump emergency conductors and wiring method not shown. 4) Switchboard 1 Line does not match physical with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/20/16 Rejected</p> <p>1) Fire alarm ATS not to be installed in the main service room. 2) Fire rated conductors not installed as per manufacturer's installation instructions. 3) Pole ATS installed on a non separately derived system for fire alarm with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p>						
53953	16A0310	APS Electric Inc. 82-32 Parsons Blvd Jamaica NY 11432	Requested approval for the electric service equipment proposed to be installed	172 Madison Avenue New York NY	Approved	\$650.00
<p>1) MDP-C-H fuses don't coordinate with 1200 amp main fuse. 2) S.S. #2-1600 amp fuse does not coordinate with 600 amp fuse in MDP-2-HA with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53772	16A0312	Rodel Electrical Contractors, Inc. 31-29 Vernon Blvd. Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	650 Academy Street New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/30/16 Swapped drawings 1,2 and 3-Revision 3s.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53640	16A0313	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Cheesecake Factory 90-15 Queens Boulevard Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53639	16A0314	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	1625 Forest Avenue Staten Island NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53637	16A0315	Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	MOMA 11 West 53rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53906	16A0317	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	60 East 42nd Street New York NY	Approved	\$650.00
Service room doors to open outwards. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53903	16A0318	JSP Electrical Contracting Corp. 187 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	3 East 28th Street New York NY	Approved	\$650.00
OR 1) Service bus feeding 1200 amp SS and fire pump undersized. 2) Show bonding and grounding of 600 amp service switch. 6/14/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53914	16A0319	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	175 Delancy Street New York NY	Approved	\$650.00
<p>1.Fire Alarm ATS to be 4 pole type with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/20/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53851	16A0322	Robert B. Samuels, Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1290 Sixth Avenue New York NY	Approved	\$650.00
<p>1.Generator Feeders &amp; Distribution Panel over fused 2.Section Bus Undersized. 6/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53843	16A0324	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	69 East 125th Street New York NY	Approved	\$650.00
<p>1) One line doesn't match physical sections 1 and 2. 2) Rear of switchboard to comply with 230.64(B)(4). 5/25/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53955	16A0325	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	B3 Atlantic Yard 30 6th Avenue New York NY	Approved	\$650.00
<p>1. Service Switchboard #4 show tap method for 3 sets of 600 KCM to 6 sets of 500 KCM to Panel DP-R</p> <p>2. Verify that service Bus complies with Section 368.119</p> <p>3. Verify set of conductors between panel DP-R, 1 line and physical don't match with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/15/15 Swapped Drawings A-Revision 3; Drawing C-Revision 3; Drawing D-Revision 3 and Drawing E-Revision 4.</p>						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0326	Sheridan Electric, Ltd. 197 Grand Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	99 Washington Street New York NY	Denied	\$650.00

1) 1 Line doesn't match physical or room layout (MD5-2). 2) Fire pump wires are undersized and shall be fire rated. 3) Remove purge panel from F.A. ATS and load. 4) Coordination study is not provided with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/22/16 Denied 1) Item #4 not addressed. 2) wiring method for special service fire pump not shown. 3) Verify bus size to service switches #3 and #6. 4) Verify conductor type to panel DP-2 and # of conduits. 5) Conductors to EDP-2, panel overfused. 6) Provide conductor spec's for type EDPM conductor. 8) Fire pump service switch to be provided with neutral conductors to be bonded and grounded - Review stopped. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer

53935	16A0327	Centrifugal Electric 7 West 36th Street, 6th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	310 West 40th Street New York NY	Approved	\$650.00
-------	---------	--	--	-------------------------------------	----------	----------

1.500 KVA Transformer secondary to be bonded & grounded in one location with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 Swapped drawing 1-Revision 3

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0329	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	225 Liberty Street New York NY	Pending	\$650.00
OR 1) Bonding, grounding, neutral link not shown on existing service. 2) Tap conductor to new 400 amp switch undersized.						
54312	16A0330	Accurate Electrical Corp. 11-07 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	152 East 87th Street New York NY	Approved	\$650.00
<p>1. Verify Bus sizes to 1600 amp service switch                  2. Show Bus Size on line side of 3000 amps service switch                  3. Provide coordination study per formed, signed, sealed by a P.E. for emergency System                  4. Verify Fire Rated Door for Emergency Room</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/25/16 Coordination study need to be signed and sealed by a P.E. 1/5/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53645	16A0331	Contact Electric Corp. 3561 12th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	50 Murray Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53647	16A0335	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	125 West 55th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53653	16A0336	Hylan Datacom & Electrical, LLC 455 Morgan Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	DOT Battery Tunnel Underpass  New York NY	Approved	\$0.00
SANDY Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53638	16A0337	Triple I Electrical Contracting 64-05 34th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Steel Works 75 North 4th Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53643	16A0338	J.L.C. Electrical Contractors, Inc. 14-45 Broadway Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	40 East 84th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53770	16A0339	Horsepower Electric 188 21st Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	36 Bleeker Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53636	16A0340	Dynamic Electrical Contractors Inc. 1650 Eastern Parkway, Suite #403 Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	508 West 24th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 13, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53771	16A0341	Ark System Electric Systems Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Marshak Science Tower 181 Convent Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53648	16A0342	Phasepoint Electrical Contracting Inc. 117 Grattan Street, Suite 113 Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	305 West 57th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53649	16A0343	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	63 Flushing Avenue, Bldg. 293 Brooklyn NY	Approved	\$650.00
OR With the stipulation that SE20KUS Solar Gage three phase inverters can be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0344	E & M Electrical NY Corp. 193-02 Northern Blvd. Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	34-37 36th Street Queens NY	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Is any bus work being installed in service switch. 3) Contractors name to be in title block. 4) Who is Solar One?						
53642	16A0347	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	101 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						