

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44658CO2	03A0061CO2	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Focal 325 Hudson Street New York NY	Approved	\$0.00
Originally on February 26, 2003 meeting.						
45443CO	04A0025CO	Flemington Electrical Maintenance Inc. 207 West 25th Street-7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging Corp. 494 Wortman Avenue Brooklyn NY	Approved	\$0.00
Carryover from February 18, 2004						
45504CO	04A0075CO	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	7 World Trade Center New York NY	Approved	\$0.00
Carryover from March 17, 2004 meeting.						
45508CO	04A0079CO	Hugh O Kane Electric Co., LLC 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1290 Avenue of the Americas New York NY	Approved	\$0.00
Carryover from March 17, 2004 meeting.						
45509CO	04A0080CO	Qnnc Electrical Contg. Corp. 86-40 122nd Street Richmond Hills NY 11418	Requested approval for the electric service equipment proposed to be installed	Kings County Hospital Brooklyn NY	Approved	\$0.00
Carryover from March 17, 2004 meeting. 1) Square D sect views. 2)Correct short circuit current.						

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45510CO	04A0081CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	NYU School of Medicine Joan & Joel Smilow Research Center New York NY	Approved	\$0.00
Carryover from March 17, 2004 meeting. With the stipulation these drawings are approved for the normal equipment only. The emergency generator and their loads are to be resubmitted for approval.						
45514CO	04A0085CO	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	146 West 29th Street New York NY	Approved	\$0.00
Carryover from March 17, 2004 meeting.						
45516CO	04A0087CO	AA Reale Electric Inc. 4223 1st Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	42 Bridgewater Street Brooklyn NY	Approved	\$0.00
Carryover from March 17, 2004 meeting.						
45558CO	Lektric Installations Corp. 3802 Church Avenue Brooklyn NY 11203	Requesting permission to leave as installed service equipment on the outside of a building that consists of one dwelling and one commercial space.	94-33 Corona Avenue Elmhurst NY	Denied	\$0.00
Carryover from March 17, 2004 meeting. Section 230.70(A) of the New York City Amendments to the 2002 National Electrical Code requires the service switches for a commercial building to be installed at a readily accessible location inside a building or structure nearest the point of entrance of the service conductors.						
45573CO	04A0130CO	Kinetics Industries, Inc. 1101 Southerfield Road Americus GA 31719	Requested approval for use in New York City of your DC Power Rectifier.		Approved	\$0.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45574	04A0131	Mass Electric Construction Co. 150-50 14th Road Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Biltmore Theatre 261-65 West 47th Street New York NY	Approved	\$650.00
Proper Advisory Board submission required.						
45575	04A0132	Unisys Electric Inc. 19 Irving Place Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard 63 Flushing Avenue-Building 500 Brooklyn NY	Hold	\$650.00
Proper Advisory Board submission required.						
45576	04A0133	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	426 West 58th Street New York NY	Approved	\$650.00
1) Service cables to switchboard 'ODB' undersized. 2) Service cable to 200A meter and service switch undersized. 3) Indicate available short circuit current at circuit breaker panels. Job finalized on 10/5/04.						
45577	04A0134	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1829 Lexington Avenue New York NY	Approved	\$650.00
Proper Advisory Board submission required.						
45578	04A0135	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	LIRR Atlantic Terminal Brooklyn NY	Approved	\$650.00
Provide code required clearances around service switchboard. 8/23/04-Approval granted.						

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45579	04A0136	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Shea Stadium Flushing NY	Approved	\$650.00
45580	04A0137	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Upper East H.S. 411 East 76th Street New York NY	Approved	\$650.00
45581	04A0138	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hearst Building 959 Eighth Avenue New York NY	Approved	\$650.00
45582	04A0139	The Sound Beyond Electrical Corp. 134 West 29th Street-11th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Dept. of Sanitation Marick St.-Brooklyn District Garages Brooklyn NY	Approved	\$650.00
45583	04A0140	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Times Headquarters 620 Eighth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45584	04A0141	L & L Electric & Power Corp. 24-20 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	301 East 45th Street New York NY	Approved	\$650.00
45585	04A0142	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Env. Protection 593 East 132nd Street Bronx NY	Hold	\$650.00
1) Service entrance conductors from end box to C.T. not marked. 2) No copper size in end box bus detail. 3) Show bonding and grounding of service switch. 4) Fire pump information not provided. 5) Clarify normal feed for fire pump sets of 4/0 MI? 6) Cutler Hammer representative to appear at next meeting.						
45586	04A0143	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Envirmtl Protection 432 East 110th Street New York NY	Hold	\$650.00
Not reviewed. See submittal 45585. Cutler Hammer representative to appear at next meeting.						
45587	04A0144	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Cornell University 1300 York Avenue New York NY	Denied	\$650.00
1) The existing feeders from the load of the 2500 kv transformer to the switchboard are undersized. 2) The bus in existing switchboard #1 is undersized. 3) The new 2000 amp switch must have ground fault protection.						
45588	04A0145	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Hospital Cancer 6300 8th Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45589	04A0146	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	2 Metro Tech Center Brooklyn NY	Approved	\$650.00
45590	04A0147	CMS Electrical Service Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	CB Richard Ellis 787 Seventh Avenue New York NY	Approved	\$650.00
45591	04A0148	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	875 Sixth Avenue New York NY	Ok, but	\$650.00
Increase size of service entrance conductors by one set.						
45592	04A0149	Absolute Electrical Contrg. Inc. One Cross Island Plaza-Suite 109 Rosedale NY 11422	Requested approval for the electric service equipment proposed to be installed	New York Sports Club 503 Broadway New York NY	Approved	\$650.00
1) Service entrance conductor undersized by one set. 2) Supplemental ground not provided. 3) Coordination curves not provided. Job finalized 12/4/07.						
45593	04A0150	Intrepid Electrical Contg Co., Inc. 149 Waterbury Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Allen Stevenson School 128 East 78th Street New York NY	Ok, but	\$650.00
1) Clarify feeder to fire pump. 2) Show wire size between sections DP-A. *Note-Load side of 800 amp service switch can be 2 sets of 500 MCM.						

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45594	04A0151	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Embassy Suites-Battery Pk 102 North End Avenue New York NY	Approved	\$650.00
45595	04A0152	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	484 Baltic Street Brooklyn NY	Approved	\$650.00
45596	04A0153	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	757 Bushwick Avenue Brooklyn NY	Approved	\$650.00
45597	04A0154	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	535 Dean Street Brooklyn NY	Approved	\$650.00
45598	04A0155	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	226 West 46th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45599	04A0156	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	1100 Park Avenue New York NY	Approved	\$650.00
45600	04A0157	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Riverside South Bldg."G" 33 West 66th Street & Freedom Plac New York NY	Approved	\$650.00
45601	04A0158	Vintage Electric Corp. 4620 Flatlands Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	300 East 39th Street New York NY	Approved	\$650.00
45602	04A0159	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	720 Park Avenue New York NY	Approved	\$650.00
45603	04A0160	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	165 Charles Street New York Ny	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45604	04A0161	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Hotel Beacon 2130 Broadway New York NY	Approved	\$650.00
45605	04A0162	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	217 East 96th Street New York NY	Approved	\$650.00
45606	04A0163	Stanco Systems Electrical Contg. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	100 Washington Square East New York NY	Approved	\$650.00
45607	04A0164	Stanco Systems Electrical Contg. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	470 Park Avenue South New York NY	Approved	\$650.00
45608	04A0165	Wank Adams Slavin Assoc (WASA) 740 Broadway New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Fordham University W. 60th St. and Columbus Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45609	04A0166	Gessin Electrical Contrs, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	555 West 23rd Street New York NY	Approved	\$650.00
45610	04A0167	Schlesinger Electrical Contrs, Inc. 664 Bergen Street Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	930 Flushing Avenue Brooklyn NY	Hold	\$650.00
1) Provide short circuit information. 2) 5-sets run in one conduit.						
45611	04A0168	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	105 West 125th Street New York NY	Approved	\$650.00
45612	-	RHR Electric Co. Inc. 135 West 29th Street-Suite 1202 New York NY 10001	Requesting permission to add additional receptacles and switches inside of existing bedrooms without installing arc circuit breakers.	103 Green Street New York NY	Approved	\$0.00
45613	..	Proscia Electrical Contracting Inc. 141-07 20th Avenue Whitestone NY 11357	Requesting permission not to file Advisory Board drawings on an existing service consisting of 2-1200 amp service switches, to add a 400 amp service switch with signage indicating not to fuse over 350 amps.	38-44 21st Street New York NY	Denied	\$0.00
Electrical Advisory Board drawing submittals are required for any addition to an existing service which would bring the total to 1000 kva or larger.						

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45614	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requesting permission not to file Advisory Board drawings on an existing 1000 KVA service, by tapping the load side of a 3000 amp, 480 volt generator main switch with 2 sets of 500 MCM that will feed a new fuse box containing 3-800 amp fuses installed next to the 3000 amp switch.	85 10th Avenue New York NY	Denied	\$0.00
Section 110.26 of the National Electrical Code requires a 36 inch step back clearance from the switch.						
45615	...	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requesting permission to install a seventh service switch that will provide power to a fire pump.	217 East 96th Street New York NY	Approved	\$0.00
45616	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requesting permission not to file Advisory Board drawings for replacing a single phase fuse pull out with a three phase fuse pull out at the second point of fusing on an 1000 KVA service.	50 Central Park West-Apt. 11A New York NY	Approved	\$0.00
45617	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission on a 480 volt, 2500 amp bus duct riser to install 2 bus duct switches, 3rd and 6th floors with front clearances less than 36".	731 Lexington Avenue New York NY	Denied	\$0.00
Section 110.26(A)1 Depth of Working Space, requires the step back clearance to be a minimum of 36 inches.						
45618	04A0169	Cooper Lighting 1121 Highway 74 South Peachtree City GA 30269	Requested approval for use in New York City of your Emergency Light. Model/Series No. UEL1SD.		Approved	\$200.00

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45619	04A0170	Astralite, Inc. 20 Pocono Road Brookfield NY 06804	Requested approval for use of New York City of your LED Exit Sign with Battery Back-up. Model/Series Nos. EUNY, EANY and ECNY.		Approved	\$200.00
45620	04A0171	Teknion, LLC 12000 Horizon Way Mount Laurel NY 08054	Requested approval for use in New York City of your Modular Furniture/Table System, Teknion Expansion Power/Data Module. Model/Series Nos. RLBX4B/8T, BEPCA, BWPK, BFPG, CLPTS3, CLPTM3, CLPC02, CLPS01/2 RLCCC3B/4B/8T, RLCCW3B/4B/85, RLWP4B/8T, RLPP72/180.		Ok, but	\$200.00
<p>CLPT53-Not acceptable for permanent installation. Use standard verbage for temporary applications. CLPTM3-Use standard verbage for temporary application. CLPC02-Same as CLPTM3 above. CLPS01 and CLPS02-Same as CLPTM3 above. RLCCC3B, RLCCC4B and ALCCC8T-Same as CLPTM3 above, but cannot require T00L5 for installation, RLCCW3B, RLCCW4B and RLCCW85 also. RLWP4B and RLWP8T-Same as CLPTM3 above. RLPP72 and RLPP180-Same as CLPTM3 above. RLBX4B and RLBX8T-Same as CLPTM3 above. BEPCA, BWPK and BFPG-Same as CLPTM3 above.</p>						
45621	04A0173	Alflex Corporation 2630 El Presidio Street Long Beach CA 90810	Requested approval for use in New York City of your McQuick UL Listed Wiring Assemblies of cut to length MC cable with fittings installed.		Approved	\$200.00
45622	04A0174	Bretford USA 11000 Seymour Avenue Franklin Park IL 60131	Requested approval for use in New York City of your Power and Data delivery system for office, training and library environments "Liquid". Model/Series Nos. M-SUB, MCH-P, MCH, M-SPT, MCJ, MSB-F, MSP-F, MSB-W, MSP-W, MSB-C, MSP-C, MPD, MDX, MSP.		Hold	\$200.00

Need specific installation and application instructions. Also need UL testing report

ADVISORY BOARD CALENDAR

April 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45623	04A0175	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Factory pre-wired office furnishing panels and other accessory additions. Model/Series Nos. A1110, A1120, A1125, A1130, A1131, A1150, A1180; A1325, A1332, A1342, A1910, NP239, X1311.		Approved	\$200.00
45624	04A0176	Thomas & Betts/Lightalarms 8155 T & B Boulevard Memphis TN 38125	Requested approval for use in New York City of your Remote Lighting Fixtures. Model/Series Nos. ELF/EF/DR-Series.		Approved	\$200.00
45625	04A0172	Controlled Power Company 1955 Stephenson Highway Troy MI 48083	Requested approval for use in New York City of your EL Series; Emergency Lighting Inverters. 1.5kw through 18kw.		Approved	\$200.00