

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52967	14A0138CO	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	42-12 28th Street Queens NY	Approved	\$0.00
Carry over from June 11, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52968	14A0553CO	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	175 Water Street New York NY	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53117	14A0633	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	2720 Broadway New York NY	Approved	\$650.00
1) Incoming fault current not shown. 2) Verify 2500 amp fuse in 4000 amp service switch. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	14A0681CO2	Roz-A-Lite Electrical Contracting Inc. 159 20th Street, #401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	234-238 East 23rd Street New York NY	Denied	\$0.00
Carry over from February 18, 2015 meeting. 1) Emergency disconnect switches are now bonded and grounded on a non separately derived system. 2) Explain what the grounding symbol represents on switches and panels on both normal and emergency sides, show proper grounding terminals. By lugs installed on the neutral bars. 3) Provide short circuit breakers/series rating for the meterbanks. 1/22/16 - DENIED - 1) Fire pump equipment grounding conductor undersized. 2) Fire pump feeder to be fire rated, note on drawing not clear. 3) Explain 9 sets of (4) 500 KCM in 3 1/2" conduit. 4) Short circuit study must be performed., signed and sealed by P.E. no copies job to be refiled.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0684	Roz-A-Lite Electrical Contracting Inc. 159 20th Street, #401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	215 Chrystie Street New York NY	Pending	\$650.00
<p>1) Coordination study not complete as per 1 Line drawing. 2) T-2 transformers overfused. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53171	14A0713	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1090 Close Avenue Bronx NY	Approved	\$650.00
<p>1) Equipment grounding conductor undersized for 10' tap out of meterbank, 100 amp disconnect switch bonded and grounded on load side of service switch. 2) Verify neutral links in 400 and 800 amp trans S switches. 3) Grounding electrode conductor to be brought to 2-100 amp retail space service switches. 8/14/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53257	15A0052	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	60 West 37th Street New York NY	Approved	\$650.00

1) Equipment grounding conductor to 200 amp F.A. disconnect switch undersized. 2) Service switch for fire pump # 1 is undersized, equipment grounding conductors undersized, feeder undersized, emergency side fusing undersized. 3) Fire pump #2 equipment grounding conductors undersized. 4) Fire pump #3, emergency fusing undersized, equipment grounding conductors undersized. 5) Verify that fire pump and fire alarm ATS' are loaded in fire rated rooms. 6) Verify type of fuses used. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an ALT 3.
2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer. 7/28/15 Rejected 1) FP-1 EGC undersized. 2) Fuse types not shown, general notes not shown with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer. 9/22/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an ALT 3. 2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52992	15A0056CO	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	FDNY 9 Metrotech Center Brooklyn NY	Approved	\$0.00
Carry over from February 18, 2015 meeting. 1) Provide ventilation in emergency switchboard room 2) Cut sheet of 3000 amp switch busbars do not match 1 Line. 3) With the stipulation: that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/23/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/25/16 Swapped drawings 1,2,3 and 4-Revision 1.						
52969	15A0060	Prestige Electrical Contracting Corp. 1301 Sheepshead Bay Road, Ground Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	626 Bushwick Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing 1 and 2-Revision 1. 10/3/16 Swapped drawing 2-Revision 3.						
53037	15A0071CO	NYMEC 269 37th Street, Suite 200 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Industry City Associates 882 3rd Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 18, 2015 meeting. Coordination study showed violations which must be corrected. Short circuit curves to match new 4000 amp switches. 5/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swap Drawing 1. Revision 1. 7/22/16 Swapped drawing 4-Revision 1. 11/28/16 Drawing 2 and 3-Revision 1 and Drawing 4-Revision 2. No more revisions will be accepted.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0105	Nead Electric, Inc. 530 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	HSBC 330 Madison Avenue New York NY	Rejected	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/22/15 Drawing and short circuit study require complete review. New submittal required.						
53013	15A0118	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1133 6th Avenue New York NY	Approved	\$650.00
Verify conductors and conduits for new 3000 amp feeder. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52970	15A0119CO	Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission to allow the primary feeders on the load side of the micro grid breakers to be run in RGS conduit.	Hudson Yards & Towers 500 West 33rd Street New York NY	Approved	\$0.00
Carry over from March 18, 2015 meeting. With the stipulation that drawings must be submitted to the Advisory Board for approval when design is completed accompanied by an approval letter from Con-Edison. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52971	15A0120	Allstate Electrical Group 120 West 31st Street New York NY 10001	Requesting permission to leave as installed a 1600 amp service switch with a pull box that extends 8" beyond the front of the switch.	570 7th Avenue New York NY	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52972	15A0147	Avoca Engineers & Architects, LLC 242 Old New Brunswick Road, Suite 130 Piscataway NJ 08854	Requested approval for the electric service equipment proposed to be installed	341 Chester Street Brooklyn NY	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52942	15A0148	Mangi Electrical Corp. 4089 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	200 Adelaide Avenue Staten Island NY	Approved	\$650.00
OR With the stipulation that the manhole ring, if metallic, is bonded. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/22/16 Swapped Drawing 1 and 2-Revision 1.						
52973	15A0164	Lobello Electric Installation Corp. 3150 East Tremont Avenue Bronx NY 10461	Requesting permission to leave as installed service equipment installed in the adjacent room due to lack of space in the existing service room.	Boar's Head Deli 183 State Street Brooklyn NY	Approved	\$650.00
With the stipulation that signage is provided at each service location indicating where the other service is located and fire alarm service switch to comply with Section 110.26(A)(3). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52896	15A0169	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52946	15A0170	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	206 East 86th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/7/15 Swap drawing 1-Revision 1.						
	15A0185	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Bay Club Heating Plant 2 Bay Club Drive Bayside NY	On Hold	\$650.00
1) Show length of transformer secondary taps. 2) Remove bonding at TRX(confirm or clarify). 3) Interconnect switches must be identified as service switches. 4) Provide provisions or explain how utility does not feed back to induction gen when gen is not in operation. 5) Confirm system voltage in general notes and 1 Line.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0189	Electrical Solutions LLC 145 30th Street Brooklyn NY 11232	Requested permission to leave as installed due to the stove area to be demolished to install 2 receptacle outlets on two 18" cabinets located on each side of the stove.	232 Dean Street Brooklyn NY	Denied	\$350.00
52930	15A0190	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	MTA 2 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52943	15A0192	Net Power Electric Corp. 1568 62nd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	256 Atlantic Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/6/15 Swapped drawings 1 and 2, Revision 1s.						
53014	15A0193	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	North Shore Towers 270-10 Grand Central Parkway Floral Park NY	Approved	\$650.00
1) Taps exceeds 6 switches on TRX. 2) Total I load is more than I secondary of transformer. 3) New switch is double tapped (600AS). 4) Tap exceeds 25' from transformer. 5) Ground cond. for 600AS is undersized. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52931	15A0194	Montgomery Electrical Contracting Corporation 4250 Van Cortland Park East Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	156 N. 4th Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52926	15A0195	M.C. Electrical NY Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Nightingale-Bamford School 20 East 92nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52938	15A0196	AKF Engineers 165 Broadway, 22nd Floor New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Barnard College 3009 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/16 Swapped drawing A-Revision 2.						
52945	15A0197	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Ralph Lauren 711 Fifth Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52932	15A0198	Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	20 West 53rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52995	15A0199	Right Away Electric LLC 56-12 Andrews Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	490 Myrtle Avenue Brooklyn NY	Approved	\$650.00
Tapped conductors #2 undersized. 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/16 Swapped drawings 1 and 2-Revision 2.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52996	15A0200	Tritech Electrical & Data Inc. 4288 Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	407 1st Avenue New York NY	Approved	\$650.00
<p>1) ATS-3 to be 4 pole w/switched neutral. 2) Equipment grounding conductor for pump undersized. With the stipulation: Fire Rated Enclosure's must comply with the following:                      1. A P.E. or R.A. must file a PWI as an AIT 3.                      2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.                      3. The fire proofing must be performed by a certified fire proofing installer. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/16 Swapped drawing 2-Revision 2.</p>						
	15A0201	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Gotham Center 42-09 28th Street Long Island City NY	Denied	\$650.00
Drawing not in Advisory Board format.						
53012	15A0203	Nead Electric, Inc. 530 West Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Soros 250 West 55th Street New York NY	Approved	\$650.00
OR Show fuse types in bus duct switches. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52925	15A0204	npbell and Dawes Ltd. Electrical Contract 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Microsoft 677 Fifth Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52933	15A0205	Arch Electric Inc. 101-11 97th Avenue Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1790 Broadway New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52997	15A0207	Top Shelf Electric Corporation 4386 Victory Blvd Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	166 West 75th Street New York NY	Approved	\$650.00
1) Verify if service room doors can comply with 110.26(c)(3). 2) New 1200 amp fuses to coordinate with panelboard A-, what are O.T. fuses? 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53064	15A0210	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	860 Washington Street New York NY	Approved	\$650.00

1) Show conductors between sections in DP-3-1. 2) Fire pump emergency feeder to be fire rated With the stipulation:that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/2/15 Job finalized. With the stipulation:

This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/15 Swapped Drawings, 1 and 2-Revision 2s. 8/24/15 Swapped Drawings 1 and 2, Revision 2s.

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53110	15A0212	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	55 West 17th Street New York NY	Approved	\$650.00
<p>1) Block off rear of switchboard. 2) Equipment grounding conductors undersized on line side service switches 3 and 4 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Correct equipment designation on 1-Line up-EM-R ATS size? F.A. switch is mislabeled. 6/25/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/17 Swapped drawing 1-Revision 2, Drawing 2-Revision 1 and Drawing 3-Revision 2.</p>						
52924	15A0213	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	289 Meserole Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53148	15A0215	Roz-A-Lite Electrical Contracting, Inc. 159 20th Street, Suite 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	20 East End Avenue New York NY	Approved	\$650.00
<p>1) Service bus feeding 4, 600 amp service switches undersized. 2) Show conductor sizes connecting sections together in panels DP-R and DP-6. 3) Panel AP-6 shall be relocated to create an unobstructed egress. 4) Show meter series rating. 5) Block space behind switchboard. 6) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/28/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52999	15A0216	Amra Electrical Corp. 47 Buffalo Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	237 11th Street Brooklyn NY	Approved	\$650.00
<p>Tapped equipment grounding conductors undersized 250.122(G). 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52944	15A0218	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	83-30 Kew Gardens Road Queens NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/5/15 Swapped drawing 1, Revision 2.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53001	15A0219	Amber Lite Electric Corp. 4441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	363 Bond Street Brooklyn NY	Approved	\$650.00
<p>1) Bus feedings 2000 amp service switch undersized. 2) Through bus last section of HDP-1 panel undersized. 3) Verify feeders to DP-1 and DP-2. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DaB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/14/16 Swapped drawing A-Revision 3. Drawing B-Revision 2 and Drawing C-Revision 2.</p>						
52934	15A0220	Allran Electric of New York Inc. 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	475 Fifth Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53054	15A0221	Electrical Specialty Enterprises Inc. 1122 Coney Island Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	1500 Bassett Avenue Bronx NY	Approved	\$650.00
800 new switch (tap) is undersized. 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52974	15A0222	Electrical Specialty Enterprises Inc. 1122 Coney Island Avenue Brooklyn NY 11230	Requesting permission to leave as installed service equipment for 6 meters outside of the building where the service was relocated due to hurricane Sandy and constant flooding because the building is located 1 block away from the beach.	231 Brighton Beach Avenue Brooklyn NY	Approved	\$350.00
Code: 230.70(A)(1) Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52928	15A0223	A.M.R. Electrical Contracting Corp. 62-59 Woodhaven Blvd. Rego Park NY 11374	Requested approval for the electric service equipment proposed to be installed	1100 Newkirk Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52927	15A0224	John Michael Electrical Contracting Corp. 1067 Post Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	360 Neptune Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52935	15A0228	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	GM Bldg Condenser Water Riser 767 5th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0229	HIG Electrical Associates NYC, Inc. 25-26 50th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	99 Wall Street New York NY	Rejected	\$650.00
<p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1) Provide coordination between EMDP and up stream device (by P.E. Stamped). 2) Clarify where the new room is, 1st or 2nd floor (Plan &amp; 1-Line). 3) Size and number of service end box conductors don't match. 7/29/15 1) Verify compliance with 110.26-(A)(2) and Table 110.26(A) working spaces for 100 amp 3 wire meters, not poles. 2) Job changed and all changes not identified on drawings. Drawings to be completely reviewed requires a new submittal. 3) Coordination study to be performed by a PE bearing the stamp.</p>						
53098	15A0231	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	Dumbo Heights- Bldg #5 175 Pearl Street Brooklyn NY	Approved	\$650.00
<p>1) New SS-B1 require side access. 2) New room require permission. 3) Provide signage to indicate service rooms location. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/22/16 Swapped drawing 34860751-1 of 2-Revision 2 of 2-Revision 2.</p>						
52937	15A0232	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	506 6th Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52990	15A0233	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	71 Reade Street New York NY	Approved	\$650.00
<p>1) Provide end egress door. 2) Identify all service switches in electrical room. 3) Grounding electrode conductor to be installed in service switches. 4) Size of bonding jumper not shown in HDP switch board. 5) Are ATS 3 or 4 pole type, sizes not shown. 6) Verify type of underground conductor to fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/22/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/28/15 Swapped drawing 1 and 2-Revision 3.</p>						
52985	15A0234	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	280 Metropolitan Avenue Brooklyn NY	Approved	\$650.00
52947	15A0235	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Livoniz Commons, Site 2 494 Sheffield Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52939	15A0236	R & L systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	700 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52975	15A0237	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	765-775 Park Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53011	15A0240	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1221 6th Avenue New York NY	Approved	\$650.00
Equipment storage area not to be in service room. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53008	15A0242	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	809 Broadway New York NY	Approved	\$650.00
<p>Are 3 or 4 pole ATS' being used off of emergency panel to comply with 250.20? With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53009	15A0243	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	142-38 37th Avenue Queens NY	Approved	\$650.00
<p>Are ATS 3 or 4 Pole? With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
52940	15A0245	Timothy Coleman Electric 19-14 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	Verizon 86-25 Van Wyck Expressway Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52976	15A0246	Myers Power Products, Inc. 44 S. Commerce Way Bethlehem NY 18017	Requested approval for use in New York City of your Illuminator "LV" Compact Emergency Lighting Inverter. Model Numbers LV-175W, LV-350W, LV-550W and LV-750W.		Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0247	Myers Power Products, Inc. 44 S. Commerce Way Bethlehem NY 18017	Requested approval for use in New York City of your Illuminator "EM" Emergency Lighting Inverter. Model Numbers: EM1, EM2, EM3 and EM4(see UL file E95719, Volume 1, Section 20)			\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52978	15A0248	Myers Power Products, Inc. 44 S. Commerce Way Bethlehem NY 18017	Requested approval for use in New York City of your Illuminator "E" and Illuminator "IE" Emergency Lighting Inverter. Model numbers: E1 through E10 and IE1 through IE10(see UL file E95719, Volume 1, Sectin 15).		Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0249	Advanced Electrical Concepts Inc. 1375 Broadway, 3rd Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	41-17 Crescent Street Long Island City NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52936	15A0250	Alef Electrical Contracting Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	248 Bedford Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53102	15A0252	Abstract Electrical Contractors, Inc. 18--60 45th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	85 4th Avenue New York NY	Approved	\$650.00
1) Service entrance conductors to comply with 376.22 A and B. 2) Verify length of tapped conductor. 3) Coordinate eagle fuse with service switch fuse. 4) Show feeder sizes to spice restaurant switch. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53050	15A0253	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	30 Sutton Place New York NY	Approved	\$650.00
OR Equipment grounding conductor to new 200 amp disconnect switch undersized. 5/22/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/2/15 Swapped drawing 1, Rev 2. 6/15/16 Swapped drawing 1-Revision 3.						
	15A0255	Brandl Electric Inc. 250 Greenpoint Avenue, 4th Floor Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	110 Wall Street New York NY	On Hold	\$650.00
<p>1) Correct note #4 on room layout drawing. 2) Portable generator connection to comply with 700.6(G), conductors overfused. 3) Equipment grounding conductors to switchboard "PGS" undersized. 4) EGC from generator disconnect switch to "PGS" board undersized. 5) Bus sizes in generator disconnect switch not shown. 6) Grounding electrode conductors to be brought into service switches. 7) MI cable does not require equipment grounding conductor. 8) Tapped conductors and EGC from trough to disconnect switches undersized. 9) Bus undersized emergency board. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Review stopped.</p>						
53108	15A0256	Cedar Electrical Contractors, Inc. 64 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	340 West Street New York NY	Approved	\$650.00
1) Provide manufacturer's cut sheet of end box and 800 and 1200 amp switches. 2) Are both transformers new? 3) Verify that incoming 4 sets of 500 are the utility. 6/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53109	15A0257	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	621 Amsterdam Avenue New York NY	Approved	\$650.00
1) Wiring methods to be on one line drawing. 2) Verify 6"x6" trough size for all conductors, taps or splices. 3) How will splices or taps be made in trough, verify trough will be installed over doorway. 6/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0258	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 530 West 120th Street New York NY	On Hold	\$650.00
1) Clearances in rooms to comply with Table 110.34(A), rear hinged doors required on SPX-swgr-C. 2) SPX-swgr C and D to comply tih NYC bus density or provide letter from GE that heat rise test was performed. 3)Coordination study too small to read. 4) Storage cabinet to indicate what will be stored in it. 5) Correct typo on ground fault relays for transformer.						
	15A0259	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 530 West 120th Street New York NY	On Hold	\$650.00
1) 1 correct typos on 5 KV fuses on 1 Line, voltage. 2) 1 Line to match coordination study. 3) Confirm bus 12" off of finished floor.						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53007	15A0260	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Riverside Building 5 1 West End Avenue New York NY	Approved	\$650.00
<p>1) Show lengths of transformer secondary conductors. 2) Bus undersized to panel HP-HV.. 3) 750KVA secon cond.is undersized. With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PWI as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</li> </ol> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PWI as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</li> </ol>						
53000	15A0261	A.S.R. Electrical Contracting, Inc. 969 Third Avenue, Suite 4F New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Temp Service 220 Central Park South New York NY	Approved	\$650.00
<p>OR Verify tap length to 800 amp disconnect switch. 4/24/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/28/15 Swapped Drawing A, Revision 1 and Drawing B, Revision 2.</p>						

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52979	15A0272	Hylan Datacom & Electrical 50-35 56th Road Maspeth NY 11379	Requesting permission per an updated approval to allow service equipment installed for cable TV as per 230.79(D) not count as a service switch 230.71, with the stipulation that no circuit breakers be installed an that the fuses have appropriate interrupting ratings for the location served.	Various Boros	Approved	\$0.00

With the stipulation that the size of the fused service switch complies with Section 230.79(D) and the grounding of the service switch complies with Sections 250.64(D)(1) or 250.64(D)(3).

52980	15A0274	Conductor Electric Corp. 116 West 23rd Street, 5th Floor New York NY 10011	Requesting permission to leave as installed due to a hardship to replace service entrance cable used from the load side of the back of the meter pan 3' to4' to the bottom of the combination panel on the opposite wall of the meter pan.	112 Reid Avenue Breezy Point NY	Approved	\$0.00
-------	---------	--	--	------------------------------------	----------	--------

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Code: Amendment 338.10 and 230.43

52981	15A0280	L & B Electrical International 2063 Atlantic Avenue Brooklyn NY 11233	Requesting permission to leave as installed 3 outdoor, 2 hallway lights and the basement branch circuits on the owners residential meter who occupies the entire building without adding a PLP meter and circuit breaker panel.	97 Dikeman Street Brooklyn NY	Approved	\$0.00
-------	---------	---	---	----------------------------------	----------	--------

With the stipulation that all common area branch circuits are installed in the owners residential panel. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.