

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52967	14A0138CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from June 11, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/26/17 - swap dwg 1 of 3, 2 of 3, &amp; 3 of 3 rev 2. 9/9/18 1) Verify bonding and grounding to new 600A main switch. 8/22/18 - swap dwg # 1, 2 &amp; 3 Rev 3. 11/29/18 1) 60HP and 40HP fire pumps OCPD are undersized. 2) Verify 2HR fire rated cond for 125HP fire pump. 1/29/19 Swap dwg #1 of 3 Rev-4 No more swaps</p>				
52968	14A0553CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from October 22, 2014 meeting. With the stipulation:                      This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53117	14A0633	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Incoming fault current not shown. 2) Verify 2500 amp fuse in 4000 amp service switch. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
	14A0681CO2	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
<p>Carry over from February 18, 2015 meeting. 1) Emergency disconnect switches are now bonded and grounded on a non separately derived system. 2) Explain what the grounding symbol represents on switches and panels on both normal and emergency sides, show proper grounding terminals. By lugs installed on the neutral bars. 3) Provide short circuit breakers/series rating for the meterbanks. 1/22/16 - DENIED - 1) Fire pump equipment grounding conductor undersized. 2) Fire pump feeder to be fire rated, note on drawing not clear. 3) Explain 9 sets of (4) 500 KCM in 3 1/2" conduit. 4) Short circuit study must be performed., signed and sealed by P.E. no copies job to be refilled.</p>				
	14A0684	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Coordination study not complete as per 1 Line drawing. 2) T-2 transformers overfused. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/20/17 - 1) Comply the section 695.6 (B). FP conductor from x'mer 'T-6' to FP controller require 2hr fire rated. 2) clearly identify that electrical service room is 2hr fire rated &amp; mechanically ventilated. 3) EM equipment (ATS-1) required in separate EM electrical room. 4) verify that 3ft clear working space in front of 'AC-9'. Disconnect switch and 3'-6" working space in front of 'T-3' clearly show the drawing scale. 4/1/2019 1) Fire alarm disconnect switches shall be tapped directly from the transformer &amp; not as a tap from xfm secondary conductor. 2) Fire alarm ATS shall be 4 pole with switched neutral to void using neutral that bonded twice. 3) Comply with 450.3(B) note(2) - xfmr T-2 OCPDs are oversized. 4) Confirm that new 100A s.switch added is feeding fire alarm.</p>				
53171	14A0713	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment grounding conductor undersized for 10' tap out of meterbank, 100 amp disconnect switch bonded and grounded on load side of service switch. 2) Verify neutral links in 400 and 800 amp trans S switches. 3) Grounding electrode conductor to be brought to 2-100 amp retail space service switches. 8/14/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/11/2017 - 1) Comply section 240.22 for retail FACP tap. 2) Comply section 695.6 (B) (1). FP conductor supply only FP &amp; load directly associated with rp system. 4/21/2017 - swap dwg "35301172AB" - Rev 3</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53257	15A0052	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment grounding conductor to 200 amp F.A. disconnect switch undersized. 2) Service switch for fire pump # 1 is undersized, equipment grounding conductors undersized, feeder undersized, emergency side fusing undersized. 3) Fire pump #2 equipment grounding conductors undersized. 4) Fire pump #3, emergency fusing undersized, equipment grounding conductors undersized. 5) Verify that fire pump and fire alarm ATS' are loaded in fire rated rooms. 6) Verify type of fuses used. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:            Fire Rated Enclosure's must comply with the following:            1. A P.E. or R.A. must file a PWI as an ALT 3.            2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.            3. The fire proofing must be performed by a certified fire proofing installer. 7/28/15 Rejected 1) FP-1 EGC undersized. 2) Fuse types not shown, general notes not shown with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:            Fire Rated Enclosure's must comply with the following:            1. A P.E. or R.A. must file a PWI as an AIT 3.            2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.            3. The fire proofing must be performed by a certified fire proofing installer. 9/22/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation:            Fire Rated Enclosure's must comply with the following:            1. A P.E. or R.A. must file a PWI as an ALT 3.            2. A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.            3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/17 - swap dwg# 1 of 3, 2 of 3 &amp; 3 of 3 rev 4 3/6/19 1) Incoming service conductors are undersized. 2) Service bus bar feeds 1200A s. sw is undersized. 3)</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
<p>Fire alarm tap to be ahead of N.D.L -760.42 8/7/19 1) Provide coordination study between 1000A Fuse and 'DP-CG' sw board. 2) Address the connection feed for three jockey pump [where they are connected] 3) Confirm all three 'ATS' rating for the fire pump. 4) Explain comment #6 and #7 in the Rev.6 6/29/2021 Amended plan# 1 Rev 8 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
52992	15A0056CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 18, 2015 meeting. 1) Provide ventilation in emergency switchboard room 2) Cut sheet of 3000 amp switch busbars do not match 1 Line. 3) With the stipulation: that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/23/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/25/16 Swapped drawings 1,2,3 and 4-Revision 1.</p>				
52969	15A0060	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing 1 and 2-Revision 1. 10/3/16 Swapped drawing 2-Revision 3. 8/23/17 - verify which building are fed by meterbank A &amp; B - one line doesn't match floor plan. 9/19/17 - swap dwgs 1 &amp; 2 rev 5</p>				
53037	15A0071CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 18, 2015 meeting. Coordination study showed violations which must be corrected. Short circuit curves to match new 4000 amp switches. 5/21/15 Job finalized.                      Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swap Drawing 1. Revision 1. 7/22/16 Swapped drawing 4-Revision 1. 11/28/16 Drawing 2 and 3-Revision 1 and Drawing 4-Revision 2. No more revisions will be accepted.</p>				
	15A0105	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/22/15 Drawing and short circuit study require complete review. New submittal required.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53013	15A0118	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify conductors and conduits for new 3000 amp feeder. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/30/17 - DP-DSA switchboard is >12" from the side wall. Barrier or seal the side of one switchboard 4/19/2017- 1) Item # 1 is not addressed correctly - barrier needs to start from the front edge of the switchboard. 8/31/17 - swap dwg PB20-01, AB20-01, SB20-01 & FP10-01. 9/27/18 1) Provide coordination between 3000A KRPC and downstream fuse 200A TRS-R fuse. 12/24/18 Swap dwg #AB20-1 of 1-Revision 5.				
52970	15A0119CO	Requesting permission to allow the primary feeders on the load side of the micro grid breakers to be run in RGS conduit.	Approved	\$0.00
Carry over from March 18, 2015 meeting. With the stipulation that drawings must be submitted to the Advisory Board for approval when design is completed accompanied by an approval letter from Con-Edison. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52971	15A0120	Requesting permission to leave as installed a 1600 amp service switch with a pull box that extends 8" beyond the front of the switch.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52972	15A0147	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52942	15A0148	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation that the manhole ring, if metallic, is bonded. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/22/16 Swapped Drawing 1 and 2-Revision 1.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52973	15A0164	Requesting permission to leave as installed service equipment installed in the adjacent room due to lack of space in the existing service room.	Approved	\$650.00
With the stipulation that signage is provided at each service location indicating where the other service is located and fire alarm service switch to comply with Section 110.26(A)(3). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52896	15A0169	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52946	15A0170	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/7/15 Swap drawing 1-Revision 1.				
	15A0185	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Show length of transformer secondary taps. 2) Remove bonding at TRX(confirm or clarify). 3) Interconnect switches must be identified as service switches. 4) Provide provisions or explain how utility does not feed back to induction gen when gen is not in operation. 5) Confirm system voltage in general notes and 1 Line.				
	15A0189	Requested permission to leave as installed due to the stove area to be demolished to install 2 receptacle outlets on two 18" cabinets located on each side of the stove.	Denied	\$350.00
52930	15A0190	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52943	15A0192	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/6/15 Swapped drawings 1 and 2, Revision 1s.				
53014	15A0193	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Taps exceeds 6 switches on TRX. 2) Total I load is more than I secondary of transformer. 3) New switch is double tapped (600AS). 4) Tap exceeds 25' from transformer. 5) Ground cond. for 600AS is undersized. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52931	15A0194	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52926	15A0195	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0196	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/16 Swapped drawing A-Revision 2. 8/25/17 - 1) Provide Tap length 2) Provide TCC for 250A FRNR & upstream 2000A A4BQ				
52945	15A0197	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52932	15A0198	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52995	15A0199	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Tapped conductors #2 undersized. 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/16 Swapped drawings 1 and 2-Revision 2. 10/20/17 - swap dwg 2 of 2 rev 2				
52996	15A0200	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) ATS-3 to be 4 pole w/switched neutral. 2) Equipment grounding conductor for pump undersized. With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <p>1. A P.E. or R.A. must file a PW1 as an AIT 3.</p> <p>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</p> <p>3. The fire proofing must be performed by a certified fire proofing installer. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/24/16 Swapped drawing 2-Revision 2.</p>				
	15A0201	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Drawing not in Advisory Board format.				



# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53012	15A0203	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Show fuse types in bus duct switches. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52925	15A0204	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52933	15A0205	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52997	15A0207	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify if service room doors can comply with 110.26(c)(3). 2) New 1200 amp fuses to coordinate with panelboard A-, what are O.T. fuses? 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/2017 - ok swap dwg 1 rev 2				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53064	15A0210	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show conductors between sections in DP-3-1. 2) Fire pump emergency feeder to be fire rated With the stipulation:that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/2/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/15 Swapped Drawings, 1 and 2-Revision 2s. 8/24/15 Swapped Drawings 1 and 2, Revision 2s.</p>				
53110	15A0212	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Block off rear of switchboard. 2) Equipment grounding conductors undersized on line side service switches 3 and 4 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Correct equipment designation on 1-Line up-EM-R ATS size? F.A. switch is mislabeled. 6/25/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/12/17 Swapped drawing 1-Revision 2, Drawing 2-Revision 1 and Drawing 3-Revision 2.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52924	15A0213	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0215	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) Service bus feeding 4, 600 amp service switches undersized. 2) Show conductor sizes connecting sections together in panels DP-R and DP-6. 3) Panel AP-6 shall be relocated to create an unobstructed egress. 4) Show meter series rating. 5) Block space behind switchboard. 6) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/28/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/3/2020 1) Mark and list all changes of Revision 2 on the plans and resubmit.. 2/8/2021 Amended Plan # 1 of 3 Rev- 4 and 3 of 3 Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/11/2021 Amended dwgs#1 &amp; 2 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 4/1/2021 Amended dwgs#1 &amp; 2 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
52999	15A0216	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Tapped equipment grounding conductors undersized 250.122(G). 4/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/10/19 1) EGC to new 100A retail switches are undersized -T250.122 2) Provide coordination between 800A ss#4 &amp; down stream 400A A2D fuse. 3) Provide 3' clearance to S.E.B 3/26/19 Swag dwg #1 &amp; 3 Rev-3 and #2 Rev-2. 5/24/19 - Swap dwg # 1 of 3 Rev-4</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52944	15A0218	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/5/15 Swapped drawing 1, Revision 2.				
53001	15A0219	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Bus feedings 2000 amp service switch undersized. 2) Through bus last section of HDP-1 panel undersized. 3) Verify feeders to DP-1 and DP-2. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DaB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2017 - ok, for existing cond for jockey pump. Swap dwg A Rev 1, dwg B rev 2, dwg C rev 1, dwg D rev 1</p>				
52934	15A0220	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53054	15A0221	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
800 new switch (tap) is undersized. 5/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52974	15A0222	Requesting permission to leave as installed service equipment for 6 meters outside of the building where the service was relocated due to hurricane Sandy and constant flooding because the building is located 1 block away from the beach.	Approved	\$350.00
Code: 230.70(A)(1) Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52928	15A0223	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52927	15A0224	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52935	15A0228	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0229	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1) Provide coordination between EMDP and up stream device (by P.E. Stamped). 2) Clarify where the new room is, 1st or 2nd floor (Plan &amp; 1-Line). 3) Size and number of service end box conductors don't match. 7/29/15 1) Verify compliance with 110.26-(A)(2) and Table 110.26(A) working spaces for 100 amp 3 wire meters, not poles. 2) Job changed and all changes not identified on drawings. Drawings to be completely reviewed requires a new submittal. 3) Coordination study to be performed by a PE bearing the stamp.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53098	15A0231	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) New SS-B1 require side access. 2) New room require permission. 3) Provide signage to indicate service rooms location. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/22/16 Swapped drawing 34860751-1 of 2-Revision 2 of 2-Revision 2. 8/30/17 - swap dwgs 1 &amp; 2 rev 3</p>				
52937	15A0232	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52990	15A0233	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide end egress door. 2) Identify all service switches in electrical room. 3) Grounding electrode conductor to be installed in service switches. 4) Size of bonding jumper not shown in HDP switch board. 5) Are ATS 3 or 4 pole type, sizes not shown. 6) Verify type of underground conductor to fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/22/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/28/15 Swapped drawing 1 and 2-Revision 3.</p>				
52985	15A0234	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>5/4/2017 - swap dwg 1 &amp; 2 rev 2</p>				
52947	15A0235	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52939	15A0236	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52975	15A0237	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53011	15A0240	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Equipment storage area not to be in service room. 4/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/2017 - provide panic bar hardware to all egress doors. 2) Comply section 230.64 (B) for "SS-G" &amp; "SS-F". Maintain working clearance between "3000A" service switch &amp; respective distribution switchboard (DS-G &amp; DS - F) with "100A" disconnect switch. 6/13/2017 - swap dwg # FP 40-01 of 1 Rev 5 7/20/17 - swap dwgs SB 1 of 5 Rev 1, SB 4 of 5 Rev 2 12/26/19 Dwgs AB40-01 of 2 rev 1, AB40-02 of 2 rev 1, FP40-01 of 1 rev 6, SB40-01 of 5 rev 1, SB40-02 of 5 rev 2, SB40-03 of 5 rev 0, SB40-04 of 5 rev 3, SB40-05 of 5 rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53008	15A0242	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Are 3 or 4 pole ATS' being used off of emergency panel to comply with 250.20? With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/2915 Job finalized. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				



# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53009	15A0243	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Are ATS 3 or 4 Pole? With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52940	15A0245	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52976	15A0246	Requested approval for use in New York City of your Illuminator "LV" Compact Emergency Lighting Inverter. Model Numbers LV-175W, LV-350W, LV-550W and LV-750W.	Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0247	Requested approval for use in New York City of your Illuminator "EM" Emergency Lighting Inverter. Model Numbers: EM1, EM2, EM3 and EM4(see UL file E95719, Volume 1, Section 20)		\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
52978	15A0248	Requested approval for use in New York City of your Illuminator "E" and Illuminator "IE" Emergency Lighting Inverter. Model numbers: E1 through E10 and IE1 through IE10(see UL file E95719, Volume 1, Sectin 15).	Approved	\$200.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0249	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52936	15A0250	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53102	15A0252	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Service entrance conductors to comply with 376.22 A and B. 2) Verify length of tapped conductor. 3) Coordinate eagle fuse with service switch fuse. 4) Show feeder sizes to spice restaurant switch. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53050	15A0253	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Equipment grounding conductor to new 200 amp disconnect switch undersized. 5/22/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/2/15 Swapped drawing 1, Rev 2. 6/15/16 Swapped drawing 1-Revision 3.				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
	15A0255	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Correct note #4 on room layout drawing. 2) Portable generator connection to comply with 700.6(G), conductors overfused. 3) Equipment grounding conductors to switchboard "PGS" undersized. 4) EGC from generator disconnect switch to "PGS" board undersized. 5) Bus sizes in generator disconnect switch not shown. 6) Grounding electrode conductors to be brought into service switches. 7) MI cable does not require equipment grounding conductor. 8) Tapped conductors and EGC from trough to disconnect switches undersized. 9) Bus undersized emergency board. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Review stopped.</p>				
53108	15A0256	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide manufacturer's cut sheet of end box and 800 and 1200 amp switches. 2) Are both transformers new? 3) Verify that incoming 4 sets of 500 are the utility. 6/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53109	15A0257	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Wiring methods to be on one line drawing. 2) Verify 6"x6" trough size for all conductors, taps or splices. 3) How will splices or taps be made in trough, verify trough will be installed over doorway. 6/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	15A0258	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Clearances in rooms to comply with Table 110.34(A), rear hinged doors required on SPX-swgr-C. 2) SPX-swgr C and D to comply tih NYC bus density or provide letter from GE that heat rise test was performed. 3)Coordination study too small to read. 4) Storage cabinet to indicate what will be stored in it. 5) Correct typo on ground fault relays for transformer.</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
	15A0259	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) 1 correct typos on 5 KV fuses on 1 Line, voltage. 2) 1 Line to match coordination study. 3) Confirm bus 12" off of finished floor.				
53007	15A0260	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show lengths of transformer secondary conductors. 2) Bus undersized to panel HP-HV.. 3) 750KVA secon cond.is undersized. With the stipulation:            Fire Rated Enclosure's must comply with the following:            1. A P.E. or R.A. must file a PWI as an AIT 3.            2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.            3. The fire proofing must be performed by a certified fire proofing installer. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.            The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.            NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/29/15 Job finalized. With the stipulation:            This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.            The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.            NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.            With the stipulation:            Fire Rated Enclosure's must comply with the following:            1. A P.E. or R.A. must file a PWI as an AIT 3.            2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.            3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/30/19 1) Fire pump OCPD is undersized. 2) Confirm that Fire Alarm ATSs are 4 pole with switched neutral. 3) Provide submission number or approval # to area of new work installed by other. 4) All changes since last EAB submission shall be marked on the Dwg. 9/30/2020 Amended Dwgs# 1-6 Rev 7. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**April 15, 2015**

Approval #	Submission #	Type of Request	Status	Fee
53000	15A0261	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Verify tap length to 800 amp disconnect switch. 4/24/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/28/15 Swapped Drawing A, Revision 1 and Drawing B, Revision 2.				
52979	15A0272	Requesting permission per an updated approval to allow service equipment installed for cable TV as per 230.79(D) not count as a service switch 230.71, with the stipulation that no circuit breakers be installed an that the fuses have appropriate interrupting ratings for the location served.	Approved	\$0.00
With the stipulation that the size of the fused service switch complies with Section 230.79(D) and the grounding of the service switch complies with Sections 250.64(D)(1) or 250.64(D)(3).				
52980	15A0274	Requesting permission to leave as installed due to a hardship to replace service entrance cable used from the load side of the back of the meter pan 3' to4' to the bottom of the combination panel on the opposite wall of the meter pan.	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Code: Amendment 338.10 and 230.43				
52981	15A0280	Requesting permission to leave as installed 3 outdoor, 2 hallway lights and the basement branch circuits on the owners residential meter who occupies the entire building without adding a PLP meter and circuit breaker panel.	Approved	\$0.00
With the stipulation that all common area branch circuits are installed in the owners residential panel. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				