

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48383CO	07A0648CO	Metro York Electrical, Inc. 23-86 BQE Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	Bowery Bay Brooklyn NY	Hold	\$0.00
Carry over from December 12, 2007 meeting. Provide notes on operation of sequence.						
48438CO3	08A0036CO3	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	407 East 61st New York NY	Hold	\$0.00
Carry over March 12, 2008 meeting.						
48524CO	08A0107CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Rego Park Mall 61-01 Junction Blvd. Rego Park NY	Approved	\$0.00
Carry over from March 12, 2008 meeting. 1) PVC Schedule 80 concrete encased Rev. drawing. 2) Add section view to drawings showing side clearance around service switchboards. Job finalized 5/19/08.						
48551CO	08A0134CO	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	IHOP 276-282 Livingston Street Brooklyn NY	Denied	\$0.00
Carry over from March 12, 2008 meeting. 1) Bus inside of existing tenant's panel is undersized to be fused at 1000 amps. 2) 400 amp fuse in tenant's panel does not coordinate with service switch fuse. 3) Tap of a tap not allowed.						
48552CO	08A0135CO	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Beekman Tower Hotel 3 Mitchell Place New York NY	Approved	\$0.00
Carry over from March 12, 2008 meeting.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48600	08A0165	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	114-02 College Point Blvd. Queens NY	Approved	\$650.00
1) Existing service room to be ventilated. 2) Verify if tap rule is 10'. 3) Drafting error-main switch backwards. Job finalized 6/23/08.						
48601	08A0166	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Montefiore Medical Center 1617 Poplar Street Bronx NY	Approved	\$650.00
1) Provide supplemental ground. 2) Show existing system ground.						
48602	08A0167	erified Electrical & Technical Services, Inc 27 Williams Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	Cingular Wireless 200 West 20th Street New York NY	Ok, but	\$650.00
1) Provide supplemental ground. 2) Show existing system ground.						
48603	08A0168	Rothstein & Hoffman Electric Service, Inc 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Four Point Sheraton Hotel 66 Charlton Street New York NY	Hold	\$650.00
Installation does not comply with tap rules.						
48604	08A0169	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	100 Gold Street New York NY	Approved	\$650.00
Drawing does not show bonding and grounding on normal and emergency sides. Job finalized 7/21/08.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48605	08A0170	Double K Electric Corp. 247-03 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	Gustavino's Restaurant 409 East 59th Street New York NY	Approved	\$650.00
1) Service room doors to open out. 2) Taps do not comply with 25' tap rule need 1000 amps capacity. Job finalized 8/25/08.						
48606	08A0171	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	NYU HCC 550 First Avenue New York NY	Approved	\$650.00
48607	08A0172	Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requested approval for the electric service equipment proposed to be installed	2930 West 30th Street Brooklyn NY	Approved	\$650.00
48608	08A0173	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 130 East 40th Street New York NY	Approved	\$650.00
48609	08A0174	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	245 Park Avenue New York NY	Ok, but	\$650.00
Indicate supplemental ground and transformer ground.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48610	08A0175	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	505 West 47th Street New York NY	Approved	\$650.00
Fire pump feeder to be fire rated. Job finalized 5/19/08.						
48611	08A0176	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	205 West 76th Street New York NY	Approved	\$650.00
48612	08A0177	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	Sutter Ave. aka 340 Pennsylvania A Brooklyn NY	Approved	\$650.00
48613	08A0178	Noble Electrical Contracting Co., Inc. 1794 Clinton Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	2100 Bartow Avenue Bronx NY	Approved	\$650.00
48614	08A0179	Maximum Electric Corp. 34-17 Broadway Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	19 East 72nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48615	08A0180	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	176 Perry Street New York NY	Approved	\$650.00
48616	08A0181	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Paramount Hotel 235 West 46th Street New York NY	Approved	\$650.00
48617	08A0182	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Boricua College 890 Washington Avenue Bronx NY	Approved	\$650.00
48618	08A0183	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	339 West 39th Street New York NY	Approved	\$650.00
48619	08A0184	CNF Electrical Corp. 27-03 23rd Avenue Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	114 East 72nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48620	08A0185	Crana Electric Inc. 600A East 132nd Street, Second Floor Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	The New Yorker Hotel 481 Eighth Avenue New York NY	Approved	\$650.00
Verify that copper and aluminum conductors are being used. Job finalized 5/19/08.						
48621	08A0186	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Edge Building 1 22 North 6th Street Brooklyn NY	Approved	\$650.00
Verify that copper and aluminum conductors are being used. Job finalized 5/19/08.						
48622	08A0187	Control Spec Electrical Systems, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	On the Avenue Hotel 2178 Broadway New York NY	Approved	\$650.00
Verify that copper and aluminum conductors are being used. Job finalized 5/19/08.						
48623	08A0188	ames F. Volpe Electrical Contracting Corp 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Family Court HS 283 Adams Street Brooklyn NY	Approved	\$650.00
Verify that copper and aluminum conductors are being used. Job finalized 5/19/08.						
48624	08A0189	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	450 West 14th Street New York NY	Approved	\$650.00
Verify that fuse adapters aren't being used in the limited service fire pump switch. Job finalized 5/6/08.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48625	08A0190	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Rockefeller University-CRC 1230 York Avenue New York NY	Approved	\$650.00
Replace ships ladder in transformer vault room with steel stairway. Job finalized 8/7/08.						
48626	08A0191	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	The New York Time College Pt College Point NY	Approved	\$650.00
Provide cuts of new switchgear. Job finalized 6/9/08.						
48627	08A0192	Lakhani & Jordan Engineers, P.C. 50 East 42nd Street, Suite 1001 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	AIG 70 Pine Street New York NY	Approved	\$650.00
48628	08A0193	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	Hudson River Trading 32 Old Slip, 30th Floor New York NY	Approved	\$650.00
48629	08A0194	AARCO Electric Inc. 5902 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	Gertz Plaza 9231 Union Hall Street Jamaica NY	Approved	\$650.00
1) Show location of panel PRLF4. 2) Bubble new work. 3) Property label equipment. Job finalized 3/10/09.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48630	08A0195	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NYU Epilepsy 225 East 34th Street New York NY	Hold	\$650.00
1) Printing on drawing to small to read shall be 1/8". 2) Verify that neutral in CT is not bonded to enclosure. 3) Show coordination between 800 amp service switch and distribution panel. 4) Verify bus size in circuit breaker panel. 5) Show fault current at panel or show series ratings.						
48631	08A0196	Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requested approval for the electric service equipment proposed to be installed	21-00 49th Avenue Queens NY	Approved	\$650.00
48632	08A0197	Jolt Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	225 Rector Place New York NY	Approved	\$650.00
48633	08A0198	Asko Electl Constn & Maint., Inc. 163-16 Northern Blvd. 2 Fl. Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	34 West 32nd Street New York NY	Approved	\$650.00
More than 2 conductors in split bolt. Job finalized 4/16/08.						
48634	08A0199	Northgate Electric Corporation 225 West 34th Street, Suite 901 New York NY 11746	Requested approval for the electric service equipment proposed to be installed	The Crosby Street Hotel 79 Crosby Street New York NY	Hold	\$650.00
1) Generator and ATS not shown on drawing. 2) Does ATS feed life safety? 3) Doors to service room to open out. 4) Provide standard notes on drawing. 5) Show voltage drop calculations.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48635	08A0200	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	6405 Yellowstone Boulevard Forest Hills NY	Approved	\$650.00
48636	08A0201	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1450 Clay Avenue Bronx NY	Ok, but	\$650.00
Tap conductor to 400 amp undersized.						
48637	08A0202	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 375 Pearl Street New York NY	Approved	\$650.00
Provide coordination study. Job finalized 12/10/08.						
48638	08A0203	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	839 6th Avenue New York NY	Approved	\$650.00
48639	08A0204	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Walgreens One Times Square New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48640	08A0205	J.G. Electrical Installations, Inc. 66-05 60th Place Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	40 Central Park South New York NY	Approved	\$650.00
1) Service entrance conductors undersized. 2) Show where tap box is located. Job finalized 8/5/08.						
48641	08A0206	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed		Approved	\$650.00
1) Verify coordination between 2000 and 3000 amp. 2) Service entrance conductors to 400 amp service switch undersized. Job finalized 6/9/08.						
48642	08A0207	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	38-42 Greene Street New York NY	Approved	\$650.00
48643	08A0208	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	1111 Father Capodanno Blvd. Staten Island NY	Ok, but	\$650.00
Provide signage at each service location indicating where the other services are located.						
48644	08A0209	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 450 West 41st Street New York NY	Ok, but	\$650.00
Need special permission for 7th service switch.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48645	08A0210	Accurate Electrical Contractors Corp. 88 New Dorp. Plaza, Suite 300 Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	141 5th Avenue New York NY	Denied	\$650.00
Show feeders on load side of trough. Void as per refiled 48818 6/18/08.						
48646	08A0211	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza New York NY	Approved	\$650.00
48647	08A0212	De Falco Electric 32-26 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	239 Central Park West New York NY	Approved	\$650.00
48648	08A0213	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	200 Chamber Street New York NY	Approved	\$650.00
48649	08A0214	Queens Electrical Contractors, Inc. 34-05 34th Street Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	106-20 Shorefront Parkway Rockaway NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48650	08A0215	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1140 Broadway New York NY	Approved	\$650.00
48651	08A0216	Eric & Ng Electrical Inc. 155 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	235 Canal Street New York NY	Approved	\$650.00
48652	08A0217	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	745 5th Avenue New York NY	Approved	\$650.00
48653	08A0218	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1510 Lexington Avenue New York NY	Approved	\$650.00
48654	08A0219	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	337 West 39th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48655	08A0220	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	343 West 39th Street New York NY	Approved	\$650.00
Provide barrier around fire pump service switch. Job finalized 5/19/08.						
48656	08A0221	Sunrise Electrical Services 86 Bowery New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Bed Bath & Beyond 2700 Veterans Highway Road Staten Island NY	Approved	\$650.00
48657	08A0222	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hampton Inn 102-10 Ditmars Blvd. East Elmhurst NY	Approved	\$650.00
1) 5' clearance needed in front of switchboard. 2) Provide 2nd door. Job finalized 5/19/08.						
48658	08A0223	B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Best Buy Store 400 East Fordham Road Bronx NY	Approved	\$650.00
48659	08A0224	All-Bright Electrical Contractors, Inc. 4214 Third Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	75-25 153rd Street Kew Gardens NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48660	08A0225	Colony Electric Company Inc. 64 West 3rd Street, Lower Level New York NY 10012	Requested approval for the electric service equipment proposed to be installed	316 Third Avenue New York NY	Hold	\$650.00
Confirm that natural gas generators can be used for emergency systems.						
48661	08A0226	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	The Waldorf Astoria 301 Park Avenue New York NY	Approved	\$650.00
48662	08A0227	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	One Bryant Park New York NY	Hold	\$650.00
1) Provide manufacturers drawings. 2) Provide one line drawing. 3) Submittal not in Advisory Board format.						
48663		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a solar photovoltaic system, to use building steel to ground the photovoltaic system and to backfeed into the elevator.	Kips Bay Tower Condo 330 East 33rd Street New York NY	Approved	\$0.00
1) Is a generator supplying elevators? 2) If connecting the PV to the elevator feeder do you have selectivity 620.62 on both normal and emergency feeders. 3) Provide documentation that the bus is not overboard. With the stipulation that the installation that the installation complies with Section 620.62 of the 2005 NEC.						
48664		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a solar photovoltaic system an to not file Advisory Board drawings to connect the 80 amp photovoltaic utility switch to the load side of a 277/480 volt 1600 am service switch where the sum of both overcurrent protective devicer will be 1680 amps.	Keyspan Energy Delivery 200 Gulf Avenue Staten Island NY	Denied	\$0.00
1) Is a generator supplying elevators? 2) If connecting to PV to the elevator feeders, do you have selectivity 620.62 on both normal and emergency feeders. 3) Provide documentation that the bus is not overloaded. Drawings must be submitted.						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48665		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a solar photovoltaic system and to not file Advisory Board drawings to connect the 350 amp photovoltaic utility switch to the load side of a 3000 amp service switch where the sum of both overcurrent protective devices will be 3350 amps, and to also ground the PV system to building steel	Ikea One Beard Street Brooklyn NY	Denied	\$0.00

Advisory Board drawings must be submitted for approval.

48666		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a solar photovoltaic system	Kips Bay Tower Condo 333 East 30th Street New York NY	Denied	\$0.00
-------	--	--	---	---	--------	--------

Advisory Board drawings must be submitted for approval.

48667		Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requesting concept approval to install a 50 KW 3 phase solar photovolataic system	30 South Bridge Street Staten Island NY	Approved	\$0.00
-------	--	---	---	--	----------	--------

With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 1) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.

48668		Douglas Electrical Contracting Corp. 87-25 78th Street Woodhaven NY 11421	Requesting permission for blanket approval of 6 solar photovoltaic installations that have variations of KW at 6 locations due to having a UL approval on another job and installing the almost all of the same components on each installation.	r Ave., 27-17 Wallace Ave., 2922 B ronx and Brookly NY	Denied	\$0.00
-------	--	---	--	---	--------	--------

48669		Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requesting permission to install a seventh service switch where one of the existing switches provides power to a fire pump.	1450 Clay Avenue Bronx NY	Approved	\$0.00
-------	--	---	---	------------------------------	----------	--------

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48670		Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requesting permission to install a seventh service switch where one of the existing switches provides power to a fire pump	On the Avenue Hotel 2178 Broadway New York NY	Approved	\$0.00
48671		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install seventh service switch where one of the switches will provide power to a fire pump.	The Edge Building 1 22 North 6th Street Brooklyn NY	Approved	\$0.00
48672		Noble Electrical Contracting Co., Inc. 1794 Clinton Avenue Bronx NY 10457	Requesting permission to connect the ground for the fire alarm fuse cutouts to the grounding collector bus instead of running 400' to the grounding electrode	2100 Bartow Avenue Bronx NY	Approved	\$0.00
48673		Noble Electrical Contracting Co., Inc. 1794 Clinton Avenue Bronx NY 10457	Requesting permission to install a seventh service switch that will provide power to a fire pump	2100 Bartow Avenue Bronx NY	Approved	\$0.00
48674		De Falco Electric 32-26 Greenpoint Avenue Long Island City NY 11101	Requesting permission to allow a 48" clearance in front of a 1000 KVA switchboard	239 Central Park West New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48675		Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to allow a front clearance in front of a 1000 KVA switchboard to be less than 5 feet	Sutter Ave., aka 340 Pennsylvania / Brooklyn NY	Approved	\$0.00
48676		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to allow a 5'6" height clearance around one end of each service switchboard due to a low overhead support beam	Rego Park 61-01 Junction Blvd. Rego Park NY	Approved	\$0.00
48677		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to install underground concrete encased Schedule 80 non metallic conduits for fire pump branch circuits on a job where the conduits are already installed	Rego Park Mall 61-01 Junction Blvd. Rego Park NY	Approved	\$0.00
48678		Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requesting permission to install a seventh service switch that will provide power to a fire pump.	Weill Cornell 407 East 61st Street New York NY	Approved	\$0.00
48679		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install concrete encased service entrance conductors in fiberglass reinforced epoxy non metallic conduits above switchgear into an adjacent room where a new service switch will be installed due to lack of space inside of the existing service room	515 West 52nd Street-Tower 2 New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48680		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requesting permission to replace defective 1600 and 2500 amp service switches that were infrared scanned and found to be defective.	NYU Medical Center 550 1st Avenue New York NY	Approved	\$0.00
48681		Laser Lite Electrical, Inc. 40 Gatton Street Staten Island NY 10309	Requesting permission to install service equipment for 24 multiple family buildings in an outdoor structure attached to the buildings and to not attach the grounding electrode conductor to the metal underground water pipe located over 100 feet from the point of entry	Markham Gardens Project Staten Island NY	Approved	\$0.00
<p>With the stipulation that the grounding conductor terminates to the metallic underground water pipe within five feet from the point of entrance to the building as per 250.52(A)(1) and a supplemental ground is installed 250.53(A)(2).</p>						
48682		Principal Electrical Corp. 78-06 Jamaica Avenue Woodhaven NY 11421	Requesting permission due to financial distress to leave as installed a multi family building that does not have separate PLP branch circuits and service	1758 Monroe Avenue Bronx NY	Approved	\$350.00
48683		Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requesting permission to leave as installed 4 sets of 500 MCM feeding a 1600 amp switchboard switch fused at 1600 amp	145-146 Central Park West New York NY	Denied	\$0.00
48684		Robert Derector Associates 19 West 44th Street New York NY 10036	Requesting permission due to lack of space inside of two electrical closets where old circuit breaker panels are being replaced with new to allow a front clearance of 30" where the panels will be installed facing each other	399 Park Avenue, 10th Floor New York NY	Hold	\$0.00
<p>Submit drawings and pictures.</p>						

ADVISORY BOARD CALENDAR

April 16, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48685		Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission due to air ducts and piping installed in dedicated equipment spaces inside of new electrical closets in 24 locations to allow with drip pans the installation of circuit breaker panels and transformers.	Bank of America One Bryant Park New York NY	Approved	\$0.00
With the stipulation that the drip pans must totally enclose the water piping and drain away from all electrical equipment and the bus ducts shall have the appropriate clearances for maintenance and servicing.						
48686		Ambrosino, DePinto & Schmieder 275 Seventh Avenue, 21st Floor New York NY 10001	Requesting permission to install eleven sets of 500 MCM Raychem 2 hour fire rated MC cable temporarily approximately 22 feet until Con-Ed can permanently feed the building approximately several months from now	Cooper Square Hotel 25 Cooper Square New York NY	Approved	\$0.00
48687		Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requesting permission to leave as installed 3 replacement circuit breaker panel mounted horizontally where the bottom rows of the circuit breakers handles are not in the "up" position when "on" in a school that does want the glazed stone wall disturbed to keep the historic condition intact	2756 Reservoir Avenue Bronx NY	Approved	\$350.00
With the stipulation that the panel hinged covers open sideways.						
48688	08A0228	Teknion, LLC 350 Fellowship Road Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion District Office Furniture		Hold	\$200.00
Need test report for wiring and structure as a complete assembly.						
48689	08A0229	Teknion, LLC 350 Fellowship Road Mount Laurel NY 08054	Requested approval for use in New York City of your Teknion Marketplace Office Worktable System		Hold	\$200.00
Need test report for wiring and structure as a complete assembly.						