

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55832	18A0436CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from August 15, 2018 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
56142	18A0677CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
OR 1) Fire pump OCPD-Emergency sode-is undersized. 2) Provide AIC rating of ATS #1 8/7/19 1) Provide coordination study between 600A fuse and down stream fuses. 10/25/19 1) Confirm the available s.c current at f.p controller is less than 100kA. 2) Clarify what existing equipment was relocated in the service room and comfirm compliance with BC 2702.1.2.1 12/17/19 1) Confirm compliance with BC 2702.1.2.1 12/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0016	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Fire pump conductor-emergency side-is undersized. 2) Fix typo on the collector bus for F.P. switch-size. 3) Provide equipment elevation and cut sheet(physical). with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				
56068	19A0048	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/18/19 1) Comply with 408.36- Provide main OCPD to new 1200A panel and provide cut sheet showing listing. 2) Provide Asbestos Abatement compliance document to include the service room location. 8/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0055	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Provide fire pumps AIC rating and available s c current. 2) Remove bonding from '50hy-EM-FPSS-C-5-(B)' panel is undersized and this panel shall be at least 600A rating-provide cut sheet and bus bar size-dwg #G1. 4) GEC 50 fire alarm are undersized-T250.66-Dwg # L1. 5) Confirm that emergency side of F.A. is a future connection with different submission-Dwg L1. 6) Show the supply of "50HY-SB-DS-6-1(B)". 7) Label all physical dwgs with related one line dwg or mark as 3rd device. 8) Verify each ATS either optional, EM or standby. 1/3/2020 1) Item # 2 from last revision is not addressed. 2) Confirm following all recommended setting within the coordination study. 3) Provide Bonding to '50HY'-FPSS-C-5(B)' - Dwg # G1. 4) Item #3 is partially addressed - FP service conductor feeds '50HY-FPSS-C-5(B)' is undersized.</p>				
	19A0060	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Comply with 408.36 and provide main OCPD to south and north distribution panels and provide cut sheet. 2) Provide coordination between 3000 A4BQ ss#2 in swbd "B" and upstream fuses-signed and sealed by P.E. 3) The secondary OCPD of the stepdown 150KVA transformer is overfused and provide secondary cond. Length. 4) Comply with 700.10(E)-provide disconnect switch at the secondary of F.A. transformer. 5) Fire alarm ATS shall be 4 pole to void double bonding when using emergency side. 6) Verify submitting solar equipment cuts. 7) Confirm listing to CHP equipment-provide cuts. 8) Fix typo for switchboard "B".. 9) Provide tap conductor size to north and south distribution panels 10) Show K2 interlock on the drawing-provide clarification for the interlock scheme.</p>				
56186	19A0092	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination & short circuit study. 2) Vertical bus (bottom part) in "DP-TC-BN" section #2 is undersized. (See cross section) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/2/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55834	19A0117	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/13/2020 Amended Dwgs # 1 & 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/9/2020 Amended Plan #1&2 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56000	19A0119	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show new F.A transformer & secondary OCPD on the one line dwg. Confirm other equipment are 3rd device. 2) Provide cut sheet for outdoor aluminum bus duct showing NRTL listing for outdoor use. 3) Provide termination details for bus duct on the switchboards. 6/6/19 1) Provide available s.c. current at connection point of 2500A AL bus way-the cut sheet shows 100K AIC rating not 200KA.. 7/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/5/2020 Amended dwgs # 1, 2, & 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55975	19A0171	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>I. GF SENSOR IS REQUIRED FOR 1200A GEN OCPD. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/14/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/2021 Amended Plan# A Rev 1,B Rev 4 and C Rev 7 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/23/2021 Amended Plan# C Rev 9. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55835	19A0177	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/2021 Amended Plans# A&B Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	19A0182	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>OR 1) Provide coordination between new 800A KRPC & upstream fuse.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
56049	19A0184	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Fix typo of ser sw #5 fire pump duplicated (should be ssw #7) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/24/2021 Amended plans # 1 & 2 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56196	19A0213	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Provide coordination between new fuses and upstream breaker. 10/30/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 2/18/2021 Amended Plans # 1 & 2 Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55960	19A0215	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provided 7' clearance between 1200A service switch and F.P. service switch.. 5/17/19. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55859	19A0217	Requesting Equipment Approval for RTRC.	Approved	\$200.00
<p>This approval is to permit the installation of RTRC outdoor, and it is not an approval for the specific project electrical installation. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
56174	19A0224	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/16/19 - 1. Show xfms & other equipment in service room on the one line dwg or verify if they are after 2nd level of OCPDs. 2. Physical doesn't match one line for "MSB-C-2" section #5 and "MSB-C-5" section #6. 3. Provide neutral cales for feeder bus duct. 12/16/2019 1) Item # 1 & 3 are not addressed. 2) SS # 4 is overfused . 4/29/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.. 10/28/2021 Amended plans# 1-9 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56178	19A0225	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire alarm neutral of "TF-FA" fire alarm transformer secondary to be bonded and grounded only in one location remove FDS-TX FA. 2) Busbar in "Dist-2" of switchboard "MSB-39-3" is undersized dwg 3 of 11. 3) Verify location of F.A. ATS and FA transition box. 4) Provide Asbestos Abatement compliance document. 5) Coordination between 2500A KRPC(SS #6) and downstream fuse 1600A KRPC in "MSB-39-4" and between 3000A KRPC and down stream 1600A KRPC fuse in "MSB-39-1" are not included within the coordination study and the coordination one line is not complete. 1/6/2020 1) Service bus bar feed ss#2, & 4 are undersized-service 6,7, and 8. 2) Verify ss# 1 & 2 in service #9 & 10-fix typo. 3) Confirm busbars size in "MSB-39-5" 4) Items #5 & 6 from last revision weren't addressed. 5/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
55851	19A0226	Requesting Special Permission to keep existing door swing as is.	Approved	\$350.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55988	19A0227	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/18/19 - 1. Provide bonding & grouding to FA service switch. 2. Confirm that the available SC current at the main swbd 'MSB-A' is less than the ATC rating (200kA) 3. Add license # to the cover sheet 4. Provide asbestos abatement compliance doc 5. Confirm 2HR fire rated room. 6/21/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/18/2020 Amended Dwg# B Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/26/2021 Amended Dwg# B Rev 6 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55836	19A0229	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0230	Requesting Special Permission for PLFA in free air.	Denied	\$350.00
Submit Constuction Code Determination form.				
56134	19A0232	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) EGC shall not be installed in a loop. 2) Service entrance conductor are not in accordance in 230.42(A)(2). 3) Remove limiter lugs from C/T. 4) Provide detail for c/t. 5) Provide cutsheet for the service disconnect means (circuit breakers). 6) Provide ACP-5 documentation. 7) room shall be 2 hr rated. 8) Remove for foreign equipment from room (irrigation pump). 9) Provide panic hardware. 10) Provide short circuit calculations. 8/6/19 1) Item #2 & 4 are not addressed. 2) Confirm that area of new electric work is under provided ACP5 Control #4339182. 9/18/19 1) Provide frame size of service switches/ 2) Provide full size dwg. 3) Item #2 from last revision is not addressed. 10/18/19 1) Item #2 from revision dated 4/24/19 still not addressed-comply with 230.42(A)(2). 12/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55860	19A0233	Requesting Equipment Approval for allowing luminaires to be installed over Fire Resistant Fabric. .	Approved	\$200.00
This approval is to accept the mounting of luminaires over fire resistive fabric. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0234	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
4/17/19 - 1. "LSA-1-2" switch is overfused in "CHP-MDP-A" and also "CB-4" in "CHP-C" is oversized. 2. Provide supplemental grounding to all existing service swbd. 3. Provide existing bus size feeding the new service switches. 4. Provide GFP to all service switches 1000A or above - 230.95. 5. Fix typo of "CHP-B" in elec. Service room "D" floor plan and typo of MLO for "CHP-MDP-C & D". 6. Provide physical dwg & provide CHP equipment cuts. 7. Coordination one line doesn't match EAB one line. 8. The provided ACP.5 control number, don't include project address. 9. Fix typo for "LSA-6-7" in "CHP-MDP-D". 10. Designer to show in the next EAB meeting to explain the design.				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
56052	19A0235	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) 400A TRS fuse is not coordinated with upstream 1200A A4BQ. 8/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55833	19A0236	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/2020 Amended dwg# A Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
56056	19A0237	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance required documents. 8/13/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55966	19A0240	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide available s.c. current and AIC rating of new 'DP-RT' swbd. 6/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56003	19A0242	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Confirm compliance with 408.60(E) exception - confirm that (4 ft) of busbar beyond the 4000A service switch is calculated based on 800A/ square inch. 2) Provide master electrician or professional engineer license #. 7/2/19 - 1. Provide selective coordination between the 3500A A4BY fuse and all secondary fuses. 2. Provide appropriate bus size feeding the new 800 amps A4BY (15) and existing 800 amps A4BY (11) fuses. 3. Provide installatoin premises correction as indicated in the asbestos report. 4. Provide neutral reduction calculations 7/3/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/20/2020 Received E-mail stating 80 Columbus Avenue is the correct address. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/20/20 Amended dwg# A Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55846	19A0243	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55837	19A0247	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/8/2020 Swap dwg #AB20-01 of 1-Revision 1, FP20-01 of 1-Revision 1, SB80-01 of 2-Revision 6, SB80-01 of 2-Revision 6 and SB80-02 of 2-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55962	19A0249	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide tap conductor length for SBP-3. 2) Clarify point (E) is SBP-2 or SBP-3 short circuit calcs doesn't match one line. 3) Show fire pump service room in the service room with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/17/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/10/19 Swap Dwgs C rev 5, D rev 2, E rev 8. 1/19/2022 Amended Plan # B Rev- 9, plan # D Rev- 3 and # E Rev-9..Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55852	19A0255	Requesting Special Permission to keep existing ATS installation under 1 RCNY 12-01 as is.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55838	19A0256	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/21/2020 Amended Plan A # Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/2/2021 Amended dwg# A Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGsm				
	19A0257	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide coordination of S.C. study signed and sealed by P.E. 2) Confirm 13 sets to "DP-27-A". 3) Confirm that no life safety equipment located within the service room with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.				
	19A0258	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide asbestos abatement compliance doc. 2) Existing service bus bar is undersized. 3) New incoming service conductors & new bus bars feed ss#3 & 4 are undersized. 4) New 1200A ss#4 is overfused.				
55853	19A0259	Requesting Special Permission to keep an optional ATS to share electrical equipment room with normal electrical power	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55854	19A0260	Requesting a Special Permission to accept project not in an EAB format.	Approved	\$350.00
Approval is for accepting the plan review documentations, applicant shall address all objections accordingly. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
56084	19A0261	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide available S.C. current at "567 Marcy" 1200A breakers.. 9/19/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/24/2020 Swap drawings # 1 REV2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/4/2020 Amended Dwg# A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55855	19A0262	Requesting a Special Permission for 1 ½" short clearance.	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55839	19A0263	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/20/2020 Amended plan # A.1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. to clearly mark and note all changes to original approved DWGs. 11/30/2020 Amended dwg# A Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/23/2021 Amended Dwg# A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55845	19A0264	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0265	Requesting Equipment Approval for PoE emergency and egress illumination.	Denied	\$200.00
POE for emergency and egress illumination application is not acceptable in NYC without a complete system listing.				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0266	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>1) Verify that the gen set is not a separately derived sys. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/23/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/9/2020 1) Service conductor feeds SSW # 3 is undersized</p>				
55959	19A0267	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Confirm using MI cables from FP controller to fire pump-show termination details for MI cable. 5/15/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/5/2022 Amended Plan# 1&2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55953	19A0268	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/18/19 - 1. Incoming service cond. Shall be concrete encased. 5/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
56008	19A0269	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Vertical service bus bar feeds 2500A SS#2 is undersized. 2) Fire pump GEC is undersized-T250.66 3) SS#4 fuse 700A A4BQ doesn't coordinate with downstream 400A A2K & 200A TR fuse. 4) Provide fuse size feeds ATS #3 normal side. 5) EGC of elevator machine is undersized-T250.122 6) Provide AIC rating & available s.c current at "retail" swbd. Also provide available s.c current at main swbd and confirm if AIC rating 200KA or 100KA for physical doesn't match one line. 7) Fix typo for ss#3 & 4 - one line doesn't match floor plan. 8) Confirm 5' clearance to F.A s.sw 9) Confirm ATSS are short circuit rated with OC devices and provide available s.c current at all ATSS.</p> <p>With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/11/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/16/2021 Amended plans# 1, 2, & 3 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56193	19A0270	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide new equipment cut sheet showing AIC rating. 2) Confirm that the existing equipment will be field evaluated for NRTL listing for new modification. 8/12/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/10/2020 Amended Plan #1 of 1-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/5/2021 Amended Plans# 1 Rev. 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55856	19A0273	Requesting Special Permission to allow 17" behind equipment in lieu of 36"	Approved	\$0.00
<p>Approved with stipulation to install plaques on the back of all three sections of SSB-D switchboard to read as "No service, testing or maintenance shall be performed while the equipment is energized". Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0274	Requesting a Special Permission to install conduit in egress enclosure (staircase).	Denied	\$0.00
Submit Construction Code Determination form to the Borough Commissioner's office requesting the variance for the proposed work.				
55970	19A0277	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide mechanical ventilation to electric service room. 2) Provide coordination for 1200A MDP. 5/17/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/3/2020 Amended Dwg# A Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55996	19A0279	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/16/19 1) Verify new verses existing and was reconnected and bubble all new work. 2) Provide coordination between new 2500A A4BQ fuse and down stream existing fuses signed and sealed by P.E. 7/1/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/30/2021 Amend Plan # A Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55847	19A0280	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/19/19 Swap Dwg # 1 rev.1 and 2 rev.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
56020	19A0281	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement Compliance document. 7/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 12/20/19 Swap Dwg #1-Revision 1. 3/3/2021 Amended Dwg# 1 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55848	19A0282	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 4/18/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/7/19 Swap Dwg # ACS-D-13548-1 Rev.2 and Dwg # ACS-D-13548-2 Rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55850	19A0283	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/24/2020 Amended Plan #1-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55948	19A0284	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/19/19 - 1. Confirm that new listed switch & enclosure is being supplied or that NRTL field evaluated is to be done. 5/24/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55954	19A0286	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show grounding (connection to ground bar) for "SSB-41GS-4" and fix physical of "SSB-41GS-3". 2) Confirm, that S.E.Bs are directly below service room and no concrete encase is required for incoming service conds. 3) Fix typo in one line dwg for phase tap connection for the existing fire pump. 4) Fire pump conductor from service switch to FP controller is undersized with the stipulation of providing ACP5 and ACP21 at the time of inspection which includes the 41st and 42nd floors(area of work), for inspector review. 5/23/19 Job finalized. With the stipulation of providing ACP5 & ACP21 at the time of inspection which includes the 41st and 42nd floors(area of work), for inspector review Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/2020 Amended dwgs# A Rev2, B Rev1 and C Rev 3. Amended dwgs# A Rev2 B Rev1 and C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 12/30/2020 Amended dwgs # A Rev 2, B Rev 1, C Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55958	19A0287	Special Permission	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55939	19A0288	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
4/18/19 - 1. Fire pump EGC is undersized - T250.122. 2. Vertical bus feeding SS#2 is undersized. 3. Provide coordination between 1600A kRPc & downstream 750A A4BY 5/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55903	19A0290	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/18/ 19 1) Provide 7' clearance between new service switch and F.A. service switch. 5/13/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55849	19A0291	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/19/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55857	19A0292	Requesting a Special Permission for 5kV tap.	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0293	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
OR 1) Provide tap conductor length. 2) Provide UL certificate of vendor will work on bus modification. 5/22/19 This job is void in lieu of Sub. #19A0367				

ADVISORY BOARD CALENDAR

April 24, 2019

Approval #	Submission #	Type of Request	Status	Fee
55973	19A0294	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 4/18/19 1) Provide Asbestos Abatement Compliance document. 2) Provide cover sheet include license # 6/5/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0295	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Provide trip size of "52-L1", "52-L2", "52-L3" and "52-L4". 2) Provide coordination and short circuit study signed and sealed by P.E. 3) Verify 5000A bus duct new or existing and confirm NRTL listing. 4) Conductors off 150A. C.B.s in "MSA" are undersized. 5) Provide neutral bonding and grounding to F.P. service switches and all service switches. 6) Fire pump tap doesn't comply with 695.4(A) Exception 3-tap shall be directly from transformer secondary. 7) Show bus bar size not ampacity on one line dwg to all switchboards. 8) Provide Asbestos abatement compliance document. 9) Ground electrode conductors for fire pump switch are undersized-T250.66. 10) Confirm that electrical room doors equipped with panic bars. 11) Provide information on Eaton 480 V main breaker and feeder breakers in paralleling and (collector bus) UL891 switchgear. Is this configuration approved by a NRTL? 12 Confirm if rear doors are being provided an 480V collector bus switchgear. 13) Submit cuts for "ATS-MSBD"-ST shall be locked rotor. 14) "ATS-MSBD" is not permitted to be located in electrical room as per building code CH. 17.				
55858	19A0296	Requesting a Special Permission to keep service panel in existing location.	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				