

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|----------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|----------|--------|
| 48383CO2 | 07A0648CO2 | Metro York Electrical, Inc. 23-86 BQE Long Island City NY 11103 | Requested approval for the electric service equipment proposed to be installed | Bowery Bay 45-41 Berrian Blvd. Queens NY | Approved | \$0.00 |
| Carry over from April 16, 2008 meeting. | | | | | | |
| 48394CO | 07A0649CO | Antares Enterprises 10838 Bloomfield Avenue Santa Fe Springs CA 90670 | Requested approval for use in New York City of your Fluorescent Lighting Fixtures. Model/Series Numbers: Odyssey T4 and Geminix T5. | | Approved | \$0.00 |
| Carry over from December 12, 2007 meeting. With the stipulation that any and all references with regard to product identity "portable under cabinet lighting" as indicated in ETL report. | | | | | | |
| 48438CO4 | 08A0036CO4 | Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Weill Cornell 407 East 61st Street New York NY | Approved | \$0.00 |
| Carry over from April 16, 2008 meeting. With the stipulation that fire department approval is required. | | | | | | |
| 48548CO | 08A0131 | CSA Engineering Services 37 Miry Brook Road Danbury CT 06810 | Requested approval for the electric service equipment proposed to be installed | NYC Dept. of Environmental Wards Island Water Pollution Contro Wards Island NY | Approved | \$0.00 |
| Carry over from March 12, 2008 meeting. Engineer to appear next meeting. Job finalized 8/1/08. | | | | | | |
| 48603CO | 08A0168CO | Rothstein & Hoffman Elec. Serv. Inc. 257 Centre Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | Four Point Sheraton Hotel 66 Charlton Street New York NY | Denied | \$0.00 |
| Carry over from April 16, 2008 meeting. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|----------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|----------|----------|
| 48634CO | 08A0199CO | Northgate Electric Corporation 225 West 34th Street, Suite 901 New York NY 11746 | Requested approval for the electric service equipment proposed to be installed | The Crosby Street Hotel 79 Crosby Street New York NY | Denied | \$0.00 |
| Carry over from April 16, 2008 meeting. 1) Neutral not bonded to enclosure in fire alarm cut out. 2) What does the 400 ATS feed? 3) More than one switch installed on normal side for the fire pump. 4) Emergency side fire pump circuit double switched. 5) Fire pump normal and emergency branch circuit not fire rated. 6) Fire pump emergency fusing not 150%. 7) Fire pump service switch not rated at 600%. | | | | | | |
| 48660CO | 08A0225CO | Colony Electric Company Inc. 64 West 3rd Street, Lower Level New York NY 10012 | Requested approval for the electric service equipment proposed to be installed | 316 Third Avenue New York NY | Approved | \$0.00 |
| Carry over from April 16, 2008 meeting. | | | | | | |
| 48684CO | | Robert Derector Associates 19 West 44th Street New York NY 10036 | Requesting permission due to lack of space inside of two electrical closets where old circuit breaker panels are being replaced with new to allow a front clearance of 30" where the panels will be installed facing each other | 399 Park Avenue, 10th Floor New York NY | Approved | \$0.00 |
| Carry over from April 16, 2008 meeting. | | | | | | |
| 48690 | 08A0242 | Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010 | Requested approval for the electric service equipment proposed to be installed | Beekman Tower 8 Spruce Street New York NY | Approved | \$650.00 |
| 1) Single egress door in cellar to swing out. 2) Add generator distribution to 1-Line. Job finalized 7/31/08. | | | | | | |
| 48691 | 08A0230 | Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | NYU Silver Towers #1 and #2 100 Bleeker Street New York NY | Approved | \$650.00 |
| Remove neutral ground on transformers utility source ground utilized. Job finalized 6/3/08. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|---------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|-------------------------------------------------------|----------|----------|
| 48692 | 08A0231 | J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216 | Requested approval for the electric service equipment proposed to be installed | 478 Broadway New York NY | Approved | \$650.00 |
| | | | | | | |
| 48693 | 08A0258 | Indy Electric Corp. 125-05 Liberty Avenue Richmond Hill NY 11419 | Requested approval for the electric service equipment proposed to be installed | 140-21 32nd Avenue Flushing NY | Approved | \$650.00 |
| Can 2nd egress be at opposite end of room? Job finalized 6/9/08. | | | | | | |
| 48694 | 08A0266 | Grand Electric, Inc. 660 Grandview Avenue Ridgewood NY 11385 | Requested approval for the electric service equipment proposed to be installed | 406 15th Street Brooklyn NY | Approved | \$650.00 |
| | | | | | | |
| 48695 | 08A0272 | Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461 | Requested approval for the electric service equipment proposed to be installed | Verizon 118-15 115th Avenue South Ozone Park NY | Approved | \$650.00 |
| 1) Fire pump feed from generator must be ahead of generator main breaker. 2) Port gen. box drawing shows cable conn to switchboard other drawings show bus duct clarify. Job finalized 6/25/08. | | | | | | |
| 48696 | 08A0269 | DiFazio Electric NY, Inc. 42-24 Douglaston Parkway Douglaston NY 11363 | Requested approval for the electric service equipment proposed to be installed | NYU Alumni Hall 33 Third Avenue New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|---------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|----------------------------------------------------------|----------|----------|
| 48697 | 08A0256 | A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220 | Requested approval for the electric service equipment proposed to be installed | 100 West 58th Street New York NY | Approved | \$650.00 |
| 48698 | 08A0255 | Meir Electrical Corp. 423 East 78th Street New York NY 10021 | Requested approval for the electric service equipment proposed to be installed | 212 West 91st Street New York NY | Approved | \$650.00 |
| 48699 | 08A0263 | Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028 | Requested approval for the electric service equipment proposed to be installed | Regeis Care Center 3200 Baychester Avenue Bronx NY | Approved | \$650.00 |
| 48700 | 08A0264 | Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028 | Requested approval for the electric service equipment proposed to be installed | 55 Van Dam Street New York N | Approved | \$650.00 |
| 48701 | 08A0262 | Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028 | Requested approval for the electric service equipment proposed to be installed | 560 West 165th Street New York NY | Approved | \$650.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|---------------------------------------------------------------------------------|--------------------------------------------------------------------------------|--------------------------------------------------------------------------|----------|----------|
| 48702 | 08A0252 | BT Electrical, Inc. 85-02 67th Drive Rego Park NY 11374 | Requested approval for the electric service equipment proposed to be installed | 45 East 66th Street New York NY | Approved | \$650.00 |
| 48703 | 08A0250 | Jim Electric Corp. 223 52nd Street Brooklyn NY 11220 | Requested approval for the electric service equipment proposed to be installed | 11 Park Place New York NY | Approved | \$650.00 |
| 48704 | 08A0248 | Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211 | Requested approval for the electric service equipment proposed to be installed | 770 Lexington Avenue New York NY | Approved | \$650.00 |
| 48705 | 08A0243 | Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238 | Requested approval for the electric service equipment proposed to be installed | Ennis Francis House 2070 Adam Clayton Powell Jr. Blvd. New York NY | Approved | \$650.00 |
| 48706 | 08A0240 | OM Electric, Inc. 262 West 38th Street New York NY 10018 | Requested approval for the electric service equipment proposed to be installed | 172-14 Henley Road Queens NY | Approved | \$650.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------------------------------------------------------------------------------------------------------------------------------------|--------------|----------------------------------------------------------------------------------|--------------------------------------------------------------------------------|----------------------------------------------------|----------|----------|
| 48707 | 08A0238 | Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467 | Requested approval for the electric service equipment proposed to be installed | 125 West 26th Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 48708 | 08A0236 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | 27 North 6th Street Brooklyn NY | Approved | \$650.00 |
| | | | | | | |
| 48709 | 08A0288 | Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314 | Requested approval for the electric service equipment proposed to be installed | Barclays Capital 200 Park Avenue New York NY | Hold | \$650.00 |
| | | | | | | |
| 48710 | 08A0281 | Belmont Electrical Inc. 244 Fifth Avenue, Suite 2352 New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | 240 Central Park South New York NY | Approved | \$650.00 |
| Load side of service switch shall be noted future use or provide 2nd fusing. Job finalized 9/24/08. | | | | | | |
| 48711 | 08A0285 | Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016 | Requested approval for the electric service equipment proposed to be installed | 139 Centre Street New York NY | Approved | \$650.00 |
| 1) Show generator room or enclosure. 2) Show correct amount of conduit on load side of 4000A generator s/s. Job finalized July 21, 2008. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|---------------------------------------------------------------------------------|--------------------------------------------------------------------------------|-----------------------------------------------------------------|----------|----------|
| 48712 | 08A0275 | Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418 | Requested approval for the electric service equipment proposed to be installed | 133-145 W. 22nd Street New York NY | Approved | \$650.00 |
| 1) Service entrance conductors undersized for both services. 2) Supplemental grounds not provided. 3) Neutrals in fuse cut outs not bonded to enclosure. Job finalized 7/30/08. | | | | | | |
| 48713 | 08A0289 | PJS Electric, Inc. 10 43rd Street, Box #L15 Brooklyn NY 11232 | Requested approval for the electric service equipment proposed to be installed | DEP Spring Creek Auxiliary Plant Brooklyn NY | Hold | \$650.00 |
| Not reviewed | | | | | | |
| 48714 | 08A0277 | A.T.J. Electrical Inc. 33-61 55th Street Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | Achievement First Endeavor 510 Waverly Avenue Brooklyn NY | Approved | \$650.00 |
| 1) Service laterals not shown on drawing. 2) Remove neutral bond emergency side FCO. 3) Verify service entrance wiring method to 600 amp service switch. 4) Provide bus sizes in panelboards. Job finalized 6/10/08. | | | | | | |
| 48715 | 08A0282 | Uptown Electric, Inc. 128-20 14th Avenue College Point NY 11356 | Requested approval for the electric service equipment proposed to be installed | 34 Leonard Street New York NY | Approved | \$650.00 |
| 1) FCO neutrals not bonded to enclosures. 2) Fire pump service switch must be 12" away from distribution equipment. 3) Verify why service entrance conductors to fire pump are concrete encased. Job finalized 3/26/09. | | | | | | |
| 48716 | 08A0284 | Empire City Electric Inc. 68 E. 131st Street, Suite 302 New York NY 10037 | Requested approval for the electric service equipment proposed to be installed | The Alexander 250 East 49th Street New York NY | Ok, but | \$650.00 |
| 1) Service entrance conductors undersized. 2) Provide bus sizes inside of panelboards. 3) Provide size number of sets of conductors feeding "QMB R/H". 4) FACP can't be on load side of fire pump service switch. 5) Where is fire pump service switch located. 6) Provide fuse type in panel OP-EL. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|---------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|----------------------------------------------|----------|----------|
| 48717 | 08A0291 | Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307 | Requested approval for the electric service equipment proposed to be installed | 140 58th Street Brooklyn NY | Hold | \$650.00 |
| Drawing not submitted in Advisory Board format. | | | | | | |
| 48718 | 08A0235 | CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | Myrtle Avenue Condominiums Brooklyn NY | Hold | \$650.00 |
| Engineer to appear at next meeting. | | | | | | |
| 48719 | 08A0232 | Compsec Electric Corporation 39-12 Crescent Street Long Island City NY 11106 | Requested approval for the electric service equipment proposed to be installed | 41-17 Crescent Street Long Island City NY | Hold | \$650.00 |
| 1) Provide size and number of sets of conductors or 1000 side of 4000 amp service switch. 2) Provide bus sizes in panelboards. 3) Provide size of service entrance conductors feeding fire pump service switch 4) No selectivity between 1600 and distribution HDP. | | | | | | |
| 48720 | 08A0233 | Compsec Electric Corporation 39-12 Crescent Street Long Island City NY 11106 | Requested approval for the electric service equipment proposed to be installed | 41-34 Crescent Street Long Island City NY | Approved | \$650.00 |
| 2 sets of 500 MCM fused at 1200 amps. Job finalized 6/6/08. | | | | | | |
| 48721 | 08A0257 | Judd Electric, Inc. 41-41 38th Street Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 32 Court Street Brooklyn NY | Approved | \$650.00 |
| Trough can not be installed through a fire rated wall. Job finalized 5/19/08. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------|--------------------------------------------------------------------------------|--------------------------------------------------------------------|----------|----------|
| 48722 | 08A0267 | Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356 | Requested approval for the electric service equipment proposed to be installed | Roosevelt Island Bridge New York NY | Denied | \$650.00 |
| 1) Transformer secondary is not bonded to enclosure and grounded to building steel. 2) Show selectivity between 800 amp circuit breakers. 3) Bus in end box and circuits are undersided. 4) Feeders from service switch to transformers undersized. 5) Provide sizes of ATS switches. 6) Generator feeder undersized. 7) All high voltage feeders undersized. 8) 3rd fusing off of generator not shown or on drawing. | | | | | | |
| 48723 | 08A0265 | Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456 | Requested approval for the electric service equipment proposed to be installed | 3055 3rd Avenue Bronx NY | Approved | \$650.00 |
| Fire pump not tapped as per 695.3A. Job finalized 8/7/08. | | | | | | |
| 48724 | 08A0271 | Colony Electric Co., Inc. 64 West 3rd Street, Lower Level New York NY 10012 | Requested approval for the electric service equipment proposed to be installed | NYU Infrastructure Project 334 East 26th Street New York NY | Approved | \$650.00 |
| 48725 | 08A0270 | B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | Circuit City 1965 Broadway New York NY | Approved | \$650.00 |
| 48726 | 08A0254 | Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | Mott Haven Campus(Bronx) 730 Concourse Village West Bronx NY | Approved | \$650.00 |
| Verify fuse size on emergency side feeding panel EDPH-main. Job finalized 5/21/08. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|---------------------------------------------------------|----------|----------|
| 48727 | 08A0261 | Pro Electric Corp. 137 King Street Brooklyn NY 11231 | Requested approval for the electric service equipment proposed to be installed | CUNY Law School 65-21 Main Street Flushing NY | Approved | \$650.00 |
| | | | | | | |
| 48728 | 08A0259 | Mazza Electric Corp. 494 Eighth Avenue New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | 37 West 28th Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 48729 | 08A0280 | Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304 | Requested approval for the electric service equipment proposed to be installed | 310 Greenwich Street New York NY | Ok, but | \$650.00 |
| Service entrance conductors to 1200 amp service switch are undersized. | | | | | | |
| 48730 | 08A0254 | Five Star Electric Corp 101-32 101st Street Ozone Park NY 11416 | Requested approval for the electric service equipment proposed to be installed | 45th Street Hotel 66 West 45th Street New York NY | Hold | \$650.00 |
| 1) 400 transformer s and switch not bonded and grounded. 2) Time Warner service switch neutral not bonded in enclosure. 3) FCO neutral not bonded to enclosure. 4) Normal and emergency fire pump circuits not fire rated. 5) Fire pump emergency disconnect switches not remote from generator distribution. 6) Are ATS 3 or 4 pole. 7) Provide load calculations. 8) Fire pump tap doesn't comply with 695.3A. 9) Service switch #2 doesn't coordinate with 1000 amp distribution fuses. | | | | | | |
| 48731 | 08A0268 | Contractors Electrical Service, Inc. 213 West 35th Street, 601A New York NY 10001 | Requested approval for the electric service equipment proposed to be installed | 860 6th Avenue, Basement New York NY | Approved | \$650.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|------------------------------------|----------|----------|
| 48732 | 08A0287 | J.G. Electrical Installations, Inc. 66-05 60th Place Ridgewood NY 11385 | Requested approval for the electric service equipment proposed to be installed | 630 3rd Avenue New York NY | Approved | \$650.00 |
| | | | | | | |
| 48733 | 08A0286 | Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029 | Requested approval for the electric service equipment proposed to be installed | 50 Franklin Street New York, NY | Approved | \$650.00 |
| | | | | | | |
| 48734 | 08A0274 | Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418 | Requested approval for the electric service equipment proposed to be installed | 410 4th Avenue Brooklyn NY | Approved | \$650.00 |
| 1) Verify if Con-Ed or contractor cables are entering switchgear. 2) Fire pump can have only one switch. 3) Fuse not coordinated. 4) Service bus feeding 2000 amp switch undersized. Job finalized 7/30/08. | | | | | | |
| 48735 | 08A0276 | Accurate Electrical Contractors Corp. 88 New Dorp Plaza, Suite 300 Staten Island NY 10306 | Requested approval for the electric service equipment proposed to be installed | 3035 White Plains Road Bronx NY | Approved | \$650.00 |
| 1) Provide tap detail in 8"x8" trough. 2) Verify sets of Parallel conductors in 10"x10" trough. 3) 800 amp service switch fuse doesn't coordinate with 350 amp fuse. Job finalized 6/10/08. | | | | | | |
| 48736 | 08A0278 | Mari Electric Contractors Inc. 635 Richmond Road Staten Island NY 10304 | Requested approval for the electric service equipment proposed to be installed | 104-110 4th Avenue Brooklyn NY | Approved | \$650.00 |
| 1) Set of 600 MCM for future space fused at 800 amps. 2) Relocate meter banks to allow only 1 door. 3) Install barrier out the end of the switchboard. Job finalized 6/10/08. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|----------------------------------------------------------------------------------------------|--------------|---------------------------------------------------------------------------------|--------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|----------|----------|
| 48737 | 08A0283 | A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433 | Requested approval for the electric service equipment proposed to be installed | City Clerk's Office Relocation 100 Center Street/141-155 Worth Street New York NY | Approved | \$650.00 |
| Indicate old room layout drawing where front of the switchboards are. Job finalized 5/19/08. | | | | | | |
| 48738 | 08A0260 | R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358 | Requested approval for the electric service equipment proposed to be installed | Ronald McDonald House 267-07 76th Avenue New Hyde Park NY | Hold | \$650.00 |
| 1) Why are parallel conductors increases at trough? 2) Provide short circuit curves. | | | | | | |
| 48739 | 08A0234 | J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Metro PCS 420 East 62nd Street New York NY | Approved | \$650.00 |
| Service room doors to open out with panic hardware. Job finalized 6/6/08. | | | | | | |
| 48740 | 08A0253 | S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215 | Requested approval for the electric service equipment proposed to be installed | 240 Park Avenue New York NY | Approved | \$650.00 |
| 48741 | 08A0251 | Venus Electrical Contractors, Inc. 34-14 Crescent Street Astoria NY 11106 | Requested approval for the electric service equipment proposed to be installed | John Jay High School 237 7th Avenue Brooklyn NY | Approved | \$650.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|-------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|----------------------------------------------------------------------|----------|----------|
| 48742 | 08A0249 | OM Electric, Inc. 262 West 38th Street New York NY 10018 | Requested approval for the electric service equipment proposed to be installed | 600 Broadway New York NY | Approved | \$650.00 |
| 48743 | 08A0244 | Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419 | Requested approval for the electric service equipment proposed to be installed | The Crown Heights Apartments 1055 St. John's Place Brooklyn NY | Approved | \$650.00 |
| 48744 | 08A0241 | Frank Pugliese Electrical 141-18 Holly Avenue Staten Island NY 10304 | Requested approval for the electric service equipment proposed to be installed | 100 West 18th Street New York NY | Approved | \$650.00 |
| 48745 | 08A0239 | Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 5th Avenue a.k.a 45 Rockefeller Ce New York NY | Approved | \$650.00 |
| 48746 | 08A0237 | Solar Electric Systems Inc. 452 West 55 Street New York NY 10019 | Requested approval for the electric service equipment proposed to be installed | 100 West 18th Street New York NY | Approved | \$650.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|----------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------|----------|----------|
| 48747 | 08A0290 | obal Electrical Contracting Westchester, Inc. 4065 Boston Road Bronx NY 10466 | Requested approval for the electric service equipment proposed to be installed | Remsen Hall-Queens College Queens NY | Approved | \$650.00 |
| 1) Bond neutral to enclosure in FCO on normal side. 2) Rewrite notes for 277/480. 3) Transformers fuses are rated for 250 volts not 480. Job finalized 6/23/08. | | | | | | |
| 48748 | 08A0292 | Jenmar Electrical Contracting Corporation 98-19 103rd Avenue Ozone Park NY 11417 | Requested approval for the electric service equipment proposed to be installed | Trader Joe's/Michael's Stores 90-30 Metropolitan Avenue Forest Hills NY | Approved | \$650.00 |
| 1) Approval pending approval of 1st drawing 47810. 2) Verify who installed service entrance conductors from Trader Joe circuit to service switch. 3) Verify who installed feeders to Michael Store panel. 4) Verify who installed service entrance conductors from transformer switch to service switch to Staples store. 5) Verify who installed service entrance, service switch and feeder for future tenant. 6) provide short circuit curves for Michael's store distribution panel. 7) Show selectivity between 1200 and 600 amp circuit breakers. 8) Series ratings for Trader Joe not prohibited. Job finalized 8/8/08. | | | | | | |
| 48750 | | Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222 | Requesting concept approval of the installation of a solar photovoltaic system and to not file Advisory Board drawings to connect the 300 amp second PV fusing to a 3000 amp bus on a 265/460 volt 1000 KVA service | Ikea One Beard Street Brooklyn NY | Denied | \$0.00 |
| Drawings must be submitted. | | | | | | |
| 48751 | | Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222 | Requesting permission for the concept approval of a solar photovoltaic system and to utilize Section 690.64(B) of the 2008 NEC by connecting the 60 ampere PV circuit breaker to the load side of the 800 amp service switch. | Brooklyn Navy Yard Perry Building Brooklyn NY | Approved | \$0.00 |
| With the stipulation that the 800 amp service switch coordinates with the 60 ampere PV circuit breaker. | | | | | | |
| 48752 | | Jim Electric Corp. 223 52nd Street Brooklyn NY 11220 | Requesting permission to reutilize two existing feeder electrical conduits installed inside of an existing elevator shaft where new feeders will be repulped to power the elevators. | 11 Park Place New York NY | Approved | \$0.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|--------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------|----------|--------|
| 48753 | | B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377 | Requesting permission to install an 8th service switch where two of the existing switches provides power to fire pumps and to locate the new service switch in a 2 hour fire rated room directly above the service room and to also allow the fire pump circuit conductors to be run without concrete encasement through 2 two hour fire rated rooms | Circuit City 1695 Broadway New York NY | Approved | \$0.00 |
| 48754 | | Mari Electric 535 Wild Avenue Staten Island NY 10314 | Requesting permission due to no common areas inside of a new commercial building, to allow the service equipment to be installed on the exterior of the building. | 2066 Hylan Blvd. Staten Island NY | Approved | \$0.00 |
| 48755 | | Ivy League Licensed Electl Contrs Inc. 3309 Avenue N Brooklyn NY 11234 | Requesting permission to install service equipment in the basement of a new building where the height of the headroom will be 5'6". | Breezy Point 134 Ocean Avenue Breezy Point NY | Approved | \$0.00 |
| 48756 | | J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101 | Requesting permission to install a seventh service switch where one of the service switches provides power to fire pump. | Metro PCS 450 West 41st Street New York NY | Approved | \$0.00 |
| 48757 | | DiFazio Electric NY, Inc. 42-24 Douglaston Parkway Douglaston NY 11363 | Requesting permission to install a seventh service switch where one of the service switches provides power to a fire pump | NYU Alumni Hall 33 Third Avenue New York NY | Approved | \$0.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------|----------|----------|
| 48758 | | Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013 | Requesting permission to leave as installed on the 74th floor a 2000 amp service grounded to building steel. | Chrysler Building 405 Lexington Avenue, 74th Floor New York NY | Approved | \$350.00 |
| With the stipulation that the water pipe grounding electrode is bonded to the building steel within five feet from where the water piping enters the building. | | | | | | |
| 48759 | | MF Electrical Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475 | Requesting permission to leave outdoor temporary pole service to feed new mausoleum until a second mausoleum is built with a new service that will serve the two buildings. | All Faith Cemetery 67-29 Metropolitan Avenue Middle Village NY | Approved | \$0.00 |
| 48760 | | Schwimmer Electric Service Corp. 244 5th Avenue, Suite 29154, 2nd Fl. New York NY 10001 | Requesting permission due to hardship to correct to leave as installed 27 new 2,3, and 4 family homes that were wired without a separate public light and power meter. | Hosmer Ave., E, 233rd St., 229th St., Bronx NY | Approved | \$0.00 |
| 48761 | | Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456 | Requesting permission to leave as installed due to a hardship to repair replacement of upgraded service equipment that is located in a bathroom | 1043 Ward Avenue Bronx NY | Approved | \$350.00 |
| With the stipulation that gasketing is installed on the enclosure containing the service equipment to prevent moisture inside the enclosure. | | | | | | |
| 48762 | | S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215 | Requesting permission to install a ground fault sensor due to the 1200 amp switch having no provisions to install ground fault protection on a 1000 KVA installation where the drawings were approved without GFP. | Avalon 4-75 48th Avenue Long Island City NY | Approved | \$350.00 |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------------------------------------------------------------------------------------|--------------|----------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------|----------|----------|
| 48763 | | Takos & K Electric, Inc. 38-58 11th Street Long Island City NY 11101 | Requesting permission to install 8 sets of copper 500 MCM conductors in EMT temporarily for 20 feet for approximately 1 year until Con-Edison can permanently feed the building on a service over 1000 KVA | 220 West 19th Street New York NY | Approved | \$0.00 |
| With the stipulation that the total fusing of the switchboard does not exceed 2000 amps. | | | | | | |
| 48764 | | mbrosino,DePinto&Schmieder Consul. En 275 Seventh Avenue, 21st Floor New York NY 10001 | Requesting permission to install 10 sets of copper 600 MCM THHN conductors temporarily approximately 22 feet in through until Con-Ed can permanently feed the building several months from now. | Cooper Square Hotel 25 Cooper Square New York NY | Approved | \$0.00 |
| 48765 | | Jen Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214 | Requesting permission to allow a single door instead of two in a 1000 KVA service room. | 276 Stagg Street Brooklyn NY | Approved | \$0.00 |
| 48766 | | Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232 | Requesting permission due to extreme financial distress and mis-interpretation of 110.26(A)(2) to leave as installed in 117 two and three family new homes, approximately 15 feet of unfused service entrance conductors installed in Greenfield in the walls and ceilings of a new frame building. | Spring Creek Homes Brooklyn NY | Denied | \$350.00 |
| 48767 | | Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101 | Requesting permission to apply a 50% demand to window A/C units as per the 2002 New York City amendments, due to the building owner adding electric ranges to the apartments. | 110-42 Merrick Boulevard Jamaica NY | Approved | \$350.00 |
| Pending inspection and verification of job. | | | | | | |

ADVISORY BOARD CALENDAR

May 14, 2008

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|------------|--------------|-----------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|----------|----------|
| 48768 | | June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461 | Requesting permission for concept approval of electrical closet design | 47-49 East 34th Street New York NY | Denied | \$0.00 |
| | | | | | | |
| 48769 | | Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314 | Requesting permission to leave as installed bus ducts installed in electrical closets with water piping installed behind and on the sides of the bus ducts leaving minimal clearance to maintenance the bus ducts and to allow telephone and communication equipment in the electrical closet. | 306 Gold Street Brooklyn NY | Denied | \$350.00 |
| | | | | | | |
| 48770 | 08A0293 | Leviton Manufacturing 59-25 Little Neck Parkway Little Neck NY 11362 | Requested approval for use in New York City of your Power Receptacle Modular Design with Mating Connector. Model/Series Numbers: M8300, M8200, M5362, M5262 and MSTWL. | | Approved | \$200.00 |
| | | | | | | |
| 48771 | | Lakhani & Jordan Engineers, P.C. 50 East 42nd Street, Suite 1001 New York NY 10017 | Requesting permission due to a failed generator that will take several months to repair to temporarily tap power from an existing roof generator by tapping power after the generators main switch from the line side of the emergency terminals from a ATS switch that will be hardwired to a temporary distribution panel that will contain 3 sets of overcurrent devices that will power open wiring that will feed 3 transfer switches that the defective generator used to feed in an area only accessible to qualified persons. | WABC TV 7 Lincoln Square New York NY | Approved | \$0.00 |

With the stipulation that the installation will remain in service no longer than six months and the New York Fire Department is notified of this installation.