

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44917CO	10A0025CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University Chiller Upgrade 530 West 120th Street New York NY	Approved	\$0.00
Carry over from January 13, 2010 meeting.						
49871CO2	09A0512CO2	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gourveneur Health Services 277 Madison Street New York NY	Approved	\$0.00
Carry over from March 17, 2010 meeting. 1) Show clearance details of bus duct to fire enclosure. 2) Provide cut sheets of materials be used for fire ratings. Job finalized 9/24/10.						
49942CO	10A0043CO	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital Center 506 Lenox Avenue New York NY	Approved	\$0.00
Carry over from February 10, 2010 meeting. Delete GFP on all emergency breakers. Job finalized 9/20/10.						
50036CO	10A0106CO	npbell and Dawes Ltd. Electrical Contract 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NYU-Tisch School of Arts 111-113 Second Avenue New York NY	Approved	\$0.00
Carry over from April 14, 2010 meeting.						
50068CO	10A0138CO	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Rockefeller University 1230 York Avenue New York NY	Approved	\$0.00
Carry over from April 14, 2010 meeting. 1) Provide Russell paralleling physical drawings. 2) items 7,8,9, and 10 not addressed from last meeting. 3) Neutral link not addressed from last meeting. 3) Neutral link not show on Russell switchgear 1 line. 4) Fire pump feed off of Russell Board shall be tapped from the line side feed on the board as per 695.3A. Job finalized 8/6/12.						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50079	10A0141	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	8719 Avenue D Brooklyn NY	Approved	\$650.00
1) Delete 30A switch for F.A. system on load side of 80A-3P ATS. 2) Show grounding on F.A. transformer. Job finalized 11/19/10.						
50080	10A0142	Jen Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	160 East 88th Street New York NY	Approved	\$650.00
Service entrance conductors to service Switch #6 not identified. Finalized 6/4/10.						
50081	10A0143	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	250 East 49th Street New York NY	Approved	\$650.00
1) Service entrance conductors undersized. 2) Bus size or service Switch #2 not shown. 3) Future disconnect switch for Store #2 not identified. 4) Coordination-SS#5 1200A-400A. Job finalized 6/4/10.						
50082	10A0144	Multi-Tech Electric, Inc. 24-42 49th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	185 East 85th Street New York NY	Approved	\$650.00
Indicate make, model & breaker, type; ratings for "store panel". Job finalized 6/7/10.						
50083	10A0145	Associated Electrl Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	1921 7th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50084	10A0146	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	NY Public Theatre 425 Lafayette Street New York NY	Approved	\$650.00
50085	10A0147	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	DHL 501 Tenth Avenue New York NY	Approved	\$650.00
50086	10A0148	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NY Weill Cornell Med. Ctr. 525 East 71st Street New York NY	Approved	\$650.00
Job finalized 6/7/10.						
50087	10A0149	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Main Street Radiology III 136-25 37th Avenue Flushing NY	Approved	\$650.00
50088	10A0150	Richard Neu, Licensed Electrician 4347 Hylan Blvd. Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	405 West 53rd Street New York NY	Approved	\$650.00
1) Fire pump branch circuit to be fire rated. 2) Verify size of vertical bus feeding 800 amp service switches. 3) Verify grounding frames of disconnect switches. 4) Rear accessible switchboard requires 36" clear both sides. Job finalized 10/28/10.						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50089	10A0151	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 470 145 West 84th Street New York NY	Approved	\$650.00
1) Neutral disconnect link not provided in new 1200 amp service switch. 2) Generator disconnect switch drawn backwards. 3) Remove neutral bond in 1200A generator disconnect switch. Only 1 bond permitted-use Con Ed neutral bond. Job finalized 6/22/10.						
50090	10A0152	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S./I.S. 42Q 488 Beach 66th Street Averne NY	Approved	\$650.00
1) Verify size EGC's on line side of service switch. 2) Provide all bus sizes on load side of CT and in the new board. 3) FCO to be changed to switches. 4) Verify if ATS are 3 or 4 pole. Job finalized 7/30/10.						
50091	10A0153	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1 Battery Park Plaza New York NY	Approved	\$650.00
50092	10A0154	Striano Electric Co., Inc. 42-24 235th Street Douglaston NY 11363	Requested approval for the electric service equipment proposed to be installed	Telx 111 8th Avenue New York NY	Approved	\$650.00
50093	10A0155	BGA Engineering, LLC 99 Bauer Drive Oakland NJ 07436	Requested approval for the electric service equipment proposed to be installed	Con Ed-59th St. Steam Station 850 12th Avenue New York NY	Approved	\$650.00
1) Clarify double grounded neutral. 2) Show bus details on single line. 3) Indicate equipment maintained by qualified personnel. Job finalized 6/29/11.						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50094	10A0156	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Ok, but	\$650.00
1) Provide secondary main on 500 KVA transformer-(Exceeds 6 devices). 2) Secondary transformer feeder undersized. 3) Provide information on existing 1200A distribution switchboard downstream of 1200A ATS.						
50095	10A0157	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	XO Communications 111 8th Avenue New York NY	Approved	\$650.00
Neutral bonded in new 1200 amp disconnect switch and all other disconnect switches. Job finalized 6/7/10.						
50096	10A0158	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Telia/DEA Re-Feed 111 8th Avenue New York NY	Approved	\$650.00
50097	10A0159	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Sprint Re-Feed 111 8th Avenue New York NY	Approved	\$650.00
50098	10A0160	Fas Electrical Contractors, Inc. 78-10 67th Drive Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	VBC Industries 156 Sanford Street Brooklyn NY	Hold	\$650.00
1) Provide sequence of operation. 2) Verify transformer configuration Y-Y or delta-Y? Provide manufactured cuts. 3) Have engineer appear at next meeting.						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50099	10A0161	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Tower 111 885 Avenue of the Americas New York NY	Approved	\$650.00
1) Is building residential or commercial? 2) Verify if fire pump is special or limited type. Where is the pump located? 3) Manual fire pump branch circuit is undersized.						
50100	10A0162	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	50-15 Beach Channel Drive Far Rockaway NY	Approved	\$650.00
50101	10A0163	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	188 Ludlow Street New York NY	Approved	\$650.00
50102	10A0164	SMC Electrical Contracting Inc. 641 Lexington Avenue, Suite 1400 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	I.S. 59 132-55 Ridgedale Street Queens NY	Approved	\$650.00
50103	10A0165	M & R Electl Contg and Repair Servs. Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	95 University Place New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 19, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50104	10A0166	Vintage Electric Corp. 4620 Flatlands Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	360 Park Avenue South New York NY	Approved	\$650.00
50105	10A0167	Platinum Electrical Contracting, Inc. 478 Wild Avenue Staten NY 10314	Requested approval for the electric service equipment proposed to be installed	Internap 75 Broad Street New York NY	Hold	\$650.00
1) Physical of GE board not submitted. 2) No ground fault provided on 2000 amp switches. 3) Floor plan not submitted. 4) Are ATS' 3 or 4 pole. 5) Coordination study not provided. 6) 1-Line drawings not complete. 7) No short circuit information provided. 8) Does emergency board feed life safety. 9) No ground fault indication provided.						
50106	10A0168	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Trader Joe's Store 2075 Broadway New York NY	Approved	\$650.00
50107	10A0169	A.T.J. Electrical Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	121st Police Precinct 970 Richmond Avenue Staten Island NY	Hold	\$650.00
1) Bus sizes not provided on 1-line drawing. 2) Fusing in 400 amp service switches to be derated. 3) Generator neutrals to be bonded to enclosure and grounded to building steel, water ground electrode to be grounded to building steel. 4) Fire pump and service switch not shown on drawing. 5) Physical doesn't match 1 line.						
50108	10A0170	WCK Electric Corp. 61 Utica Avenue Brooklyn NY 11213	Requested approval for the electric service equipment proposed to be installed	135 Eastern Parkway Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50109	10A0171	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	161-19 Jamaica Avenue Jamaica NY	Approved	\$650.00
1) Verify that service room is fire rated. 2) Provide conductor size on load side of service Switch #2. 3) Neutral conductor not provided in fire pump service switch. 4) Provide bus size to 1200 amp disconnect switch. Job finalized 6/4/10.						
50110	10A0172	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	HBO 1100 Avenue of the Americas New York NY	Hold	\$650.00
1) Service entrance not shown. 2) Service entrance conductors feeding 4000 amp service switch are undersized. 3) 4000 amp service switch neutral not bonded. 4) Load side of 5000 and 2-400 amp service switches not shown. 6) 1 Line does not match room layout equipment. 7) Physical not provided.						
50111	10A0173	Verde Electric Corp. 1402 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Public Safety Answering Ctr. 1200 Waters Place Bronx NY	Hold	\$650.00
1) Fence enclosure to comply with Section 110.31, and be properly grounded. 2) Conductors outdoors on poles to comply with Section 225.60 and 225.61, verify and add note on drawing. 3) 120/208 and 480/277 transformer secondaries not ground and bonded in 1200 and 4000 amp switches neutral links not provided. 4) 480 volt switches to be ground fault protected. 5) Outdoor equipment to have rear hinged doors. 6) Review transformer design. 7) Provide coordination study.						
50112	10A0174	Amko Electrical Construction & Maint. Inc 32-17 College Point Blvd. Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	101 West End Avenue New York NY	Approved	\$650.00
50113	10A0175	Patriot Electric Corporation 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	2625 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50114	10A0176	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lowes of Staten Island 661 Veterans Road Staten Island NY	Denied	\$650.00
1) Service entrance conductors undersized for 2500 amp frame of service switch. 2) Neutral link not allowed in series with main bonding jumper. 3) Neutral link not provided in 2500 amp service switch. 4) Emergency side fire alarm switch neutral bonded to enclosure. 5) Cut sheets of Square D MGP equipment not provided. 6) No disconnect switch provided on generator.						
50115	10A0177	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Eataly 200 Fifth Avenue New York NY	Approved	\$650.00
50116	10A0178	NJS Electrical Services Corp. 149-17 Cross Island Parkway Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	East River Science Projec 450 West 29th Street New York NY	Approved	\$650.00
50117	10A0179	Switch Electric Co., Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	5900 Arlington Avenue Bronx NY	Approved	\$650.00
50118	10A0180	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Lowe's Kings Plaza 5100 Kings Plaza Brooklyn NY	Hold	\$650.00
1) Provide manufacturers cut sheet of fire pump controller showing how it is listed, service switch feeds direct connect fire pump. 2) Fire pump switch not grounded. 3) Normal side fire alarm switch tapped on line side of C.T. 4) Remove neutral bond in 30 amp fire alarm switch on the emergency side. 5) Equipment grounding conductors undersized for 800 amp fusing. 6) Size on main bonding jumper not provided. 7) Provide generator cut sheet showing switchgear as a listed assembly. 8) Fire alarm ATS room layout is this correct?						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50119	10A0181	Amra Electrical Corp. 47 Buffalo Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	Douglaston Mall 242-02 61st Avenue Douglaston NY	Approved	\$650.00
1) Correct voltage typos. 2) Is equipment rated for outdoors? Job finalized 7/26/10.						
50120	10A0182	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	AT & T 811 10th Avenue New York NY	Approved	\$650.00
50121	10A0183	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	1468 Hoe Avenue Bronx NY	Approved	\$650.00
50122	10A0184	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	t. Washington Ave. a.k.a. 651W.168 New York NY	Approved	\$650.00
50123	10A0185	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	116 East 63rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50124	10A0186	Altman Electric 283 West 11th Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	261 West 28th Street New York NY	Approved	\$650.00
50125	10A0187	Centrum Electric Corp. 12 Lombardy Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1490 Boston Road Bronx NY	Approved	\$650.00
50126	10A0188	Belmont Electrical Inc. 5-12 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	30 West 47th Street New York NY	Approved	\$650.00
50127	10A0189	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	120 Broadway New York Ny	Approved	\$650.00
50128	10A0190	Joseph Garfolo, Licensed Electrician 125 First Avenue New York NY 10003	Requested approval for the electric service equipment proposed to be installed	116 West 32nd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50129	10A0191	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	395 Hudson Street New York NY	Approved	\$650.00
50130	10A0192	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	National September 11 Memorial  New York NY	Hold	\$650.00
1) Clearances behind medium voltage switchgear to comply with Table 110.34(A). 2) Concrete pads behind switchgear do not show clearances between pads and walls. 3) Switchboard rooms to be ventilated. 4) Ground fault protection of equipment not provided. 5) Review not completed, designer and engineer to appear at meeting to explain the job details.						
50131	10A0193	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Mandell School 795 Columbus Avenue New York NY	Approved	\$650.00
50132	10A0194	Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requested Concept Approval for	Mutual of America 320 Park Avenue New York NY	Approved	\$0.00
50133		otroneo & Marinos United Electric Co., In 58-15 Fresh Pond Rd. Maspeth NY 11378	Requesting permission due to past corrosion problems to install rigid non metallic conduit exposed to power five lighting fixtures located in a vaulted area under the side walk.	97 Chambers Street New York NY	Denied	\$0.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50134		Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission to leave as installed due to a hardship to replace AC cable that does not contain an insulated equipment grounding conductor as a wiring method in a place of assembly.		Approved	\$350.00
50135		C.M.S. Electrical Services Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requesting permission to replace a water damaged combination CT/5000 amp service switch with new containing ground fault protection on a 1000 KVA service without filing Advisory Board drawings.	Ford Foundation 320 East 43rd Street New York NY	Approved	\$0.00
50136		W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requesting permission to tap power to supply a fire pump from the load side of a CT located in the same cubicle as a service switch due to Con-ED having to replace the 5-way crab connectors in the street.	Isabella Geriatric Center 525 Audobon Avenue New York NY	Denied	\$0.00
50137		Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requesting permission to leave one means of egress to a 1000 KVA service room and to allow service entrance conductors to be extended by high-pressure connectors to comply with 4/14/2010 Advisory Board comments.	NYU-Tisch School of Arts 111-113 Second Avenue New York NY	Approved	\$0.00
50138		Spice Electric Company Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requesting permission on a 1000 KVA service to replace a portion of a defective bus duct that was directly connected to the load side of a 4000 amp service switch by running 10 sets of 600 MCM copper conductors to a cable tap box to feed the replacement bus duct without filing Advisory Board drawings.	189 Schermerhorn Street Brooklyn NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50139		Samco Electric Corp. 39-08 24th Street Long Island City NY 11101	Requesting permission on a like and kind feeder replacement to fuse 3 sets of 500 MCM copper conductors at 1200 amps and to not provide panic bars on the existing double doors to the service room.	PS 221 K 791 Empire Blvd. Brooklyn NY	Approved	\$350.00
50140		Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requesting permission to replace a defective water damaged service bus duct with new as required in Section 368.119(c) manufactured by Lincoln Electric products on a 1000 KVA service without filing Advisory Board drawings.	32 Avenue of the Americas New York NY	Denied	\$0.00
50141		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to ground two elevator transformer secondary's to concrete encased steel rebar in 2 locations in a building that does not contain building steel	505 West 37th Street New York NY	Denied	\$350.00
50142		G & F.A.ST Electric, Inc. 36-12 23rd Street Long Island City NY 11106	Requesting permission to allow 6'3" headroom instead 6'6" due to an existing structure design above the replacement service.	P.S. 206 61-21 97th Place Rego Park NY	Approved	\$0.00
50143		NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requesting permission to approve a circuit breaker panel with an aluminum back box, cover and internal supports that was specially designed by a listed switchboard manufacturer, tested for use in a MRI/OR but is not listed to UL standards.	1275 York Avenue New York NY	Denied	\$0.00
Awaiting letter from Siemens to send out to board members.						

# ADVISORY BOARD CALENDAR

**May 19, 2010**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50144		Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requesting permission to install listed insulating bushings on conduit ends, drill and tap 1/4" holes into each conduit to fasten mechanical lugs that will be used to terminate equipment grounding conductors to equipment enclosures on a job where it will be devastating to shut down production.	4435 Victory Blvd. Staten Island NY	Denied	\$350.00
50145		Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requesting permission to leave as installed and to allow future 2 family homes for the Spring Creek home project to not group the PLP service switch with other 2 service switches where signage will be provided at the buildings entrance indicating that the PLP service switch is located indoors behind the top meter.	Spring Creek Homes  Brooklyn NY	Approved	\$350.00
50146		A.T.J. Electrical Inc. 122-13 15th Avenue College Point NY 11356	Requesting permission due to lack of space inside of the service room to install a 200 amp service switch in the adjacent room and provide signage at each service location indicating where the other services are located.	Public Shool PS-90X 1116 Sheridan Avenue Bronx NY	Approved	\$0.00
50147	10A0195	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	152 West 26th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 19, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50148	10A0196	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	340 West 40th Street New York NY	Approved	\$650.00