

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0551CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Governors Island BMB Building Slip 7 New York NY	Pending	\$0.00
Carry over from October 22, 2014 meeting. New transformer not properly protected on the primary side; and secondary of transformer not grounded on line drawing.						
53107	14A0568	& D Electrical Construction Company, In 18 West 27th Street, 12th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	626 First Avenue New York NY	Approved	\$650.00
<p>1 Verify that rear covers on switchboard "MDBW" are not removable. 2) Clearance in front of 15 KV switches to comply with Table 110.34(A) and around the equipment in the back. 3) Switchboard MDBW room to be mechanically ventilated. 4) Verify length of transformer secondary conductors. 5) Verify that this is one building with common area access to all service rooms, verify compliance with Article 225 Part 2. 6) Bond at the sync gear instead of individual gen bonding with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/25/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0707	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	PS298Q 50-51 98th Street Queens NY	Pending	\$650.00
<p>1) Section bus undersized for 2-1200 amp switches in "MSB-B" switchboard. 2) Fire pump equipment grounding conductor undersized on load side of service switch. 3) Correct room layout scale. 4) Show conductors to load bank. 5) 3 and 4 pole ATS mixed, verify bonding and grounding of generator, 4 wire systems used.</p>						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53332	15A0044CO	ampbell and Dawes Ltd. Electrical Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	1221 Avenue of the Americas New York NY	Approved	\$0.00
Carry over from March 18, 2015 meeting. Provide EAB calendar number for the existing generator. 11/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53520	15A0046CO	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	50 West Street New York NY	Approved	\$0.00
Carry over from March 18, 2015 meeting. 1) Transformers FA-A & FADs not protected. 2) Confirm that the controllers are limited service controllers. 2/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/5/16 Swapped drawing FP50-01-Revision 3.						
53035	15A0049CO	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	118 East 40th Street New York NY	Approved	\$0.00
<p>Carry over from March 18, 2015 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53104	15A0135	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Alexandria 450 East 29th Street New York NY	Approved	\$650.00
<p>1) Verify which way the generator switch is facing. 2) Incoming fault current not shown. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/25/16 Swapped drawing E-Revision.</p>						
53198	15A0143	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	40 East 52nd Street New York NY	Approved	\$650.00
New feeders are overfused. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53147	15A0150CO	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Magnum Apartment Conversion 140 West Street New York NY	Approved	\$0.00
Carry over from March 18, 2015 meeting. 4/0 fused at 400 amps emergency board. 7/28/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/3/15 Swapped Drawing 4 of 5, Revision 1.						
	15A0188CO	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	3270 Hylan Blvd. Staten Island NY	Pending	\$0.00
Carry over from March 18, 2015 meeting. 1) Clearances of equipment to comply with 230.64(B). 2) Rear of equipment to comply with 230.64(B)(4) or 408.60(F).						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53103	15A0191	Joseph Skarulis Electric 245 Wilson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	Empire Stores 55 Water Street Brooklyn NY	Approved	\$650.00
<p>Service room doors to open outwards with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/23/15 Job finalized. This drawings is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53038	15A0208	Metropolis Electric Corp. 11-36 31st Avenue Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	880 5th Avenue New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/26/16 Swapped drawing 1 and 2-Revision 1.</p>						
53835	15A0214	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	400 West 42nd Street New York NY	Approved	\$650.00
<p>1) S.S. #1, verify that load side bus is over 4' in length, no height of equipment shown. . 2) Fire pump emergency feeder to 50 HP fire pump undersized. 3) S. S. for 75 HP fire pump is undersized. 4) 50 HP fire pump mislabeled as special service fire pump and indicates wrong FLA. 5/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53022	15A0238	Valentis Electric Inc. 32-21 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	113 East 13th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53039	15A0239	Brandl Electric Inc. 250 Greenpoint Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	120 Stuyvesant Place Staten Island NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53021	15A0244	Redline Electric Inc. 1715 East 9th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	7 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0254	Lens Electric, Inc. 2802 Avenue Y Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	40 Irving Place New York NY	Denied	\$650.00
1) Tap of a tap is not permitted. 2) Existing taps off of existing service switch are not protected, dangerous condition, tap rules not followed.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53052	15A0255CO	Brandl Electric Inc. 250 Greenpoint Avenue, 4th Floor Brooklyn NY 11122	Requested approval for the electric service equipment proposed to be installed	110 Wall Street New York NY	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. 1) Drawings do not indicate Revision 1. 2) Verify MI cable installed in conduits. 3) Add note on drawing that all ATS' are 4 pole except fire pumps. 4) Explain how portable generator will connect to 4000 amp disconnect switch. 5) Verify if system is separately derived system or not and indicate bonding accordingly. 6) Provide neutral disconnect to completely isolate the neutral from other sources. 5/28/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/19/16 Swapped Drawing 1-Revision 3 and Drawing 2-Revision 3.</p>						
53144	15A0258CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 530 West 120th Street New York NY	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. 1) Correct voltages on drawings and indicate 3 wire system. 2) Provide sequence of operation. 7/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53143	15A0259CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia University 530 West 120th Street New York NY	Approved	\$0.00
<p>Carry over from April 15, 2015 meeting. Provide sequence of operation of key system. 7/22/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	15A0262	Polaris Electrical Construction Inc. 738 New Lots Avenue Brooklyn NY 11207	Requested approval for the electric service equipment proposed to be installed	117-10 Roosevelt Avenue Queens NY	Rejected	\$650.00
<p>1) 12 pages of drawings submitted, all that is needed are pages 7 and 11 other drawings don't pertain to 1000 KVA service installation. 2) Drawings are not in Advisory Board format. 3) Tapped conductors are undersized. 4) Short circuit study to be provided by a PE bearing the stamp. 5) Bonding and grounding of existing service equipment not shown. 6) Bus bar sizing not shown. 6/23/15 Rejected 1) Bonding and grounding of main switchboard not shown on 1 Line. 2) Verify that tapped conductors are not over 25' in length. 3) Cut sheet of new equipment not provided. 4) Explain 1/0 to ground bar coming out of new equipment that is second fused.</p>						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0263	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	IS 002 333 Midland Avenue Staten Island NY	On Hold	\$650.00
<p>1) Verify bus sizing, cut sheet and 1 Line. 2) Show size of system bonding jumper. 3) Provide vertical bus sizes. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53040	15A0265	Emanon Electric 114-49 Lefferts Blvd. South Ozone Park NY 11420	Requested approval for the electric service equipment proposed to be installed	503-511 Broadway New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	15A0266	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Fordham University 140 West 62nd Street New York NY	Administrative Closure	\$650.00
<p>1) Address on drawing to be 140 West 62nd Street. 2) Neutral in generator is bonded and grounded using 3 pole ATS'. 3) #6 MI cable undersized for fire pump, normal feeder to fire pump not fire rated. 4) Section bus in "MDB" undersized. 5) Verify that line and load are not mixed together on load side of the 1600 amp switch. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. This job is void in lieu of Sub. #15A0587.</p>						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53197	15A0268	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	610 Lexington Avenue New York NY	Approved	\$650.00
<p>4/0 MI cable undersized to FP-2 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/20/15 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/28/15 Swapped drawing 1,2,3-Revision 7.</p>						
53356	15A0269	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Ambulatory Care 1283 York Avenue New York NY	Approved	\$650.00
<p>1) Show concrete encasement of SEC up to service room. 2) Show cut of the splice chambers. 3) Show circuit breaker trip settings on 1 Line. 4) Bus sizing to be on 1 Line drawing not chart. 5) Correct typo on ring bus B-B. 6) Show connection point of snubbers and transformers. 7) Clarify ground points of hold equipment and transformers. 8) Provide ground fault protection of equipment. 8/19/15 Rejected 1) Provide manufacturer's heat rise test report for switchboards. 2) Have coordination study signed and stamped by a P.E. 12/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53120	15A0271	Prince Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	350 West 40th Street New York NY	Approved	\$0.00
<p>1) Tapped conductor off of 800 amp fusing is undersized, length of tap not shown. 2) Show length of transformer secondary conductors for fire pump. 3) Explain open air conductors off of generator, not allowed. 4) Fire pump and fire alarm system transformer voltages mismarked on 1Line. 5) 480 volt 1200 amp switch to be ground fault protected with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/30/15 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53041	15A0275	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requesting permission to install corrosion-resistant jacketed mc cable outdoors underground as per Table 300.5 for amusement park wiring.	3030 Stillwell Avenue Brooklyn NY	Approved	\$0.00
Code: 300.5(A), 330.10(5). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53042	15A0276	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requesting permission to install corrosion-resistant jacketed MC cable outdoors underground as per Table 300.5 for amusement park wiring.	1218 Bowery Street Brooklyn NY	Approved	\$0.00
Code: 300.5(A), 330.10(5). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53142	15A0277	Dooley Electric Co., Inc. 4014 43rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	195 Broadway New York NY	Approved	\$650.00
1) Verify existing 8 sets of 500 KCM feeding 5000 amp service switch #2, or reduce fusing. 2) Existing 5000 amp fuse to new 2000 amp fuse are different fuse types. 3) 600 amp ATS to be 4 pole between 2 points of entry. 7/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53017	15A0278	ECNY Electric 12 West 32nd Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Boys and Girls High School 1700 Fulton Street Brooklyn NY	Approved	\$650.00
OR 5/5/15 Advisory Board approval limited to solar photovoltaic system final connection to utility. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53019	15A0281	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Park Central Hotel 870 7th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53145	15A0282	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Sony 25 Madison Avenue New York NY	Approved	\$650.00
OR 1) Tapped conductors undersized See 240.21(B)(1). 2) Existing 3000 amp switchboard fused at 4000 amps. 7/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53180	15A0284	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NYPL 476 Fifth Avenue New York NY	Approved	\$650.00
1) Correct address on drawings and contractors name. 2) Verify that switchboard will comply with 408.60(F). 3) Secondary of transformer to be bonded and grounded in one location not two. 4) Will the public be walking through the service room to get to the storage rooms? 8/17/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53141	15A0285	Kleinknecht Electric Company, Inc. 252 West 37th Street, Suite 1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Wolfson Con Ed Vault 25 Broadway New York NY	Approved	\$650.00
1) Is 2nd floor vault room new? 2) Equipment grounding conductor to 400 amp service switch undersized. 3) Show lengths of tapped conductors off of 400 amp switch.4) Equipment grounding conductor to 100 amp disconnect switch undersized. 5) Service switches misidentified as #2. 6) What level of the building is the existing service room located on? 7) Provide cut sheet of ceiling tap box 1 A. 7/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53043	15A0286	HYN Consulting Engineers, LLC 150 West 36th Street, 4th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Sears 283 Platinum Avenue Staten Island NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53044	15A0287	GT Electrical Co., Inc. 144-02 Jewel Avenue, 2nd Fl., Ste 4 Flushing NY 11367	Requested approval for the electric service equipment proposed to be installed	360 Central Park West New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53379	15A0288	E D Electrical Inc. 5402 7th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	538 West 58th Street New York NY	Approved	\$650.00
53118	15A0289	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Clolumbia University 530 West 120th Street New York NY	Approved	\$650.00
Submit Siemens equipment cut for sections and cb. 6/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53113	15A0290	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	37-01 138th Street Flushing NY	Approved	\$650.00
7' clearance required in front of service switchboards facing each other. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53112	15A0291	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	774 Grand Street Brooklyn NY	Approved	\$650.00
1) Verify amount of sets of service entrance conductors to 800 and 2000 amp service switches. 2) Tap conductors to 2-600 amp switches undersized 25' tap. 3) Provide coordination study for fuse supplying circuit breaker panel. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0294	Rolf Jensen & Associates P.E. P.C. 360 West 31st Street, Suite 900 New York NY 10001	Requesting permission: 1. Requesting permission to allow the use of seacoast marine type wiring to power the fire alarm system for a floating detention facility. 2) Requesting permission to allow the power for the fire alarm system to be tapped from the 2nd fusing off of the load side of the paralleling switchgear.	1 Halleck Street Bronx NY	Administrative Closure	\$0.00
Code: 90.2(B)(1). Void See Article 90, Section 90.2(B)(1) and Article 553, Section 553.1. Although the scope of this code indicates that the code does not cover installations in ships, portions of this code are incorporated by reference into Title 46, code of Federal Regulations, Parts 110-113.						
53045	15A0295	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to install listed 1000 volt solar photovoltaic equipment on three buildings.	Job addresses in comment section	Approved	\$0.00
201 West 27th Street, Manhattan; 3110 Avenue U/2245 Gerristen Avenue, Brooklyn and 83-30 118th Street-Kew Gardens, NY. With the stipulation that this permission is for the equipment use only and the PV installation is to comply with the 2014 NEC.						
53247	15A0299	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Lexington Hotel 511 Lexington Avenue New York NY	Approved	\$650.00
1) Show circuit current at fire pump controller rated 100,000 AIC. 2) Verify that motorized valve switch is part of the fire pump. 9/14/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53264	15A0300	Dal Electrical Corporation 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	125 Broad Street New York NY	Approved	\$650.00
1) Temporary switchboards installed permanently shall comply with 700.6(G). 2) DLO cables to be dual rated, provide cut sheet. 3) Installation of cable trays to comply with Article 392. 4) Provide drawing of how conductors will be installed in cable trays. 5) Provide cut sheet for cable trays. 6) Verify that temp switchboards are not located in the service room. 10/5/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53036	15A0301	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Gotham Center 42-09 28th Street Long Island City NY	Approved	\$650.00
1) S.S. #6C to be grounded. 2) Provide 2nd set of equipment cut sheets. Job finalized 5/21/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53119	15A0303	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CBS 530 West 57th Street New York NY	Approved	\$650.00
Show coordination between 3000 and 2000 amp fuses in switchboards A and B. 6/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/23/16 Swapped drawing A-Revision 3. 5/18/16 Swapped drawing A-Revision 3, B-Revision 5, C-Revision 5 and D-Revision 3.						
53046	15A0304	Steelcase Inc. 901 44th Street Grand Rapids MI 49508	Requested approval for use in New York City of your Single, 20A Low profile, Multioutlet Assembly and accessories. Model/Series Numbers: Thread, #PFLTRK, PFLTRKINF, PFLCNCTR, PFLHUB, PFLADPTR.		Approved	\$200.00
With listed accessories. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53047	15A0306	ADS Engineers 45 Broadway, Suite 1200, 12th Floor New York NY 10006	Requested approval for the electric service equipment proposed to be installed	170 Central Park West New York NY	Approved	\$350.00
Code: Section 220.43 (B) Exception Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53025	15A0307	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sheraton 811 7th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53059	15A0308	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	90 Lexington Avenue New York NY	Approved	\$650.00
1) Explain 2 electrical services for 2 separate buildings located in one service room, each separate building should have their own point of entry. 2) Verify that 90 Lexington Avenue switchboard is not feeding loads in 88 Lexington Ave building. 3) Indicate which building the meterbanks will be located in. 4) Equipment grounding conductor to MB-1 undersized. 5) Does fire alarm service feed 88 and 90 Lexington Avenue buildings? 6) Service entrance conductors undersized or provide load calculations. 7) Provide site plan indicating the two buildings and relationship between the two. 8) Provide details for 90 Lexington service end box. 5/29/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53058	15A0309	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	88 Lexington Avenue New York NY	Approved	\$650.00
1) Explain 2 electrical services for 2 separate buildings located in one service room, each separate building should have their own point of entry. 2) Verify that 88 Lexington Avenue switchboard is not feeding loads in 90 Lexington Ave building. 4) Which building are the meterbanks located in? 5) Explain fire pump feeding 2 separate buildings. 6) Fire pump service switch not bonded and grounded. 7) Provide site plan. 8) Provide detail for 90 Lexington S.E.B. 5/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53048	15A0311	Call Metro Electrical Assoc, 191 Willow Avenue Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	420 Park Avenue South New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53020	15A0312	& H Electrical Corp. d/b/a Mage Electric 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	360 East 55th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53206	15A0313	Massaro Electric Corp. 105-05 150th Street Queens NY 11435	Requested approval for the electric service equipment proposed to be installed	74-09 37th Avenue Jackson Heights NY	Approved	\$650.00
1) Show clearances in service room. 2) Relocate 60 amp fire alarm service switch. 3) Service entrance conductors to 2000 amp service switch undersized. 4) Fire pump emergency feeder to fire pump not fire rated, undersized. 8/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing 1-Revision 2.						
53101	15A0314	Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	70 West 36th Street New York NY	Approved	\$650.00
Signage for additional service rooms to be posted on each service room door. 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/28/16 Swapped Drawing 1-Revision 2.						
	15A0315	Wank Adams Slavin Associates LLP 740 Broadway New York NY 10003	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital Center 1650 Grand Concourse Bronx NY	Pending	\$650.00
1) Fire pump, what is the distance of transformer secondary tap, overcurrent protection not provided for secondary conductors. 2) "DP-BIA" section and vertical bus undersized. 3) Switchboard "B" bus to service switch 2B is undersized. 4) B-MSBA section bus undersized. 5) S.S. 3c fuses don't coordinate with 200 amp 2nd fuses. 6) MSBA-1600 and 1200 amp fuses do not coordinate.						
53024	15A0316	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Waldorf Astoria 301 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53023	15A0317	Konsker Electric Corp. 32-15 36th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	CUNY School of Public Health West 125th Street, 7th and 8th Floor New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53018	15A0318	ECNY Electric 32 East 31st Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	P.S. K505 5800 20th Avenue Brooklyn NY	Approved	\$650.00
OR 5/5/15 Advisory Board approval limited to solar photovoltaic system final connection to utility. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53598	15A0320	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	522 First Avenue New York NY	Approved	\$650.00
1) Is the switchboard already installed? 2) Verify neutral disconnect links in 30 and 400 amp switches. 3) Coordination study recommendation is not addressed on plan 1-Line. 3/15/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53181	15A0322	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Columbia University 701 West 168th Street New York NY	Approved	\$650.00
1) Drawings to have the 701 West 168th Street address. 2) Switchboards are misidentified. 3) Room layout and 1 Line drawings don't match. 4) Existing feeders to switchboards 2 and 3 are overfused. 5) Switchboards 2 and 3 vertical bus feeding 1200 and 1600 amp disconnect switches undersized. 408.60(B)(5). 6) Provide cuts of replacement switches. 8/17/15 Job finalized. Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53121	15A0323	Sheridan Electric, Ltd. 197 Grand Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	301 East 99th Street New York Ny	Approved	\$650.00
1) Service bus feeding switchboard undersized or provide load calculations 230.4(A)(2). 2) Emergency side 3/0 fused at 225 amps. 3) Verify 150 amp fuse type panel "ODP". 4) Provide section view of service board. 5) Siemen cat and bus sizes must be submitted to verify 1-Line bus sizes. Job finalized. 6/30/15 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53115	15A0324	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	585 8th Avenue New York NY	Approved	\$650.00
1) Fire pump 40 HP is not special service fire pump as per NYC def. Provide correct size s.s. 2) With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53034	15A0325	T. McCaffrey-T. McGovern Electrical Inc. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	136 East 79th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped Drawing 1, Revision 1.						
53033	15A0326	Lazer Electrical Corp. 23-18 31st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	23-25 31st Street Astoria NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53032	15A0327	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	40 West 57th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53031	15A0328	United Electric & Lighting Corp. 200-24 Hollis Avenue New York NY 11412	Requested approval for the electric service equipment proposed to be installed	113 Nassau Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53111	15A0329	Approved Electric Corp. 3550 White Plains Road, Suite 9 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	3556 Webster Avenue Bronx NY	Approved	\$650.00
Verify 3' clearance in front of the Con-Ed service box. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/23/16 Swapped Drawing 1-Revision 2.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0330	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1809 Emmons Avenue Brooklyn NY	Administrative Closure	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/24/15 Cal. #53049, Submission 15A0330 is void in lieu of Cal. #53398, Submission # 15A0810.						
53251	15A0331	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	1 West 64th Street New York NY	Approved	\$650.00
Verify amount of service entrance conductors in service trough. 9/16/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53030	15A0332	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	160 West 62nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53029	15A0333	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	1100 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53116	15A0334	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	245 Bricktown Way, Bldg. "D" Staten Island NY	Approved	\$650.00
1) Is transformer owner or utility owned, overfused. 2) Show fuse types in future disconnect switches or remove switch. 6/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

May 20, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0335	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Bam South Brooklyn 286 Ashland Avenue Brooklyn NY	Pending	\$650.00
<p>Block the back This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53028	15A0337	Foster Electrical Service Inc. 1325 Foster Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	530 Cozine Avenue Brooklyn NY	Approved	\$650.00
OR For final connection of solar photovoltaic system only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53027	15A0338	R.C.M. Electric Corp. 1915 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	West Tower 505 West 37th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53026	15A0339	All Tech Electrical Contractors 817 Broadway, 5th Floor New York NY	Requested approval for the electric service equipment proposed to be installed	113 Nassau Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						