

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55984	19A0016CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from April 24, 2019 meeting. 1) 4000A A4BY SS#1 doesn't coordinate with 2000A A4BY downstream fuse. 2) Physical dwg was not submitted-full size dwg. 2) 4000A A4BY ss#1 doesn't coordinate with 2000A A4BY downstream fuse. 6/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0054	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Show generator grounding with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Confirm that service room is 2HP fire rated. 3) Confirm using ground fault protection not sensing. 4) Provide coordination study signed and sealed by P.E. 5) Provide transformers cuts.</p>				
56109	19A0105	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination study for new OCPDs and up stream breaker. 2) Provide documentation to show NRTL listing to existing & new switch board as one assembly. 11/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55929	19A0129CO	Requesting SP for 3M fire wrapping over emergency feeder for fire rating.	Approved	\$0.00
<p>Carry over from February 20, 2019 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55942	19A0193	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0216	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Confirm number of conductors EM feeder to all ATS 4 wire system? 2) Confirm that generator neutral is bonded and grounded as separately driven system with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Verify AIC rating of "EDPH-2" and provide available s.c. connect. 4) Provide conductor size feeds F.A. switches from trough. 8/6/2020 1)The provision of 240.4(B) shall not be permitted for transformer secondary conductors 2) Xfmr Secondary conductors are undersized as per 240.21(C).</p> <p>3) Confirm listing of 400 A panels.</p> <p>4) Confirm that all new equipment AIC ratings are adequate to the available short circuit current.</p>				
	19A0234CO	Requested approval for the electric service equipment proposed to be installed	On Hold	\$0.00
<p>Carry over from April 24, 2019 meeting. 1) Item #1 is partially addressed-"CB-4" still overfused. 2) Item #4 is partially addressed-existing switches with new fuse still don't have GFP. 3) Physical doesn't match one line for "CHP-B"-dwg 7 of 7. 4) Provide CHP equipment cuts. 5) Confirm submission address-different block and lot than buildings A,B,C & D. 6) Show all relays on the dwg. 7) Show correct grounding to co-gen neutral shall be grounded only once. 8) Verify K8 inter lock on the sequence of operation and not in the drawing.</p>				
55934	19A0238	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/14/2021 Amended Dwgs# A Rev 5, B Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/8/2021 Amended dwgs# A Rev 6, B Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/19/2021 Amended dwgs# A Rev 7, B Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56123	19A0248	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Add barrier on gen set to separate normal and emergency with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Fix typo in MDRH-RLDG-4 for number of 100A's in one line diagram and room layout and also 200A fuses. 3) Fix typo in MDBH-RLDG-4 2000A not s. sw. 4) Fix typo in HDB-4 for 200A fuses not matching one line with room layout. 5) Verify size of FP SW SSFP1 1200A or 1600A(conflict between one line diagram and room layout) (SS#5A). 6) Verify DRL-4 on one line diagram located in electrical service room is it 3rd pt? 7) Provide short circuit and coordination study. 8) Verify grounding and bonding for 400A DS-4C switch and 1200 DS-4B sw. 9) Verification of transformer T-4c on room layout and verify T-4G on one line diagram. 10) Verify size and number of conductors connecting 1200A sw DS-4B (4) 500MCM AL or (4) 600 MCM a cu?? 11) Fix typo in EMDB RLFH-4 # and size of conductors (4) 500 MCM AL or (A) 600 MCM Cu?? 9/6/19 1) Show the location of the generator on the floor plan. 2) Provide correction, as the coordination study related to the generator and "EMBD-BLDG-4" do not match the Dwg. 3) Address the following related to "T-4k-1000KVA" transformer - a. Conductor between "3000 A A4BQ" fuse and transformer is undersized. b. Coordination study does not match rating shown on the Dwg. c. Show short cicuit calculation at all panels. d. Transformer secondary taps are in violation with 240.21. 10/10/2019 1) Provide coordination study signed and sealed for "1600A" breaker at generator to all downstream fuses. 2) Address undersized bus bar in "EMDB-BLDG-4". 3) Comply with 408.36 for "DS-4B and DS-4C" and provide coordination study signed and sealed for the "1200A" A4BQ and all downstream fuses. 4) For DS-4B and DS-4, provide UL 891 listing. 5) Provide ground fault protection for "DS-4B and DS-4" 1200A fuse and "MDBH-BLDG-4" 2000A fuse per 215.10 6) Provide generator "1600A" fuse ground fault protection alarm per 700.26. 11/15/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/7/20 Swap Dwg # C rev. 7 and E rev. 7 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55924	19A0252	Requesting SP to keep existing plumping pipes above electrical equipment.	Approved	\$0.00
<p>with stipulation; Drip pans shall be provided and shall extend 12" minimum beyond the equipment in all directions. Additionally, Leak Detection equipment with audible alarm shall be provided in all drip pans. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55940	19A0253	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56129	19A0272	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Verify distance to top ss# 1 and 2 in accordance with 404.8(A)(6'-7") 10/11/2019 1) Show bonding, grounding & N.D.L to service swbd. 2) Confirm that new swbd is in compliance with 404.8(A). 3) Confirm NRTL of new equipment. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. 1/8/2021 Amended dwg# 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/13/19. 1) Item #2 from last revision is not addressed the measurement has to be taken to the center of the grip of the handle when in its highest position. 11/29/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/2021 Amended plan# A Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55931	19A0276	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/15/2020 Amended Plan # A & B Rev-1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	19A0278	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>OR - 1) Confirm bonding & grounding to existing service switch SS #5 - show them on dwg. 2) Provide available s.c current at new 'WP' panel & confirm NRTL listing. 3) Provide asbestos abatement compliance doc.</p>				
55945	19A0289	Requesting a SP to eliminate a required receptacle outlet under the counter overhang.	Approved	\$350.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56013	19A0295CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>1) Neutral shall be brought fire pump service switches and to be bonded and grounded-dwg E-107-code section 250.24(c). 2) Provide 5' clearance to F.P. service switch. 3) Coordination doesn't match one line-verify 5000A or 4000A breaker in TCC-LTCC01. 4) "ATS-MSBD" shall be sized based on the locked rotor current of fire pump. 5) Show size of the tie breaker in "SWBD-TDS". 7/23/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/23/19 This job superseded job # 14A0424 with C# 52662.</p>				
	19A0297	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/27/2020 1) Undersize conductors to feed two trans "S" 2) Provide coordination study between 700A, 400A fuses sigend & sealed.</p>				
55923	19A0298	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/9/2021 Amended dwgs# A, B & C Rev 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/2/2021 Amended dwgs# A, B & C Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/28/2021 Amended dwgs# A, B & C Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/7/2021 Amended Plan #B & C Rev- 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/16/2021 Amended Plans# A Rev 3, B Rev 3 and C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
	19A0301	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Short circuit protective devices coordination analysis sealed and signed by P.E. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Provide Asbestos Abatement compliance required documents. 3) Verify ATS-SBP tap and reflect how the tap is maid.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55933	19A0303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/19 1) Sectional bus in "MDP" Section #3 is undersized. 7/26/2019 Swap Dwg # 1904-31356A Rev 6 and Dwg # 1904-31356B Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 10/11/19 Swap Dwg # 1904-31356A Rev 7 and Dwg # 1904-31356B Rev 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/27/19 Swap Dwg # A rev.8 and # B rev.7 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. No more swaps.</p>				
56197	19A0304	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) Provide supplemental grounding to existing service. 2) Provide asbestos abatement compliance doc. 11/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
55925	19A0307	Requesting a SP to use 800 amp bus density for paralleling switchgear.	Approved	\$350.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55926	19A0308	Requesting a SP for NYC EC 210.25(B) and permitting connection of common area light to tenants	Approved	\$350.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56002	19A0311	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show new verses existing work - bubble new work. 2) Use smaller profile 800A switch to clear door. 7/2/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/20/19 Swap Dwg # A rev. 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56043	19A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide available short circuit current at new eaton panel boards and provide AIC rating of new service switches. 7/29/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55927	19A0314	Requesting SP to shared equipment on the Small Appliance circuit.	Approved	\$0.00
<p>with stipulation; Share Small Appliance circuits shall be provided with AFCI circuit breakers. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56213	19A0316	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination study signed and sealed by P.E. 2) Provide neutral disconnect link to all service switches. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 8/27/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/25/2021 Amended plans 1, 2, & 3 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56187	19A0317	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Confirm that service elec. Room is 2HR fire rated. 2) Confirm that all recommended settings within coordination study is applied. 3) Confirm that provided ground fault is ground fault protection not just sensing. 4) Confirm compliance with building code 2702.1.2.1 8/22/19 1) Provide siemens cut sheet for OC & SC protection device. 9/24/2019 1) The 6000A and 3000A fuses do not coordinate with upstream breaker 4000A - coordination study shall include clarification. 2) Comply with 408.60E for bus bar sizes is SSB-2. 3) Verify fuses types in coordination study for they do not match EAB one line. 1/28/2020 1) Item # 1 & 3 from last revision are not addressed. 7/15/2020 Amended Dwg #A Rev4 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55964	19A0319	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Confirm coordination between 800A A4BY and downstream 400A A2D-Provide TCC signed and sealed. 6/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	19A0320	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Confirm 1600A Bolt Switch is fused or unfused in 1000KVA transformer and DP-R board (DWG E) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Busbar off 3000A switch in "DP-R" board is undersized-800A/square inch shall be used-408.60(E)(3)-dwg (E). 3) Provide coordinatin study signed and sealed by P..E. 4) Confirm GFP to 1200A switch 750 KAA transformer secondary-and show it in one line dwg #F. 5) Provide all transformers cuts showing NRTL listing.</p>				
56198	19A0321	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide neutral loads to "TDP-22" and "PPL 3". 3) Provide coordination and short circuit study signed and sealed by P.E. 4) Provide cut sheet of all transformers showing the NRTL listing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/21/2020 •Confirm that the incoming service conductors are con Ed conductors and not the customer property. •Confirm 2 HR fire rated service room. •Neutral calculation to be signed and sealed by P.E. •Add the generator OCPDs to the coordination study(1200A CB and downstream CBs). •Confirm that the transformer primary is suitable to the transformer inrush current for SS#3 & 5 transformers: 11/12/2020 Job finalized.Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56047	19A0323	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Provide asbestos abatement compliance required documents 2. Verify mechanical ventilation to electric service room. 3. FA GEC shall be in accordance with 250.66 8/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56010	19A0324	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Sectional service busbar feeds S.SWs #415 & 6 and verticle bus bar feeds S.SW #4 are undersized. 2. Main bonding jumper is undersized - 250.102. 7/12/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/18/19 Swap dwgs 1 and 2-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/4/2020 Swap drawings # 1 & 2 REV2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55997	19A0325	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Existing tap conductors shall be updated with the new main service switch to have ampacity at least 1/3 of main OCPD. 2) Provide cut sheet to new 1200A service switch.. 7/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/18/2020 Amended Dwg # 1 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55993	19A0326	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide documentation for Aelio switchboard is listed. 2) Disable and remove old current transformer. 6/7/2019 1) Cables feeding existing loads are undersized. 6/24/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56007	19A0327	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance doc or control # ACP5 associated with the new work. 7/10/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55930	19A0328	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55920	19A0329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55941	19A0330	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0332	Requesting a SP to allow smaller dedicated work space in front of 1000kVA service equipment.	Denied	\$0.00
1. Roll-up door must be removed and blocked with suitable material to provide 2 hr. fire rating construction. 2. All storage and shelves shall be removed out from the electric service room (parts shelving).				
55943	19A0333	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56116	19A0334	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide coordination between new fuse & upstream existing fuse. 2) Provide UL certificate of vendor will work on bus modification. 3) Provide asbestos abatement compliance doc. 7/11/19 1) Provide 3' clearance in front of new main dist. Swbd. 2) New bus bar that the new tap taken off is undersized - 240.21(B). 11/14/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55998	19A0335	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 5/15/19 1) Provide new fuse type to 7-11 switch. 2) Provide Asbestos abatement compliance document.. 7/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56158	19A0336	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Verify with 450.9 ventilation 1/22/2020 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/8/2020 Amended plans# A1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/6/2020 Amended plans# 1 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55936	19A0337	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	19A0338	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Fire pump "EGC" is undersized-T20.122 to FP-1 and FP-2. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2) Service bus bar feeds service switch #2B is undersized. 3) Draw connection to 3000A service switch in "MSB-B" main distribution board and fix typo for Time Warner service switch. 4) Bus bar feeding 3000A in "MSB-B" distribution board and "MSB-A" board are undersized-800A/Square inch shall be used to bus bar connected to 3000A switch 408.60(E)(3)(a). 5) Provide coordination and short circuit study signed and sealed by P.E. 6) Fix typo to secondary voltage of 1000KVA transformer. 7) Physical doesn't match one line. 8) Provide service bus bar size feeds F.A. and F.Ps service switches. 9) Provide 12" separation F.A. and F.Ps service switches in service room. 10) Comply with 760.D(4).				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
	19A0340	Requesting SP to eliminate the second egress required by NYC EC 230.64.	Denied	\$0.00
Egress from the existing room is non-code compliant.				
55910	19A0343	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56053	19A0344	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Confirm # of sets feeding ser. Sw #2-3 sets or 4 sets. 2) Provide available s.c current at F.P controller. 3) Provide signage in both service rooms existing & new and special permission is required for 2 service room. 7/23/19 1) Provide coordination study for ser. sw. #2 and all downstream fuses signed and sealed by P.E. 8/8/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55944	19A0346	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/8/19 1) Clearly show any changes if any. 2) Provide signed and sealed coordination study for any changed fuses. 2/25/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/6/2020 Swap drawings #: E-350 Rev #2: E101.02 Rev#5; E201.02 Rev#5; E301.02 Rev#7; E401.02 Rev#5 and E501.02 Rev#5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55965	19A0347	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Special permission required to retrofit existing panel. 6/4/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/29/19 Swap Dwg # 16371 rev.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55946	19A0350	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56101	19A0351	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos abatement compliance doc. 9/10/19 1) Confirm that area of new work is included in the provided ACP 21 document. 2) Provide available s.c current at new service swbd "MSB". 10/11/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56065	19A0352	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Service conductor feeds new SS #4 is undersized. 2) Provide asbestos abatement compliance doc. 8/5/19 1) Fix the typo on the physical cut sheet of s.sw #4 for the conductor size on the line side. 8/21/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/19/2020 Swap dwg # Sheet 1-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55921	19A0353	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/8/2020 •Provide coordination study(TCC) between new circuit breaker and upstream fuse signed and sealed by P.E. 10/14/2020 Amended Plan #1 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
56085	19A0354	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance required documents. 8/6/19 1) Verify all 'MTS' has no life safety loads. 9/19/19 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/8/2020 Amended Dwgs # 1 & 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/1/2021 Amended Dwgs # 1 & 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/3/2021 Amended Dwgs # 1 & 2 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
56004	19A0355	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Comply with 705.12(D)(R). 7/2/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/8/2020 Amended dwgs# 1 & 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/25/2021 Amended plans# 1 & 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/16/2021 Amended plans# 1 & 2 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55911	19A0356	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/10/19 Swap Dwg 1 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/25/19 Swap dwg #1-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55994	19A0357	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1. Provide cut sheets of new equipment showing AIC rating and NRTL listing. 2. Confirm transformers are after 2nd level OCPD. 6/26/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55938	19A0358	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55935	19A0359	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55999	19A0360	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 5/15/19 1) Provide coordination between new 1200A KRPC and downstream existing "TR" fuse.. 7/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
56001	19A0361	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1. Confirm 7' clearance between FA service SW & service SW #3 and the scale 6/28/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55937	19A0363	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/12/19 Swap Dwg 1,2 & 3 rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 7/8/2020 Swap drawings # 1, 2 & 3 Rev2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55932	19A0364	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55922	19A0367	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/4/2020 Swap dwg #A041903-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/19/2021 Amended Dwg# 1 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

ADVISORY BOARD CALENDAR

May 22, 2019

Approval #	Submission #	Type of Request	Status	Fee
55928	19A0376	Requesting a SP to utilize NYC EC 725.130(A) and reclassify class II circuits.	Approved	\$350.00

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.