

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47131CO2	06A0218CO2	Danfoss Inc. 7880 Tranmere Drive Toronto ON L5S1L	Requested approval for use in New York City of your Danfoss GX Snow Melting System complete with GX 850. Model/Series Number: GX Series 088L.		Denied	\$0.00
Carry over from May 24, 2006 meeting. 1) There was no barrier provided inside of the wiring compartment separating line and low voltage wiring. 2) The mounting box and the GX850 were not listed as one complete assembly.						
47680CO	07A0063CO	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-West Quad 2900 Bedford Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 14, 2007 meeting.						
47691CO2	07A0073CO2	Fas Electrical Contractors Inc. 90-61 Pitkin Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging 975 Essex Street Brooklyn NY	Approved	\$0.00
Carry over from April 18, 2007 meeting.						
47764CO	07A0136CO	Jay Helfgott Electric Corp. 2970 Fulton Street Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	205 Rockaway Parkway Brooklyn NY	Approved	\$0.00
Carry over from March 14, 2007 meeting.						
47765CO2	07A0137CO2	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Towers at Hutchinson Metro Ctr 1250 Waters Place Bronx NY	Approved	\$0.00
Carry over from April 18, 2007 meeting.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47776CO2	07A0100CO2	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1211 Southern Blvd. Bronx NY	Approved	\$0.00
Carry over April 18, 2007 meeting.						
47781CO2	07A0134CO2	Washington Electric Co., Inc. 140 58th Street, Suite 8F Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	B & H Photo 420 9th Avenue New York NY	Approved	\$0.00
Carry over April 18, 2007 meeting. With the recommendation that an additional equipment grounding conductor should be installed in each feeder conduct and bonded to each enclosure from the service equipment up to the transformers, the sizing to conform with Article 250.122 or a four pole automatic transfer switch be used.						
47782CO	07A0120CO	Paradise Electrical Contractors Inc. 50-24 71st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Condominium Conversion 15 East 26th Street New York NY	Approved	\$0.00
Carry over from March 14, 2007 meeting.						
47808CO	07A0198CO	BRG Electric Inc. 88-26 Winchester Blvd. Queens Village NY 11427	Requested approval for the electric service equipment proposed to be installed	Time Warner 59-81 Paidge Avenue Brooklyn NY	Approved	\$0.00
Carry over from April 18, 2007 meeting. Provide 4-Pole ATS. Job finalized 10/29/07.						
47866CO	07A0190CO	GTS Electrical Corp. 218-14 Northern Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	112-02 15th Avenue College Point NY	Approved	\$0.00
Carry over from April 18, 2007 meeting. 800 amp switches to be changed to 600 or increase sets of 350 one set.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47876	07A0218	Atlantic Electrical Contracting Inc. 206 East 9th Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	5 East 22nd Street New York NY	Approved	\$650.00
47877	07A0216	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	New Yorker Hotel 481 Eighth Avenue New York NY	Hold	\$650.00
Full drawings must be submitted.						
47878	07A0256	Guth DeConzo Consulting Engineers 242 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint PCS 32-50 Hunter Point Avenue Long Island City NY	Approved	\$650.00
47879	07A0263	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	News Corp. 1211 6th Avenue New York NY	Approved	\$650.00
Provide short circuit calculations for new distribution switchboard. Job finalized 12/17/07.						
47880	07A0249	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Evander Child High School 800 East Gun Hill Road Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47881	07A0250	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Public School 245Q 384 Seneca Avenue Brooklyn NY 104	Approved	\$650.00
1) Bus sizing on load side of 3000 amp switch must meet Article 408 (800A/sq in within 4-8"). 2) Show wire size for fac tap. Show fac neutral bonded. 3) Fire pump tap requires neutral bonded to enclosure. Job finalized August 16, 2007.						
47882	07A0253	Mari Electric Contractors Inc. 635 Richmond Road Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	161-171 East 110th Street New York NY	Approved	\$650.00
1) Change 100 amp fuse to 1000 amps in 1200 amp service switch. 2) Correct typo-feeder to meterbank 'c' should have 3 conduits. Job finalized 8/2/07.						
47883	07A0257	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	148 Lafayette Street New York NY	Hold	\$650.00
1) Service room doors to open out with panic hardware. 2) Show details of end box. 3) Show 2nd fusing of 1200 amp service switch. 4) Type of ATS not provided 3 or 4 pole. 5) Does generator feed life safety equipment? 6) Generator and fire pump controller information not provided. 7) Drawing not complete.						
47884	07A0241	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Columbia Univ.-Jerome Greene 538 West 114th Street New York NY	Denied	\$650.00
1) Emergency source not code compliant as per Amendment 695.3( c ). 2) The tap that supplies the main service switch does not comply with 695.3(A)(1). Tap made on through bus between the 3000 and 1200 amp service switches.						
47885	07A0242	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	NYC Office of Emergency Mgmt 930 Flushing Avenue Brooklyn NY	Approved	\$650.00
Provide overcurrent protection at point of connection for port. gen.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47886	07A0259	Gallagher Electrical Contractors 111 John Street, Suite 1020 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	Club H 222 East 34th Street New York NY	Approved	\$650.00
Neutral bonding not permitted in distribution switchboard. Job finalized 8/2/07.						
47887	07A0228	Hugh OKane Electric, Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adam Houses, Bldg. #4 721 Tinton Avenue Bronx, NY	Approved	\$650.00
1) Service room doors to open out with panic hardware. 2) Must have A.B. required clearances. June 12, 2007.						
47888	07A0229	Hugh O kane Electric, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adam Houses, Bldg. #3 720 Westchester Avenue Bronx NY	Approved	\$650.00
1) Service room door to open out with panic hardware. 2) Must have A B required clearances in front of service B equipment. June 12, 2007.						
47889	07A0230	Hugh O kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adam Houses, Bldg. #2 700 Westchester Avenue Bronx NY	Approved	\$650.00
1) Service room door to open out with panic hardware. 2) Service entrance conductors feeding 2000 amp service switch undersized. 3) Neutral in 800 amp service switch not bonded to the enclosure. 4) Switchboard section views wrong. Job finalized June 12, 2007.						
47890	07A0231	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adam Houses, Bldg. #1 745 East 152nd Street Bronx NY	Approved	\$650.00
1) Service room door to open out with panic hardware. 2) Must have A B required clearances in front of service equipment. Job finalized June 11, 2007.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47891	07A0245	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11375	Requested approval for the electric service equipment proposed to be installed	653 11th Avenue New York NY	Approved	\$650.00
47892	07A0246	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Med. College 1305 York Avenue New York NY	Approved	\$650.00
1) Provide updated generator room layout. 2) Confirm loads fed are not legally required emergency configuration GF accordingly. Job finalized August 16, 2007.						
47893	07A0247	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	174 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
47894	07A0248	Elmac Electric, Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	267 5th Avenue New York NY	Approved	\$650.00
47895	07A0251	Shorr Electrical Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's Herald Square 151 West 34th Street New York NY	Approved	\$650.00
480 volt 1200 amp disconnect switch not ground fault protected. Job finalized June 12, 2007.						

# ADVISORY BOARD CALENDAR

May 23, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47896	07A0233	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Plaza Hotel Fifth Avenue @ 59th Street New York NY	Approved	\$650.00
47897	07A0234	Amcor Electrical Contracting Corp. 1610 Richmond Terrace Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Building "D" 2935 Veterans Road West Staten Island NY	Approved	\$650.00
47898	07A0235	Amcor Electrical Contracting Corp. 1610 Richmond Terrace Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Building "B" 2955 Veterans Road West Staten Island NY	Approved	\$0.00
47899	07A0236	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1790 Broadway New York NY	Approved	\$650.00
Provide signage for 2 service rooms.						
47900	07A0237	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	16-20 West 19th Street New York NY	Approved	\$650.00
Increase feeder/tap size to 8"x8" trough must be sized for sum of loads.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47901	07A0219	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	500 4th Avenue Brooklyn NY	Approved	\$650.00
47902	07A0217	A to Z Electrical Maint. & Serv. Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sherry Netherland 781 Fifth Avenue New York NY	Approved	\$650.00
47903	07A0261	Shally Electrical Corp. 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	2801 Emmons Avenue Brooklyn NY	Approved	\$650.00
47904	07A0252	N.J.D. Wiring & Electric, Inc. 55 Huron Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Edward R. Murrow H.S. 1600 Avenue L Brooklyn NY	Approved	\$650.00
Show tap detail of bus in through. Job finalized August 16, 2007.						
47905	07A0254	BLH Electrical Contractors, Inc. 535 Coster Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Jefferson Towers 700 Columbus Avenue New York NY	Approved	\$650.00
1) Show tap detail in trough Al to copper. 2) Verify if trans S is 400 or 800 amp. One does not match electrical closet layout. Job finalized 8/2/07.						



# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47906	07A0255	Aero Electric Corp. 159 Eldridge Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	128 Mott Street New York NY	Approved	\$650.00
1) New 200 amp disconnect switches not shown in service room layout, are they within 10'? 2) Increase bus so there is no tap of a tap. Job finalized 8/28/07.						
47907	07A0260	Proscia Electrical Inc. 141-07 20th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	96 Spring Street 7th & 8th Floors New York NY	Approved	\$650.00
47908	07A0258	Lippolis Electric, Inc. 445 Fifth Avenue Pelham NY 10803	Requested approval for the electric service equipment proposed to be installed	Nat Sherman 12 East 42nd Street New York NY	Approved	\$650.00
1) 800 amp service switch neutral not bonded to enclosure. 2) Provide supplemental ground in new 800 amp service switch. 3) Are the conductors 500 or 600 MCM.? Job finalized June 14, 2007.						
47909	07A0221	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	YWCA 30 Third Avenue Brooklyn NY	Hold	\$650.00
1) Service entrance conductors are undersized. 2) Neutral not bonded to enclosure and supplemental ground not provided in new 800 amp service switch. 3) Provide bus size feeding 800 amp switch. 4) Does 800 amp ATS feed life safety equipment.? 5) LPN fuses should be installed in panel "E". 6) Show what equipment is new and what is existing.						
47910	07A0262	Ideal Electric & HVAC Co., Inc. 235 India Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	1040 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47911	07A0220	Icor Associates, LLC 485E Route 1 South-Suite 320A Iselin NJ 08830	Requested approval for the electric service equipment proposed to be installed	Manhattan Eye, Ear and Throat Hospital 264 East 64th Street New York NY	Approved	\$650.00
47912	07A0232	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adam Houses, Bldg. #7 815 East 152nd Street Bronx NY	Approved	\$650.00
Service room doors to open out with panic hardware. Job finalized 6/8/09.						
47913	07A0226	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue, 5th Floor New York NY	Approved	\$650.00
47914	07A0227	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adams Houses, Bldg. #6 80 Tinton Avenue Bronx NY	Approved	\$650.00
Service room doors to open out with panic hardware. Job finalized June 12, 2007,						
47915	07A0266	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Adams Houses - Bldg.#5 710 Tinton Avenue Bronx NY	Approved	\$650.00
1) Show doors to service room to open out with panic hardware. 2) 2-sets 500 MCM fused at 1600 amps. 3) Sets of conductors are reversed in Disc #5. Job finalized 6/16/09.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47916	07A0222	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	99 Green Street New York NY	Approved	\$650.00
1) Spare switch to be removed. 2) Neutral in 400 amp service switch not bonded to enclosure. Job finalized June 12, 2007.						
47917	07A0223	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	788 Columbus Avenue New York NY	Approved	\$650.00
47918	07A0224	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	37 Wall Street New York NY	Approved	\$650.00
47919	07A0225	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Millennium Tower Residence 30 West Street New York NY	Approved	\$650.00
47920	07A0243	J.L.C. Electrical Contracting 14-45 Broadway Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	219 West 81st Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47921	07A0244	Electrotec of NY Electrical Inc. 119-21 89th Avenue, Suite B Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	150 Clermont Avenue Brooklyn NY	Approved	\$650.00
47922	07A0238	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Time Warner Road Runner 25-20 West BQE Woodside NY	Approved	\$650.00
47923	07A0239	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Fordham University-Walsh Library 441 East Fordham Road Bronx NY	Approved	\$650.00
47924	07A0240	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Clove Lake MRI Bldg Addi 1050 Clove Road Staten Island NY	Approved	\$650.00
47925	07A0264	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	John Jay College 860 11th Avenue New York NY	Approved	\$650.00
400 MCM conductors to be changed to 500 MCM off of 800 amp switches.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47926	:	Cedar Electrical Contractors, Inc. 325 East 41 Street New York NY 10017	Requesting permission to replace service equipment where the service room contains existing piping in the dedicated electrical space.	15 East 91st Street New York NY	Approved	\$0.00
47927	::	ACP Electrical Contracting, Inc. 412 West 48th Street New York NY 10036	Requesting permission to install new perimeter slab lighting in non metallic conduit for a helicopter landing site located in a corrosive area over the Hudson River	VIP Heliport 30th Street and 12th Avenue New York NY	Approved	\$0.00
47928	:::	Maitra Associates, P.C. 450 Seventh Avenue, Suite 2505 New York NY 10123	Requesting permission to install Schedule 40 non metallic conduits outdoor under ground for service entrance conductors, chillers and emergency generator feeders, all non metallic conduits will change over to metallic when entering the building.	Art Leather HS 45-10 Street Elmhurst NY	Approved	\$0.00
47929	::::	Double D Electric Corp. 33 2nd Avenue Brooklyn NY 11215	Requesting permission to install Schedule 80 non metallic underground service entrance conductor conduits that enter the bottom of an open switchboard where the conduits are cut flush to the floor	PETCO Brooklyn 1610 Avenue Y Brooklyn NY	Approved	\$0.00
47930	:::::	Safeway Construction Inc. 90-04 Liberty Avenue Ozone Park NY 11417	Requesting permission due to a corrosive area of Far Rockaway, Queens to install non metallic Schedule 80 overhead service entrance conduits on three-3 family buildings	124, 126 and 128 Beach 31st Street Far Rockaway NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47931	.....	Sage Electrical Contracting, Inc. 651 Willowbrook Rd., Suite 201 Staten Island NY 10314	Requesting permission to install underground Schedule 80 non metallic service entrance conduits with rigid galvanized conduits as stub ups in a building where the service will be located approximately 100 feet away from the end box	400 East 67th Street New York NY	Approved	\$0.00
47932	.....	Dooley Electric Co., Inc. 4014 43rd Avenue Brooklyn NY 11232	Requesting permission to install underground service entrance conductors in non metallic Schedule 40 conduits.	Fordham Univ.-Walsh Library 441 East Fordham Road Bronx NY	Approved	\$0.00
47933	.....	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requesting permission to extend underground service entrance conductors into a building using non metallic Schedule 80 conduits.	Cypress Hills School 2911 Atlantic Avenue Brooklyn NY	Approved	\$0.00
47934	.....	Bloomingdales 1000 Third Avenue New York NY 10022	Requesting permission not to file full Advisory Board drawings to add a 60 amp, 208 volt fire alarm cutout to an existing 1000 KVA service	Bloomingdale's 1000 Third Avenue New York NY	Approved	\$0.00
47935	.....	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting concept approval to add a seventh service switch to an existing service where one of the existing switches powers a fire pump	583 Riverside Drive New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47936	:.....:	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission to install a seventh service switch for a cell site on a 1000 KVA service where one of the existing switches feeds a fire pump. (Cal. #47816)	Sprint Srvice 2025 Seward Avenue Bronx NY	Approved	\$0.00
47937	:.....:	Alom Electric LLC 148 22nd Street Brooklyn NY 11232	Requesting permission to add a seventh service switch to a service where one of the existing switches powers a fire sprinkler pump.	99 Green Street New York NY	Approved	\$0.00
With the stipulation that the spare 100 amp #6 service switch is removed.						
47938	:.....:	Blue Ribbon Electrical Contractors Inc. 500 Smith Street Brooklyn NY 11231	Requesting permission to add a second level over current protection device rated at 150 amps without filing full Advisory Board drawings.	Tiedmann's Residence 550 Park Avenue, Apt 8W New York NY	Approved	\$0.00
47939	:.....:	Smith Electrical Contracting 120 Dobbin Street Brooklyn NY 11413	Requesting permission due to the building having no common areas to leave as installed a 400 amp service switch mounted outside of a commercial building.	10-32 B 20th Street Far Rockaway NY	Approved	\$0.00
47940	:.....:	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requesting permission due to lack of space inside of the service room to install a 400 amp service switch in an adjacent room that will power a special service fire pump.	1790 Broadway New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47941	:.....	Colony Electric Company Inc. 64 West 3rd Street, Lower Level New York NY 10012	Requesting permission to leave as installed secondary protection of a step up 500 KVA transformer on the roof of a 36 story building where the transformer is located in the basement	18 West 48th Street New York NY	Denied	\$350.00
47942	:.....	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to replace a defective 480 volt 4000 amp aluminum bus duct with a new 5000 amp aluminum bus duct, replace 11 sets of defective 700 KCM aluminum conductors with reduced neutrals with 11 sets of 4-700 KCM aluminum conductors with an added 700 KCM equipment grounding conductor and also due to having practically no room on the conduits between the bonding bushings and the concrete floor inside the switchgear to install a bonding strap to leave as originally installed 1/0 bonding jumpers on the 11 sets of conduits on a service rated over 1000 KVA	Park Avenue Plaza 55 East 52nd Street New York NY	Approved	\$0.00
47943	:.....	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as installed a 480 volt 1200 amp disconnect switch without ground fault protection that feeds motor loads on a 1000 KVA service in a building that started being built in 1/2004.	Battery Park City-Site 18B 211 North End Avenue New York NY	Denied	\$0.00
47944	:.....	Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requesting permission to replace an existing defective distribution panel with new on a 1000 KVA service	25 Church Street New York NY	Hold	\$0.00
<p>1) Your request for special permission to replace a defective panel was not clear as to what you intend to do. 2) A one line drawing has to be submitted. 3) Provide the manufacturers cut sheets of the panel showing the short circuit information. 4) Provide the manufacturer's cut sheet of the circuit breakers showing the AICS. 5) Provide picture of the existing panels rating. 6) Show selectivity between the 1st fuse and the second fusing. 7) Your request was not for a one for one replacement.</p>						



# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47945	.....	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission not to install receptacles on non stationary kitchen islands and to not provide ground fault protection on bathroom receptacles installed behind fixed in place flat screen televisions.	55 Wall Street New York NY	Approved	\$0.00
Approved for your first request concerning the kitchen island receptacles. However, your second request not to install ground fault protection for a bathroom receptacle is denied.						
47946	.....	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a Solar photovoltaic system.	Wiener Residence 297 West 4th Street New York NY	Approved	\$0.00
With the stipulation 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47947	.....	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requesting permission for concept approval of a service room layout, particularly the means of egress for service equipment over 1000 KVA.	DHS New Family Intake Ctr 151 E. 151st Street Bronx NY	Approved	\$0.00
With the stipulation that drawings shall be submitted to the Advisory Board for final approval.						
47948	.....	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requesting permission to leave as installed service equipment in a fenced in area outdoors inside of a waterproof enclosure.	PS37R 15 Fairfield Street Staten Island NY	Approved	\$350.00
47949	.....	Cipriani Electric, Inc. 150-16 14th Avenue Whitestone NY 11357	Requesting permission on a row of 7 stores where the last store is upgrading their service, to utilize a branch water pipe as the grounding electrode with a ground rod due to a hardship of running the grounding conductor through six other stores.	12-23 150th Street Whitestone NY	Approved	\$0.00
With the stipulation that two ground rods are installed six feet apart from each other.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47950	..... ::	Hanington Engineering Consultants 501 Fifth Avenue, Suite 1809 New York NY 10017	Requesting permission to install a new feeder for elevators in the corner of an existing elevator shaftway due to the existing conditions of the building making it impractical to install new conduits or the outside of the shaftway.	Empire LLC 37 West 47th Street New York NY	Approved	\$0.00
With the stipulation that Pyrotex MI system 1650 is installed.						
47951	..... ::	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requesting permission to tap power to the fire pump service switch from the through bus between service switches in switchboard A, pick up emergency power to the fire pump from second fusing at switchboard B and to leave a front clearance of 54" for the fire pump.	Columbia Law School 538 West 114th Street New York NY	Denied	\$0.00
47952	..... :::	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requesting permission to allow the use of kirk key interlocks to manually operate a portable generator that will be operated by New York City Office of Emergency Management electricians only. Signage will be provided at the 800 and 3000 amp stating "Fuses may be energized even if the switches is in the open position.	NYC Office of Emerg. Mgmt 930 Flushing Avenue Brooklyn NY	Approved	\$0.00
47953	07A0265	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The (New) Yankee Stadium 1 Yankee Stadium Way Bronx NY	Hold	\$650.00
1) Clarify bus sizes. 2) Provide section views of equipment. 3) ATS must be in separate 2HR fire rated room as per New York City Rule 12-01.						
47954	07A0267	Exhausto, Inc. 1200 Northmeadow Parkway #180 Roswell GA 30076	Requested approval for use in New York City of your Motor Control Panel for 120/1/60 Motors. Model/Serial Numbers: EBC 12 and EBC 14		Hold	\$200.00
1) Provide installation instructions. 2) Explain bonding and ground continuity of metal raceways. 3) Provide barrier or separation between line and low voltage wiring.						

# ADVISORY BOARD CALENDAR

**May 23, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47955	07A0268	Kimball International 1881 W. Seltice Way Post Falls ID 83854	Requested approval for use New York City of your Retrofits Kits. Model/Series Numbers: 10P30EHPA, 10P36EHPA.10P42EHPA, 10P48EHPA, and 10P60EHPA.		Approved	\$200.00
47956	07A0269	Fuel Cell Energy Inc. 3 Great Pasture Road Danbury CT 06813	Requested approval for use in New York City of your Stationary Fuel Cell Power Plant. Model/Series Number: DFC300MA		Approved	\$200.00
47957	07A0270	Phantom Lighting System 607 Durham Drive Houston TX 77007	Requested approval for use in New York City of your Lighting Strips HM, AC, AE, TL, VM & CM. Projectors: SM, RM, FF, TA and NC.		Approved	\$200.00