

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45782CO	04A0306CO	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	77 Park Avenue New York NY	Approved	\$0.00
46236CO2	05A0128CO2	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Intell Management 350 West 42nd Street New York NY	Approved	\$0.00
1) Show fire alarm ATS. 2) In generator panel switch and fuse for fire alarm should be fire alarm cut out. 6/22/05 Job finalized.						
46238CO	05A0130CO	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Surface Hotel 109 Rivington Street New York NY	Approved	\$0.00
46276CO	05A0167CO	Northgate Electric Corporation 225 West 34th Street, Suite 901 New York NY 11746	Requested approval for the electric service equipment proposed to be installed	Parker Jewish Institute 271-11 76th Avenue Queens NY	Approved	\$0.00
46327	05A0182	R.M.T. Electric Corp. 238-19 Braddock Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	41-61 Kissena Boulevard Flushing NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46328	05A0183	CMS Electrical Services Co. Inc. 306 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	555 Madison Avenue New York NY	Approved	\$650.00
46329	05A0184	BLH Electrical Contractor, Inc. 146 East 151st Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	65 West 13th Street New York NY	Approved	\$650.00
46330	05A0185	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	10 N. Moore St. aka 378 Greenwich S New York NY	Approved	\$650.00
46331	05A0186	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	James Weldon Johnson House 1829/1839 Lexington Avenue New York NY	Approved	\$650.00
46332	05A0187	Ackerman Electrical Contracting, Inc. 264 West 35th, 6th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	444 Manhattan Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46333	05A0188	Mazza Electric Corp. 494 Eighth Avenue New York NY 10001	Requested approval for the electric service equipment proposed to be installed	261 5th Avenue-Basement New York NY	Ok, but	\$650.00
Provide Con Ed short circuit amps & impedance.						
46334	05A0189	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Brooklyn Tabernacle 392 Fulton Street Brooklyn NY	Approved	\$650.00
46335	05A0212	Dal Electrical Corporation 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Broadway 110 543 West 110th Street New York NY	Ok, but	\$650.00
1) Provide code compliant bus sizes in switchboard. 2) Show location of point of entry (POE) and service end box.						
46336	05A0213	ATJ Electrical Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	400 Madison Avenue New York NY	Approved	\$650.00
Provide manufacturer's cuts on new 800A						
46337	05A0214	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Ellwell Associates 375 West Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46338	05A0215	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Schaeffer Development 440 Kent Avenue, North Tower Brooklyn NY	Approved	\$650.00
46339	05A0216	Edwards & Zuck, P.C. 315 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Tishman-Speyer 50 Rockefeller Plaza New York NY	Approved	\$650.00
46340	05A0217	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Superior Block Corp. 761 E. 42nd Street Brooklyn NY	Approved	\$650.00
46341	05A0218	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	29 John Street New York NY	Approved	\$650.00
46342	05A0219	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Metropolitan Club 1 East 60th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46343	05A0222	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Home Depot 585 DeKalb Avenue Brooklyn NY	Approved	\$650.00
Provide fire cut out(FCO) on generator for fire alarm. Same for normal source. 6/10/05 finalized.						
46344	05A0223	New Phase Electrical Contractor, Inc. 300 East 149th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	230 Fifth Avenue New York NY	Approved	\$650.00
46345	05A0226	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1095 Avenue of the Americas New York NY	Approved	\$650.00
1) Correct bus duct sizes for switchgear-cb (circuit breaker and switchgear-06). 2) Provide sequence of operation and interlock scheme for generator mains and ties. 3) Verify copper table A and C 1600/2000A. 4) Provide overcurrent protection at portable generator box. 5) Coordination study.						
46346	05A0227	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Carnegie Hall 881 Seventh Avenue New York NY	Approved	\$650.00
46347	05A0229	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 2 Hanson Plaza Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46348	05A0230	Al s Best Electric Co. Inc. 915 Broadway, Suite #607 New York NY 10003	Requested approval for the electric service equipment proposed to be installed	210 11th Avenue New York NY	Hold	\$650.00
Electric service equipment in path of access to telephone equipment room and office not acceptable. Electric service room shall not be used.						
46349	05A0231	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	873 Broadway New York NY	Approved	\$650.00
46350	05A0233	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	726 Broadway New York NY	Hold	\$650.00
Show complete 1-Line of existing service equipment.						
46351	05A0234	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	200 Willoughby Avenue Brooklyn NY	Hold	\$650.00
Carry over from May 25, 2005 meeting. 1) Remove neutral bond downstream of service. 2) Show all bus bar sizes. 3) Show required notes.						
46352	05A0235	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Walton High School 2780 Reservoir Avenue Bronx NY	Hold	\$650.00
1) Switch configuration wrong on 1-line. Switch/fuse reversed. 2) 2000A distribution switchboard not protected by 2500A fuse service switchboard bus not protected. 3) Show all bus bar sizes. 4) Add standard notes.						

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46353	05A0236	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Teacher's Prep High School 1150 East New York Avenue Brooklyn NY	Approved	\$650.00
46354	05A0238	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Wachovia Securities 375 Park Avenue New York NY	Approved	\$650.00
1) Switchboard HB-cover side with non-conductive material for 3'-0" clearance. 2) Provide composite system drawing . 3) Transfer switches shall not serve code required life safety loads. 4) Coordination study.						
46355	05A0239	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Union Plaza Care Center 33-23 Union Street Flushing NY	Approved	\$650.00
46356	05A0174	Axcel Electric Company, Inc. 636 11th Avenue, 10th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	90-04 161st Street Jamaica NY	Approved	\$650.00
1) Provide size of feeder from 400A service switch #2 to trough. 2) Is copper detail provided in existging 200 amp. disconnect switch. 3) Coordinate 400 FL NR with 1200 amp KLLU fuses.						
46357	05A0175	Trince Electric Inc. 330 East 35th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	219 West 81st Street New York NY	Approved	\$650.00
Add additional door on right side of new installation.						

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46358	05A0176	Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	60 East 55th Street New York NY	Hold	\$650.00
Advisory Board format bonding, grounding and fusing.						
46359	05A0177	Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requested approval for the electric service equipment proposed to be installed	Dunkin Donuts Store 476 Second Avenue New York NY	Hold	\$650.00
Not Advisory Board format.						
46360	05A0178	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	170 West 23rd Street New York NY	Approved	\$650.00
46361	05A0179	Paul F. Viviano, Inc. 132-43 41st Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	35 Sutton Place New York NY	Approved	\$650.00
46362	05A0180	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	395 Riverside Drive New York NY	Approved	#Error
Verify service bus length and fusing. 5/26/05 job finalized.						

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46363	05A0181	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	352 Seventh Avenue New York NY	Approved	\$650.00
46364	05A0190	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1805 First Avenue New York NY	Approved	\$650.00
46365	05A0191	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	203 Lafayette Street New York NY	Approved	\$650.00
46366	05A0192	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	63-11 Queens Boulevard Woodside NY	Approved	\$650.00
46367	05A0193	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	32-20 Leverich Street Jackson Heights NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46368	05A0195	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	202 Centre Street New York NY	Approved	\$650.00
46369	05A0196	Millennium Maintenance & E.C., Inc. 57 Orchard Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	2345 Broadway New York NY	Approved	\$650.00
46370	05A0197	McDougall Electric, Inc. 28-11 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	1500 Lexington Avenue New York NY	Approved	\$650.00
46371	05A0198	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	27 West 72nd Street New York NY	Approved	#Error
46372	05A0199	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	1930 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46373	05A0200	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens West Building #6 47-20 Center Blvd. Long Island City NY	Approved	#Error
46374	05A0201	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	100 Maiden Lane New York NY	Approved	\$650.00
46375	05A0202	Angel Electrical Construction Inc. 101 Luquer Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	225 Park Avenue South New York NY	Approved	\$650.00
46376	05A0203	Decora Electric Company, Inc. 135 Lincoln Avenue Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	3-9 Hubert Street New York NY	Approved	\$650.00
46377	05A0204	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	211 Central Park West New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46378	05A0205	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	1600 Broadway New York NY	Approved	\$650.00
1) With the stipulation that the secondary circuit breaker feeding the signs withstand the available short circuit. 2) The circuit breakers settings are coordinated with the 2000 amp fuse.						
46379	05A0206	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	250 West 93rd Street New York NY	Approved	\$650.00
46380	05A0207	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	88 Leonard Street New York NY	Approved	\$650.00
46381	05A0208	Urban Power and Lighting, Inc. 24-42 49th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	377 Greenwich Street New York NY	Approved	\$650.00
46382	05A0209	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	18 Ninth Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46383	05A0210	Gateway Electric Group 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	255 Hudson Street New York NY	Approved	\$650.00
46384	05A0211	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 Lexington Avenue New York NY	Approved	\$650.00
46385	05A0220	T & R Alarm & Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Kingston Psychiatric Center 681 Clarkson Avenue Brooklyn NY	Ok, but	\$650.00
1) Change title block to correct contractor. 2) Verify what ATS in service is for.						
46386	05A0221	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Medical Center Brooklyn NY	Approved	\$650.00
1) Increase bus in remote switchboards to 4-5x 1/4. 2) Mark distribution switches amperage and switch information reversed. 6/23/05 job finalized.						
46387	05A0224	Lizardos Engineering Associates, P.C. 200 Old Country Road Mineola NY 11501	Requested approval for the electric service equipment proposed to be installed	Columbia University-Pupin Hall 410 East 118th Street New York NY	Approved	\$650.00
Existing 1200 amp disconnect switch reversed fuse feeds switch blades.						

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46388	05A0225	Deltex Electrical Contracting, Inc. 1027 McDonald Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	36-08 Review Avenue Long Island City NY	Approved	\$650.00
46389	05A0228	Fried Electric Co., Inc. 250 West 77th Street, Suite 430 New York NY 10024	Requested approval for the electric service equipment proposed to be installed	250 West 77th Street New York NY	Hold	\$650.00
1) Need 2 sets of drawing room layout and 1-line. 2) Not Advisory Board format.						
46390	05A0232	J.H. Electric of New York, Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Time-Life Building 1271 6th Avenue New York NY	Approved	\$650.00
46391	05A0237	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Societe Generale 1221 Avenue of Americas, 7th Floor New York NY	Approved	\$650.00
46392	-	Edwards & Zuck, P.C. 315 Park Avenue South New York NY 10010	Requesting permission to tap emergency power for the fire alarm system from the line side of local generator panel in lieu of tapping the line side of the generators main switch located 17 floors away. The fire alarm system is also backed up by batteries.	50 Rockefeller Plaza New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

May 25, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46393	'	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requesting permission to allow a fron clearance of 57 inches between switchboards C and D on a previously approved 1000 KVA service Cal. #43916	Bronx Criminal Courthouse 231-265 East 161st Street Bronx NY	Approved	\$0.00
46394	"	J.A. Lee Electric, Inc. 20-30 50th Avenue Long Island City NY 11101	Requesting permission to install a seventh service where one of the existing switches powers a fire pump.	T-Mobile Co. Site 552 Seventh Avenue New York NY	Approved	\$0.00
46395	'''	J.A. Lee Electric, Inc. 20-30 50th Avenue Long Island City NY 11101	Requesting permission to install a 7th service switch where one of the existing switches powers a fire pump.	170 West 23rd Street New York NY	Approved	\$0.00
46396	''''	Brandl Electric Inc. 19-26 Mott Avenue Far Rockaway NY 11191	Requesting permission to install a 600 amp service on the outside of a commercial, residential building, utilizing Schedule 80 pvc conduit as the service standpipe wiring method due to the corrosive nature of Far Rockaway, Queens.	1032 Beach 19th Street Far Rockaway NY	Approved	\$0.00
With the stipulation that outdoor type service equipment is installed inside of an enclosed structure.						
46397	''''	Dal Electrical Corporation 5910 11th Avenue Brooklyn NY 11219	Requesting permission to install service entrance conductors in Schedule 80 pvc conduit that will be run below slab between the Con-Ed box and the service room.	Broadway 110 543 West 110th Street New York NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46398	****	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requesting permission not to group together service equipment in a commercial building that does not have a common area.	32 Carlin Street Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other services are located.						
46399	*****	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to leave as installed, service equipment installed in a two family building that is not grouped together due to the building having no common areas.	322 Davis Avenue Staten Island NY	Approved	\$0.00
46400	*****	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 PVC conduit for outdoor services that will be fed underground on 50 two family buildings located in a corrosive area, Rockaway, Queens.	Aquatic Place, Beach Breeze Place Far Rockaway NY	Approved	\$0.00
46401	*****	J.P.E. Electrical Contractor, Inc. 7426 Amboy Road Staten Island NY 10307	Requesting permission not to group together 12 service switches in a commercial building that does not have any common areas.	680 Sharrotts Road Staten Island NY	Denied	\$0.00
Section 230.71(A) permits a maximum of 6 service switches per service. Section 230.72(A) requires that service switches must be grouped together.						
46402	05A0240	Halax Company 23901 Aurora Road Cleveland OH 44146	Requested approval for use in New York City of your Zinc EMT Set Screw Connector-Snap -In Type. Model/Series Numbers: 12005B, 12007B, 92005B, 92007B.		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**May 25, 2005**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46403	05A0241	Zumtobel Staff Lighting Inc. 141 Lanza Avenue Garfield NJ 07026	Requested approval for use in New York City of your Lighting Fixture. Model/Series Numbers: 05395339, 05395342, 05395417, 05395420, 05395336, 05365643, 05365628 and 05395333.		Approved	\$200.00
46404	05A0242	Orion Energy Systems 1204 Pilgrim Rd Plymouth WI 53073	Requested approval for use in New York City of your Lighting Fixture & Retrofit Material. Model/Series Numbers: 8RRK, 8WRRK, 8IN4, AG-12.		Denied	\$200.00
1) No laboratory test report provided. 2) Amendment 410.40(A) requires metallic fixtures to be not less than 20 gauge metal. 3) Model AG-12 must comply with Amendment 410.37.						
46405	05A0243	American Power Conversion Corp. 85 Rangeway Road North Billerica MA 01862	Requested approval for use in New York City of your Uninterruptible Power Supply. Model/Series Numbers: SymmetraMW.		Approved	\$200.00
46406	05A0194	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requested approval for the electric service equipment proposed to be installed	1446 2nd Avenue New York NY	Approved	\$650.00