

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53003	13A0127CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Energy Building FDR 34h Street New York NY	Approved	\$0.00
Carry over from April 17, 2013 meeting. Short circuit study indicates that feeders originating from EMDP are not properly protected. 4/24/15 Job finalized. Short circuit for EMDP provides alarm only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52531	13A0326CO	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	NYC College of Technology 300 Jay Street Brooklyn NY	Approved	\$0.00
Carry over from December 11, 2013 meeting. Fire alarm must comply with 760. 9/17/14 Job finalized.						
52359	13A0636CO2	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	371 Broadway New York Ny	Approved	\$0.00
Carry over from May 7, 2014 meeting.						
	13A0712CO2	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Telx 32 Avenue of the Americas New York NY	On Hold	\$0.00
Carry over from April 9, 2014 meeting. 1) 1 Line and room layout don't match. 2) Someone who knows job to appear at the meeting when new drawings are submitted. 3) Review not complete.						
52300	14A0039CO3	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	605 West 42nd Street New York NY	Approved	\$0.00
1) Drawing K-Tap length to elev low rise not shown and EGC undersized, #2 can't be run in parallel. 2) Drawing N-3/0 fuses at 600 amp. 7/17/14 Job finalized. 5/29/15 Swapped Drawings B-Revision 2, N-Revision 6.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0048CO	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street New York NY	On Hold	\$0.00
Carry over from February 12, 2014 meeting. 1) Since gen is optional standby (702) GFI is required at the board to protect it when energized by alternate source (215.10). 2) Coordination is required at the board since OCPD are over 601 amps. (240.12A). 3) Neutral calculations of required .						
52360	14A0133	Ramdeen s Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to leave as installed direct buried PVC jacketed MC cable as a wiring method for outdoor planting area lighting .	424 Melrose Street Brooklyn NY	Approved	\$350.00
	14A0138	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	42-12 28th Street Long Island City NY	On Hold	\$650.00
1) Service room to be mechanically ventilated. 2) Verify that emergency feeders are not installed in the service room. 3) Add note on 1 line indicating whether 3 or 4 pole ATS are being installed, 60 fire alarm emergency disconnect is bonded. 4) Equipment grounding conductors undersized for mid-zone-FP. 5) MS-B-2 load side bus off of 2500 amp service switch undersized. 6) 750 KVA TRX, 1200A secondary cond. req. GF!. 7) F.P. service ground must be 2/0.						
53065	14A0150	Broadway Electric LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	145 West 44th Street New York NY	Approved	\$650.00
1) Correct voltage statement 277/480. 2) Provide short circuit study and provide circuit breaker sizes. 9/23/14 Rejected 1) Equipment grounding conductors undersized from co-gen units to new panels and capacitor banks. 2) Short circuit study not provided by a P.E. bearing the stamp. 6/2/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52446	14A0152	Amber Lite Electric Corp. 4830 Arthur Kill Rd., Staten Island NY	Requested approval for the electric service equipment proposed to be installed	Compass Residence 1512 Boone Street Bronx NY	Approved	\$650.00
1) Tap conductor undersized to 200 amp disconnect switch.B. 2)Tap conductor undersized to 30 amp disconnect switch.B. 3) FACP feeder overfused. B. 4) Tap conductor undersized to 30 amp disconnect switch c. 6/27/14 Rejected Item #4 not addressed. 7/25/14 Job finalized. 3/24/16 Swapp drawing A-Revision 2; Drawing B-Revision 5; Drawing C-Revision 5 and Drawing E-Revision 5.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52680	14A0171CO	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	20 Waterside Plaza New York NY	Approved	\$0.00
SANDY Carry over from April 9, 2014 meeting. 1) Verify what cable equipment box is for in the service room. 2) Verify size of existing feeders DP6-13B. 9/15/14 Rejected, Item #1 not addressed. 12/18/14 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/28/16 Swapped drawings AB40-1,2 and 3-Revision 3s, SB40-1-Revision 3 and SB40 2 and 3-Revision 2s. 3/18/16 2nd Swapped Drawings AB40-1, Revision 4s; SB40-1, Revision 4s; AB40-2 and 3; Revision 3s.						
52518	14A0172CO	Zwicker Electric Co., Inc. 360 Park AvenueSouth New York NY 10010	Requested approval for the electric service equipment proposed to be installed	40 Waterside Plaza New York NY	Approved	\$0.00
SANDY Carry over from April 9, 2014 meeting. Feeder to DP-2R and DP-1L overfused. 9/15/14 Job finalized. 8/14/15 Rejected. 1) Wiring method not shown size of conduit. 2) Transformer overfused, length of secondary tap not shown. 3) 200 amp switch reversed. 2/16/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/28/16 1) AB40-1 feeder to 75KVA transformer overfused and not shown on AB-2 drawing as per note 5. 1/4/17 Swapped drawings FP1-Revision 2 and Drawing AB1 and 2-Revision 5s.						
52530	14A0198	Crana Electric Inc. 600A East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	509 West 121st Street New York NY	Approved	\$650.00
Change f.p. fuse to be lower than 570A. 9/17/14 Job finalized. 9/10/15 Swapped drawing 1-Revision 2.						
52447	14A0220	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	CVS 300 Park Avenue South New York NY	Approved	\$650.00
1) Verify clearance in front of 800 amp disconnect switch. 2) 800 amp disconnect switch overfused. 7/28/14 Job finalized. 7/2/15 Swapped 1 Line drawing Revision 2.						
	14A0227	Jorob Contracting and Electrical Co. Inc. 1040 Avenue of the Americas Lower Level New York NY 10001	Requested approval for the electric service equipment proposed to be installed	42-15 Crescent Street Long Island City NY	Rejected	\$650.00
1) Service entrance conductors undersized, if utility is feeding service equipment state note it on the drawing. 2) Tap to 400A disconnect switches undersized. 9/25/14 Rejected. Tap conductors to 400 amp disconnect switches are undersized. 3/30/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/16 1) Emergency feeder to fire pump controller to be concrete encased. 2) Provide cut sheet and short circuit current at fire pump controller.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52608	14A0238	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Rego Park Tower 61-35 Junction Blvd. Queens NY	Approved	\$650.00
<p>1) Service switch MDPH-F bus undersized, E drawing. 2) Note normal side fuse size for limited service fire pump, cut sheet of equipment shows all 30 amp breakers. 3) TDP-4N 1 line does not match physical. 4) Provide NRTL listing for generator. 10/30/14 Job finalized With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/28/16 Rejected 1) Show 5' front clearance I front of fire pump s.s #3. 2) Drawing E, Revision 3 was already existing? 3/25/16 Swapped Drawing A-Revision 1; Drawing E-Revision 4 and Drawing F-Revision 1.</p>						
52361	14A0259	Sky 2 Electric 32 East 31st Street, 8th Fl. New York NY 10016	Requesting permission due to the building having no common area to leave the service equipment installed on the exterior of the building.	14 Roswell Avenue Staten Island NY	Approved	\$350.00
52362	14A0261	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon 104 Broad Street New York NY	Approved	\$650.00
OR						
52462	14A0263	Jemco Electrical Contractors, Inc. 271 42nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Queens College-Queens Hall 65-21 Main Street Flushing NY	Approved	\$650.00
OR Provide main in panelboard, ampere rating of panelboard not shown 408.36. 7/15/14 Rejected. Provide main in panelboard, ampere rating of panelboard not shown 408.36. 8/11/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52363	14A0264	Jemco Electrical Contractors, Inc. 271 42nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Queens College-Dining Hall 65-30 Kissena Blvd. Flushing NY	Approved	\$650.00
OR						
52364	14A0266	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	8 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
5/20/16 Swapped drawing 1-Revision 1						
52524	14A0268	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	UN Development 3 UN Plaza New York NY	Approved	\$650.00
OR Bonding, grounding and neutral links not shown in existing switchboard. 7/24/14 Rejected Grounding electrode conductor terminated to equipment ground bus that is not connected to main bonding jumpers 250.24(A)(4) and 200.2(B). 9/16/14 Job finalized.						
52400	14A0269	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Harlem Dream Project 222 East 104th Street New York NY	Approved	\$650.00
9/16/14 Swapped A & B, Rev 1.						
52399	14A0270	C.M. Richey Electrical Contractors, Inc. 347 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	U.C.P. of NYC 80 West End Avenue New York NY	Approved	\$650.00
1) Main bonding jumpers not to have removable link. 2) Grounding electrode conductor to terminate on neutral bus. 6/25/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52365	14A0271	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bloomingdales 1000 3rd Avenue New York NY	Approved	\$650.00
OR						
52965	14A0272	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	199 Water Street New York NY	Approved	\$0.00
SANDY 1) Confirm that trough with disconnect switches in service room complies with 110.26(A)(3), and show length of taps. 2) Retail trough #3 tap conductor undersized. 3) AB 2 of 4 fire pump supply conductors to be fire rated. 4) AB 2 of 4 EGC undersized for emergency feeder to elevator ATS. 5) AB 2 of 4 fire pump supply conductors to be fire rated. 4/7/15 Job finalized, Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 9/23/16 Bus feeding sections 5, undersized drawing AB-1. 12/20/16 Swapped drawings AB50-1-Revision 3, AB50-3-Revision 4, AB50-4-Revision 4;SB40-Revision 1, SB504-Revision 3, SB505-Revision 2.						
52366	14A0273	AKF 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	90 Broad Street New York NY	Approved	\$0.00
SANDY 8/26/15 Swapped drawings AB20-1,2 and 3-Revision 1s.						
52488	14A0274	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	J P Morgan Chase 4 Chase Metrotech Center, 4th Fl. Brooklyn NY	Approved	\$650.00
1.Provide interlock between two board sections. 2) Provide generators enclosures layout and details. 8/27/14 Job finalized.						
52367	14A0276	PowerCon Associates, LLC 29 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	6 East 43rd Street New York NY	Approved	\$650.00
OR						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52368	14A0277	M.C. Electrical NY Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Nightingal Bamford School 20 East 92nd Street New York NY	Approved	\$650.00
OR						
52383	14A0279	Wise Electrical Services 307 West 38th Street, Suite 1501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1 Union Square West New York NY	Approved	\$650.00
Fire pump service and supply conductors undersized. 6/18/14 Job finalized.						
52369	14A0282	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	34-01 38th Avenue Queens NY	Approved	\$650.00
12/17/15 Swapped Drawings A & C-Revision 1s. 3/15/16 Swapped drawings A, Revision 2, B, Revision 1 and C, Revision 2.						
52405	14A0283	RGF Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	60 East 86th Street New York NY	Approved	\$650.00
1) Verify that no emergency feeders are installed in the service room. 2) Fire alarm grounding electrode conductor to be #10 normal side. 3) Remove bond and ground on 30 amp emergency fire alarm switch. 4) Provide 2 copies of drawings with the contractors correct address. 7/15/14 Job finalized.						
	14A0285	Rightway Electrical 1465A Flatbush Avenue Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	218 West 35th Street New York NY	On Hold	\$650.00
1) S.S. #A-neutral not bonded to enclosure service switches grounded on load side of main neutral link. 2) SS #B-Verify bonding and grounding and neutral link, S6, W6 on ground bus. 3) Fire rated enclosures to comply with: A. Have a P.E. or R.A. file a PW1 as ALT 3. B. Special inspection TR1 form to be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. C. The fire proofing to be performed by a certified fire proofing installer. 4) Provide cut sheet of generator with switchboard showing that it is listed as a complete assembly. 5) Con ED end boxes and conduit entries not shown on room layout drawing. 7) Future kitchen panel and feeder to be shown on the drawing if Rightway Electrical is installing the work or omit it from drawing.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52604	14A0286	United Electrical Contracting Corp. 69 Ludlow Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	136-33 37th Avenue Flushing NY	Approved	\$650.00
<p>1) Emergency feeder to DPEM panel overfused. 2) Provide listing report from NRTL for generator w/distribution panel as a complete assembly. 3) Verify service bus size. 4) The fire rated enclosure to comply with: A) A PE or RA must file a pw1 as an ALT 3. B) Have a special inspection agency to sign off on the fire proofing installation. C) The fire proofing to be performed by a certified fire proofing installer. 7/18/14 Rejected Item #2 not addressed. 8/22/14 Rejected. Provide manufacturer's installation instructions for the particular generator being installed. 10/30/14 Job finalized With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
52441	14A0288	alvatore Campisi & Sons Electl Contrs, Inc 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	242 West 36th Street New York NY	Approved	\$650.00
1) Show size of bus in 2000 amp service switch. 2) Provide supplemental ground. 3) Indicate that service is 120/208 at s.s. 7/23/14 Job finalized.						
52456	14A0289	RC3 Electric 631 Bruckner Blvd. Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	234 Skillman Avenue Brooklyn NY	Approved	\$650.00
8/8/14 Job finalized.						
52457	14A0290	& H Electr1 Corp.d/b/a Mage Electl Contr 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	229 West 43rd Street New York NY	Approved	\$650.00
Verify ampere rating of existing panel and bus sizes min 1200A. 8/8/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52370	14A0291	Allcom Electric Corp. 119 East 124th Street New York NY 10035	Requested approval for the electric service equipment proposed to be installed	King & Grove 30 East 30th Street New York NY	Approved	\$650.00
52493	14A0292	Interphase Electrical Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Pier 40 353 West Street New York NY	Approved	\$650.00
<p>1) Transformers secondary grounds to be installed in only 1 location. 2) Bus bars in main switchboard undersized and vertical bus sizes not shown. 3) Bus in 2000 amp generator disconnect switch undersized. 4) Why PVC coated RGS is used on F.P. circuits? 5) F.A. ATS shall not be marked as normal and emergency sources. 8/28/14 Job finalized. 10/27/16 Swapped drawing 1-Revision 2 and Drawing 2-Revision 3.</p>						
52371	14A0294	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Zuma Restaurant 261 Madison Avenue New York NY	Approved	\$650.00
OR						
52438	14A0295	Faithful Electric Inc. 300 Grand Street, Store D New York NY 10002	Requested approval for the electric service equipment proposed to be installed	28 Varick Avenue Brooklyn NY	Approved	\$650.00
<p>1600 amp panelboard fused at 2500 main OCPD required 408.36. 7/18/14 Job finalized.</p>						
52372	14A0296	Rigid Electric Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	246 Greene Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52373	14A0297	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	Shopping Center 220-34 Hillside Avenue Queens NY	Approved	\$650.00
OR						
52437	14A0298	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Livonia Commons Site 3 494 Georgia Avenue Brooklyn NY	Approved	\$650.00
52380	14A0299	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Livonia Commons Site 2 494 Sheffield Avenue Brooklyn NY	Approved	\$650.00
52894	14A0300	CRM Electric Corporation 461 West 261st Street Bronx NY 10471	Requested approval for the electric service equipment proposed to be installed	Morris Court Apartments 250 East 144th Street Bronx NY	Approved	\$650.00
Provide load calculation for meter banks. 3/26/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
52374	14A0301	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	729 7th Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52375	14A0302	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	300 Schermerhorn Street Brooklyn NY	Approved	\$650.00
52376	14A0303	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	585 8th Avenue New York NY	Approved	\$650.00
	14A0304	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	855 6th Avenue New York NY	Pending	\$650.00
<p>1) Service entrance conductors undersized, what type conductors are being installed. 2) Provide manufacturer's cut sheet for generator w/panelboard showing listing by a NRTL. 3) Show type of ATS being installed, Verify neutrals to ATS and disconnect switches, type. 4) Show grounding for normal and emergency systems. A) PE or RA must a PW1 as ALT 3. B) Special inspection TCI for to be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. C) Fire proofing to be performed by a certified fire proofing installer.</p>						
52487	14A0306	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	43-08 Crescent Street Long Island City NY	Approved	\$650.00
<p>Show coordination between 800 amp service switch and meter bank circuit breakers. 8/26/14 Job finalized. 3/30/15 Swapped Drawings 1,2, and 3-Revision 2s. 12/18/15 Swapped drawings 1,2,3-Revision 3s.</p>						
52494	14A0307	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	135 West 45th Street New York NY	Approved	\$650.00
<p>1) Indicate emergency distribution ATS's and gen on single. 2) If emergency room is new, comply with RCNY 12-01. 8/26/14 Job finalized.</p>						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52402	14A0308	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Lenox Hill Hospital 100 East 77th Street New York NY	Approved	\$650.00
1) Future roll up generator to comply with 700.6F. 2) Will feeders be installed for future generator? 3) Provide 2nd copy of generator cut sheets. 4) note types of ATS being installed. 5) Show grounding scheme of normal and emergency systems. 6) Provide sequence of operation. 7) Note now bus duct will be run between 9th and 11th floors. 6/27/14 Job finalized.						
52403	14A0309	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requested approval for the electric service equipment proposed to be installed	700 8th Avenue New York NY	Approved	\$650.00
OR 1) Verify bus sizes in existing service switch. 2) Tap conductors to 400 amp disconnect switches undersized. 7/15/14 Job finalized.						
	14A0310	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bayard Rustin H.S. 351 West 18th Street New York NY	On Hold	\$650.00
1) Verify more than 6 service switches installed. 2) Bonding and grounding of service switches not shown.						
52377	14A0311	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	We Work Suite 25 Broadway New York NY	Approved	\$650.00
OR						
53016	14A0312	Shenoy Engineering 39 US Highway 46E, Suite 802 Pine Brook NJ 07058	Requested approval for the electric service equipment proposed to be installed	J.H.S. 324 800 Gates Avenue Brooklyn NY	Approved	\$650.00
1) 3' clearance required in front of new equipment behind switchboard. 2) Provide cut sheet of DP-1. 3) Supplemental ground not provided. 5/1/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52451	14A0313	Recon Electric 79 Alexander Avenue, Suite 52-A Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	10 Bond Street New York NY	Approved	\$650.00
1) Verify that Con ED box and service entrance conductors are installed in a fire rated room. 2) Show size of main bonding jumper. 7/31/14 Job finalized,.						
52455	14A0314	Recon Electric 79 Alexander Avenue, Suite 52-A Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	500 West 21st Street New York NY	Approved	\$650.00
1) Verify length of taps to 2-200 amp disconnect switches and compliance with 110.26(A)(3). 2) Garage switch does not coordinate with 800A upstream s.s. 8/8/14 Job finalized. 3/17/16 Swapped drawing 3, Revision 1. 3/28/16 Swapped drawing 3-Revision 2. 5/13/16 Submitted revision for swap drawings but too many changes too soon require new submittal.						
52453	14A0316	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	41-43 21st Street Queens NY	Approved	\$650.00
1) Fire pump s.s. is oversized. 2) Clarify location of F.P. ATS and fire pump. 7/31/14 Job finalized. 8/24/15 Rejected. 1. 2-sets of 3/0 fused at 800 amps. 10/6/15 Rejected. 1) Verify that 800 amp ATS is listed to accept 4 sets of 3/0 conductors on the load side, documentation from manufacturer required. 2) Verify 30" width of working space in front of meter. 11/24/15 Rejected. Item #2 not addressed. See 110.26(A)(2). 2/18/16 Swapped Drawing 1, Revision 3; Drawing 2, Revision 0 and Drawing 3, Revision 4. 5/25/16 Swapped drawing 1-Revision 4, Drawing 2-Revision 1 and Drawing 3-Revision 5.						
52378	14A0319	Walsh Electrical Contracting Inc. 76 Midland Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	745 5th Avenue New York NY	Approved	\$650.00
52454	14A0320	QNCC Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	17 Battery Place New York NY	Approved	\$0.00
SANDY 1) Cellar service room to have mechanical ventilation. 2) Section bus feeding 2-1200 amp disconnect switches undersized in switchboards DS-1N, DS-2N. 3) 1 Line does not match physical for switchboard DS-3N-2. 4) Section bus feeding 2-1200 and 1-600 amp switches undersized in switchboard DS-1S. 5) Verify that service switchboard comply with 230.64(B)(4) or 408.60(F). 6) Verify the number of sets of conductors and sizes in the split panelboards. 7) 4000 amp A4BQ to 4000 amp A4BQ don't coordinate. 8) Provide short circuit curve for note on "B" drawing. 7/22/14 Rejected. Item #5 not addressed on Drawing "A". 8/8/14 Job finalized.						

# ADVISORY BOARD CALENDAR

**June 11, 2014**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52443	14A0321	New York Empire Electrical Contracting Serv 1236 Jerome Avenue Bronx NY 10460	Requested approval for the electric service equipment proposed to be installed	1350 Broadway New York NY	Approved	\$650.00
1) Show available short circuit current from utility. 2) Verify that rear of free standing 2000 amp switchboard complies with 408.60(F). 3) Provide time current curves for 4000A service switch to new 2000 amp disconnect switch. 7/23/14 Job finalized.						
52609	14A0322	Primiano Electric Co. 600 Third Avenue, 2nd Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Whole Foods Market 1551 3rd Avenue New York NY	Approved	\$650.00
1) Temp connection for portable generator to comply with Section 700.6(F). 2) Provide locking between temp gen OCPD and 2000A. 11/5/14 Job finalized.						
	14A0323	Enertiv, Inc. 353 West 39th St., 3rd Fl. New York NY 10018	Requesting approval for use in New York City of your Energy Metering Equipment. Model/Series Numbers: E2i(Enertiv Two Internal)		On Hold	\$200.00
1) Product specific installation instructions(classified). 2) Sensing coils are "unlisted equipment". 3) Company representative to appear at nex meeting to explain.						
52379	14A0326	New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission to install feeders for elevator room panels inside of the elevator shaftway where the panels will be dedicated for wiring for the elevators only. The elevator motors have separate feeders.	345 East 153rd Street Bronx NY	Approved	\$0.00
52382	14A0331	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	11 East 31st Street New York NY	Approved	\$650.00
Provide fuse sizes and types(ss #2 and 3). 6/18/14 Job finalized.						