

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

BOARD MEMBERS PRESENT: BUNK, CANGEMI, CATALANO, COLUCCIO, GIMBUT, GOTFRIED, LORENZ, MARCOVICI, MAZZEO, MILLER, MUNOZ, PACE, PANARIELLO, PESCATORE, PETROU, XANTHOS, CHAIRMAN ZEC AND DIRECTOR MINTZ.

- | | | |
|---|-----------------|--|
| 44038 Community Electric Inc.
124 Granite Avenue
Staten Island, NY 10303 | Hold | Sub. #02A0358 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | FDNY/Training Academy
Randall's Island
New York, NY |
| 44039 Irwol Electric Corp.
57-12 58 th Drive
Maspeth, NY 11378 | Approved | Sub. #02A0359 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | 222 East 3 rd Street
New York, NY |
| 44040 Louis Correa, Licensed Electrical Contractor
718 East 180 th Street
Bronx, NY 10457 | Approved | Sub. #02A0360 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | 250 East 30 th Street
New York, NY |
| 44041 Adco Electrical Corporation
380 Chelsea Road
Staten Island, NY 10314 | Approved | Sub. #02A0361 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | FedEX Ground Facility
300 Maspeth Avenue
Brooklyn, NY |
| 44042 Aligned Energy Concepts, Inc.
4 White Birch Drive
Englishtown, NJ 07726 | Approved | Sub. #02A0369 |
| Requested concept approval for the electric service equipment proposed to be installed in the building located at: | | The NY Botanical Garden
Site Utilities Infrastructure Project
200 Street & Kazimiroff Boulevard
Bronx, NY |
| 44043 Nead Electric, Inc.
500 5 th Avenue, Suite B15
New York, NY 10110 | Hold | Sub. #02A0370 |
| Requested approval for the electric | | Department of Sanitation |

service equipment proposed to be installed in the building at:

52-35 58th Street
Queens, NY

-1-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44044 Spieler & Ricca Electrical Co., Inc.
52-09 Van Dam Street
Long Island City, NY 11101

Approved

Sub. #02A0371

Requested approval for the electric service equipment proposed to be installed in the building located at:

17 Battery Place
New York, NY

44045 Zwicker Electric Co., Inc.
200 Park Avenue South
New York, NY 10003

Approved

Sub. #02A0373

Requested approval for the electric service equipment proposed to be installed in the building located at:

9 MetroTech Center South
Brooklyn, NY

44046 Adco Electrical Corporation
380 Chelsea Road
Staten Island, NY 10314

Approved

Sub. #02A0395

Requested approval for the electric service equipment proposed to be installed in the building located at:

The Worth Building
65-77 Worth Street
New York, NY

44047 Jordan Daniels Electrical Contractors, Inc.
214 West 29th Street, Suite 2E
New York, NY 10001

Approved

Sub. #02A0374

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sprint
60 Hudson Street
New York, NY

44048 Altieri Sebor Wieber LLC
31 Knight Street
Norwalk, CT 06851

Approved

Sub. #02A0375

Requested approval for the electric service equipment proposed to be installed in the building located at:

The Museum of Modern Art
11 West 53rd Street
New York, NY

44049 Virginia Lighting Fixtures, Inc.
271 67th Street
Brooklyn, NY 11220

Hold

Sub. #02A0377

Requested approval for the electric service equipment proposed to be installed in the building located at:

100 Centre Street
New York, NY

-2-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44050 T & R Alarm & Electrical Systems, Inc.
1870 Webster Avenue
Bronx, NY 10457

Hold

Sub. #02A0378

Requested approval for the electric service equipment proposed to be installed in the building located at:

Queens House of Detention
Queens Blvd. & 82nd Avenue
Queens, NY

44051 Zwicker Electric Co., Inc.
200 Park Avenue South
New York, NY 10003

Approved

Sub. #02A0379

Requested approval for **emergency generator** equipment proposed to be installed in the building located at:

AOL Timer Warner
10 Columbus Circle
New York, NY

44052 Levis Electrical Contractors Corp.
28-17 31st Street
Long Island City, NY 11102

Approved

Sub. #02A0396

Requested approval for the electric service equipment proposed to be installed in the building located at:

711 West End Avenue
New York, NY

44053 A.S.R. Electrical Contracting, Inc.
177-04 93rd Avenue
Jamaica, NY 11433

Approved

Sub. #02A0397

Requested approval for the electric service equipment proposed to be installed in the building located at:

NY Hall of Science
47-01 111th Street
Corona, NY

44054 Capsys Corp.
155 3rd Street
Brooklyn, NY 11231

Approved

Sub. #02A0351

Requested approval for the electric service equipment proposed to be installed in the building located at:

Modular Bldgs-Bay View Homes (46)
Beach 102nd St. and Beach Channel Dr.
Queens, NY

44055 Hub Electric Inc.
247 West 38th Street
New York, NY 10018

Approved

Sub. #02A0352

Requested approval for the electric service equipment proposed to be installed in the building located at:

32 Union Square East
New York, NY

-3-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44056 Dal Electrical Corporation
5910 11th Avenue
New York, NY 11219

Approved

Sub. #02A0353

Requested approval for the electric service equipment proposed to be installed in the building located at:

King World
555 West 57th Street
New York, NY

44057 Jusler Electrical Corp.
2616 Skillman Avenue
Long Island City, NY 11101

Approved

Sub. #02A0350

Requested approval for the electric service equipment proposed to be installed in the building located at:

Audubon III
1130 St. Nicholas Avenue
New York, NY

44058 Clough, Harbour & Associates LLP
111 Winners Circle-P.O. Box 5269
Albany, NY 12205-0269

Approved

Sub. #02A0380

Requested approval for the electric service equipment proposed to be installed in the building located at:

2000 East Gun Hill Road
Bronx, NY

44059 Unity Electric Co., Inc.
65-45 Fresh Meadow Lane
Flushing, NY 11365

Approved

Sub. #02A0381

Requested approval for the electric service equipment proposed to be installed in the building located at:

Atlantic Telecom
470 Vanderbilt Avenue
Brooklyn, NY

44060 Platinum Electrical Service, Inc.
588 Broadway, Suite 203
New York, NY 10012 **Approved** Sub. #02A0382

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

Crate & Barrel
611 Broadway
New York, NY

44061 Forest Electric Corp. Sub. #02A0383

Two Penn Plaza
New York, NY 10121 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

499 Theatre Shubert Organization
424 West 42nd Street
New York, NY

-4-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44062 King Electric Corp. Sub. #02A0384
11-50 129th Street
College Point, NY 11356 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

Lincoln Towers
180 West End Avenue
New York, NY

44063 Hugh O'Kane Electric Co., LLC Sub. #02A0385
30-40 48th Avenue-2nd Floor
Long Island City, NY 11101 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

HBO/AOL
1100 6th Avenue
New York, NY

44064 E. Fitzgerald Electric Co., Inc. Sub. #02A0386
98-16 Rockaway Beach Blvd.
Rockaway Park, NY 11693 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

41 Union Square
New York, NY

44065 Unity Electric Co., Inc. Sub. #02A0387
65-45 Fresh Meadow Lane
Flushing, NY 11365 **Approved**

Requested approval for **emergency generator** equipment proposed to be installed in the building located at:

CIBC
417 5th Avenue
New York, NY

44066 Atlas-Acon Electric Service Corp.
283 Hudson Street
New York, NY 10013

Sub. #02A0388

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

630 5th Avenue
New York, NY

44067 Mechanical Construction Systems Inc.
d/b/a Laurelton Electric
230-04 S. Conduit Avenue
Laurelton, NY 11413

Sub. #02A0389

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

Fisk Building
250 West 57th Street
New York, NY

-5-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44068 All Electric Service Corp.
1751 Stillwell Avenue
Brooklyn, NY 11223

Sub. #02A0390

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

3600 Jerome Avenue
Bronx, NY

44069 Matros Automated Electrical Construction Corp.
214 West 29th Street
New York, NY 10001

Sub. #02A0391

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

Manhattan Mini Storage
220 South Street
New York, NY

44070 Gilston Electrical Maintenance Corp.
453 E. 175th Street
Bronx, NY 10457

Sub. #02A0392

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

2432 Grand Concourse
Bronx, NY

44071 Gallagher Electrical Contractors, Inc. Sub. #02A0393
116 John Street-Suite 212
New York, NY 10038 **Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

44 Wall Street
New York, NY

44072 Citi-Wide Electric Sub. #02A0394
1702 8th Avenue
Brooklyn, NY 11215 **Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

62-01 15th Avenue
Brooklyn, NY

44073 Laser Lite Electrical, Inc.
40 Gaton Street
Staten Island, NY 10309 **Approved**

Requesting permission to leave as installed separate disconnect means for a two family house with separate occupancies with no common area, in a building located at:

12 Wright Street
Staten Island, NY

-6-

ADVISORY BOARD CALENDAR JUNE 12, 2002

44074 CT Electric Inc.
488 Smith Street
Brooklyn, NY 11231 **Approved**

Requesting permission to leave as installed separate disconnect means for a two family house with separate occupancies with no common area, in a building located at:

106 Sylvia Street
Staten Island, NY

44075 CT Electric Inc.
488 Smith Street
Brooklyn, NY 11231 **Approved**

Requesting permission to leave as installed separate disconnect means for a two family house with separate occupancies with no common area, in a building located at:

108 Sylvia Street
Staten Island, NY

44076 Atlas Electric Contractors, Inc.
87-12 113th Street
Richmond Hill, NY 11418 **Approved**

Requesting permission to leave as installed separate disconnect means for two family houses with separate occupancies with no common area, in ten buildings located at:

141, 143, 145, 147, 149, 151, 153, 155, 157 and 159 Hopkinson Ave. Brooklyn, NY

44077 Atlas Electric Contractors, Inc.
87-12 113th Street
Richmond Hill, NY 11418

Approved

Requesting permission to leave as installed separate disconnect means for two family houses with separate occupancies with no common area, in eleven buildings located at:

217, 219, 221, 223, 225, 233, 235, 237, 239, 241 and 243 McDougal St. Brooklyn, NY

44078 B & R Electrical Contracting Inc.
4320 Arthur Kill Road
Staten Island, NY 10309-1317

Approved

Requesting permission to leave as installed separate disconnect means for two family houses with separate occupancies with no common area, in two buildings located at:

245 and 247 Livingston Avenue
Staten Island, NY

44079 Laser Lite Electrical, Inc.
40 Gaton Street
Staten Island, NY 10309

Approved

Requesting permission to leave as installed, separate disconnect means for two family houses with separate occupancies with no common area, in two buildings located at:

10 and 20 Noah Court
Staten Island, NY

-7-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44080 Atlas Electric Contractors, Inc.
87-12 113th Street
Richmond Hill, NY 11418

Approved

Requesting permission to leave as installed, separate disconnect means for two family houses with separate occupancies with no common area, in nine buildings located at:

276, 278, 280, 282, 307, 309, 311, 313 and 316 Sumpter St. Brooklyn, NY

44081 Atlas Electric Contractors, Inc.
87-12 113th Street
Richmond Hill, NY 11418

Approved

Requesting permission to leave as installed, separate disconnect means for a two family house with separate occupancies with no common area, in a building located at:

110 Rockaway Avenue
Brooklyn, NY

44082 Hugh O’Kane Electric Co., LLC
30-40 48th Avenue-2nd Floor
Long Island City, NY 11101 **Approved**

Requesting permission to waive the requirement for concrete encasement around the service conductors within the service room, for four services, with feeder lengths of 13’ 10” to 14’ 10”, where feeders will be encased in concrete from the end-line box to the service room, as per submitted specifications and drawings, in a building located at:

Bronx Criminal Courthouse
231-265 East 161st Street
Bronx, NY

44083 Metro York Electrical, Inc.
22-50 46th Street
Astoria, NY 11105 **Approved**

Requesting permission to leave as installed service equipment in a driveway to the basement area, not used as a parking garage, and protected by an 8” curb, as per submitted specification and photos, in a building located at:

147 West 83rd Street
New York, NY

44084 Gessin Electrical Contractors, Inc.
791 East 139 Street
Bronx, NY 10454 **Approved**

Requesting permission to leave as installed feeders not encased in concrete that are 15 feet from the service end box to the service switchboard, consisting of two 600 amp switches and one 200 amp switch, as per submitted specifications and sketch, in a building located at:

1514 Unionport Road
Bronx, NY

-8-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44085 Arco Electrical Construction Corp.
104-22 100th Street
Ozone Park, NY 11417

Requesting permission to leave as installed elevator motor drives with no visible disconnecting means, where the following are being proposed:

1. For low rise elevators (floors 1-15): lockable switches on the 16th floor elevator machine rooms to control shunt circuit breakers supplying current to each motor drive. **Approved**

2. For high rise elevators: a 30 amp 250 volt safety disconnect switch to disconnect the control circuit wiring.
As per submitted specifications and sketch, in a building located at: **Hold**

Municipal Building
1 Centre Street
New York, NY

44086 Caruso & Sons Electrical Contracting Inc.
1489 Blondell Avenue
Bronx, NY 10461-2640 **Approved**

Requesting permission to leave as installed a 4' threadless rigid steel connection presently attached to the incoming conduit with the installation of an electrical ground clamp on the rigid conduit below the fitting and a bond wire to the enclosure, as per submitted specifications and sketch, in a building located at:

Checkers
344 Baychester Avenue
Bronx, NY

44087 Barton Associates, Inc.
221 West Philadelphia Street
York, PA 17404 **Approved**

Requesting permission to connect definite purpose receptacles installed in the building to 20 amp circuits, in a building located at:

JC Penney
Queens Center Mall
59 Avenue and 94th Street
Queens, NY

44088 SPI Systems Ltd.
41 Steelcase Road West
Markham, Ontario L3R 2M4 **Approved**

Requesting permission to install Advisory Board approved (Cal. #39581) low voltage (0-24V) override switches using Class 2 cable, as per submitted specifications, to be installed:

Citywide

-9-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44089 Primiano Electric Co.
237 West 60th Street
New York, NY 10023 **Approved**

Requesting permission to utilize an existing 1200 amp service switch in an elevator location, with the installation of a platform with a 3' minimum clearance and ship ladder dedicated for access to the service switch, as per submitted sketches,

8923 Bay Parkway

44090 building located in a at:
Delco Electrical Corp.
1512 86th Street
Brooklyn, NY 11228

Brooklyn, NY

Approved

Requesting permission to use PVC Schedule 80 conduit for standpipes, in the Rockaway area, due to salt air environment, as per submitted specifications and proposed grounding sketch, in a building complex located at:

Beach Channel Dr. and Beach 102nd St.
Rockaway, Queens

44091 Lawless & Mangione Architects & Engineers, LLP
480 North Broadway
Yonkers, NY 10701-1945

Denied

Requesting permission for a general approval of the existing multiple services and proposed service upgrade for a high rise multifamily building, as per submitted one-line diagram and layout plan, located at:

N.Y.C.H.A. Castle Hill Houses
Building #4
635 Castle Hill Avenue
Bronx, NY

44092 Barth-Gross Electric Co., Inc.
110 West 26th Street
New York, NY 10001

Approved

Requesting permission to modify the original scope of work by using a gasketed trough in lieu of a gasketed copper detail box, due to field conditions, for an approved special permission, in a building located at:

Pierre Hotel
2 East 61st Street
New York, NY

44093 Jaros Baum & Bolles Consulting Engineers
80 Pine Street
New York, NY 10005

Approved

Requesting permission for a variance to Bulletin #119 to maintain existing clearances that are from 2'6" to 2'10" between the panelboards and bus duct take-off devices in electric closets, in conjunction with panelboard modifications, in a building located at:

Brown Brothers Harriman
140 Broadway
New York, NY

-10-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44094 L.K. Comstock & Company, Inc.
70 West 36th Street, 4th Floor
New York, NY 10018

Approved

Requesting permission to leave as installed PVC conduit risers, used to provide physical protection for the uninsulated copper ground conductors associated with the building's lightning protection system, as per submitted specifications, in a building located at:

Bear Stearns
383 Madison Avenue
New York, NY

44095 Lite-Up Associates Inc.
511 West 20th Street
New York, NY 10011

Approved

Requesting permission to install a 7th service switch where one of the existing service switches is a fire pump, in a building located at:

Metropolitan Tower
146 West 57th Street
New York, NY

44096 Forest Electric Corp.
Two Penn Plaza
New York, NY 10121

Approved

Requesting permission to install PVC raceway under concrete slab on grade, where raceways into the building space will be rigid galvanized steel, in a building located at:

LIJ Health System Energy Center
167-25 76th Avenue
Queens, NY

44097 Super-Charged Electric, Inc.
2 Dubois Avenue
Staten Island, NY 10310

Hold

Requesting permission to install new equipment for a 2 family residence with a drive-in garage at street level at standard height (not 48" above the floor, which would result in the panel top being 8' above the floor for the 46" panel), in a building located at:

377 Pacific Street
Brooklyn, NY

44098 W. Romanello, Licensed Electrical Contractor
34 Gansevoort Street
New York, NY 10014

Hold

Requesting permission for a waiver to install a fire pump service switch in a stairwell as per submitted specifications, sketch and photos, in a building located at:

119 West 22nd Street
New York, NY

44099 E-J Electric Installation Co.
46-41 Vernon Boulevard
Long Island City, NY 11101

Approved

Requesting permission to install junction boxes for telephone cable support in electric closets at five floors for a residential high rise site, as per submitted sketch, in a building located at:

AOL Time Warner Center
Mandarin Oriental Hotel
10 Columbus Circle
New York, NY

44100 Hugh O’Kane Electric Co., LLC
30-40 48th Avenue, 2nd Floor
Long Island City, NY 11101

Approved

Requesting permission for a variance of the ten foot service rule to install seven sets of galvanized conduit in lieu of concrete encasement, for a total footage of approximately 15 feet, in a building located at:

HBO/AOL
1100 6th Avenue
New York, NY

44101 Qncc Electrical Contracting Corp.
86-40 122nd Street
Richmond Hill, NY 11418

Approved

Requesting a one-time permission to install PVC conduit for branch circuits, which will be encased in concrete slab, with rigid galvanized stub-ups, in a building located at:

Jacobi Medical Center
1400 Pelham Parkway South
Bronx, NY

44102 Accu-Glo Electric of New York, Inc.
325 Broadway (Suite 201)
New York, NY 10007

Approved

Requesting permission for the installation of Advisory Board approved pendant-hung lighting fixtures where the fixture cable is tie-wrapped to the steel hanging cable approximately every 12’, due to field conditions, as per submitted specifications, in a building located at:

535 Eighth Avenue
New York, NY

44103 Cameron Engineering & Associates, LLP
Three Aerial Way, Suite 100
Syosset, NY 11791-5598

Denied

Requesting permission to leave two existing 800 amp service switches, each with dual 350 amp one time fuses with no new loads, with additional loads to be tapped ahead of the switches, where the existing switches are in good condition and the existing service room is very tight for space and has physical constraints which will not allow replacing with new wider switches, in a building located at:

I.S. 278K
Brooklyn, NY

44104 Egg Electric, Inc.
26 West 17th Street
New York, NY 10011-5710

Approved

Requested approval for the electric service equipment proposed to be installed in the building at:

Sub. #02A0398

Grand Concourse Plaza
2501-2525 Grand Concourse
Bronx, NY

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44105 Artemide Sub. #02A0348
1980 New Highway
Farmingdale, NY 11735 **Approved**

Requested approval for use in New York City of your
Wall Mounted Halogen Lighting Fixture, Model ICARO
#023208.

44106 Intech 21, Inc. Sub. #02A0349
50 Glen Street
Glen Cove, NY 11542 **Hold**

Requested approval for use in New York City of your
AC Power Meter, Model PM-2104.

44107 Sundance Spas Inc. Sub. #02A0356
14525 Monte Vista Avenue
Chino, CA 91710 **Approved**

Requested approval for use in New York City of your
Portable Spas, Models: 800 and LX Series.

44108 Lightolier Sub. #02A0357
631 Airport Road
Fall River, MA 02720 **Approved**

Requested approval for use in New York City of your
Outlet Box Mounted Compact Fluorescent Lighting
Fixtures, Model "Discus" NYC Version.

44109 Delta Metal Products, Co., Inc. Sub. #02A0364
476 Flushing Avenue
Brooklyn, NY 11205 **Approved**

Requested approval for use in New York City of your
400A Trans "S" with Enclosed Switch Combination, Models:
4CTS-3CESWB-L and 4CTS-3CESWB-H (Line Bottom).
800A Trans "S" with Fused Power Circuit Device Combination.
Models: 8CTS-3CESWB-L and 8CTS-3CEWB-H (Line Bottom).

44110 Marconi Communications Sub. #02A0365
325 Welcome Center Blvd.
Welcome, NC 27374 **Approved**

Requested approval for use in New York City of your
AC Power Transfer Switch, Models: 42GESBAASLE22JAZ7,
42GESBAAZZE22JAZ7, 42GESBAAWLJ22JAZ7,
42GESBBBJLE22JAZ7 and 42GESBBBQLJ22JAZ7.

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44111 Leviton Manufacturing Co., Inc. Sub. #02A0366
59-25 Little Neck Parkway
Little Neck, NY 11362 **Approved**

Requested approval for use in New York City of your
Architectural Lighting Control System, Models: D3206 and
D3208 Energy Management Accessories Cat. Nos. NE100
and NE600.

44112 Teknion, LLC Sub. #02A0367
1200 Horizon Way
Mount Laurel, NJ 08054 **Approved**

Lighting and Electrical System for Desk Furniture System,
XM Series-ACTO, XEBF, XECT, XEI, XESB, XESB8N, XESB8K
and XEPB.

44113 Herman Miller, Inc. Sub. #02A0368
855 E. Main Avenue-P.O. Box 302
Zeeland, MI 49464-0302 **Approved**

Requested approval for use in New York City of your
Portable (Task) Office Furnishing Lights, Models: G6123,
PM123 and Q6123 Series.

44114 Nulux Inc. Sub. #02A0376
112 Green Street
Brooklyn, NY 11222 **Hold**

Requested approval for use in New York City of your
Fluorescent Lighting Fixture 8', Model Hydrolux,
Outdoor Wet Location w/Remote Ballast.

44115 Litelab Corp. Sub. #02A0399
251 Elm Street
Buffalo, NY 14203 **Withdrawn**

Requested approval for use in New York City of your
Custom Made Chandeliers-One time one location:
**434 Lafayette Street, Apartment G2
New York, NY**

44116 Steelcase Inc. **Approved**
P.O. Box 1967
Grand Rapid, MI 49501

Requesting concept approval for a new product being developed, which would have provisions to route low voltage Class II (30 volts or less) wiring within the panel frame for UL listed office furniture, as per submitted specifications and photos, to be located:

Citywide

-14-

**ADVISORY BOARD CALENDAR
JUNE 12, 2002**

44117 Solar Works Inc. Sub. #02A0400
64 Main Street
Montpelier, VT 05602 **Approved**

Requested for one time one location approval of Advanced Energy GS1000 Inverters and AstroPower AM100 Photovoltaic Panels at: **340 Clinton Street, Brooklyn, NY.**

44118 Sigtex Inc. Sub. #02A0401
220 VFW Avenue
Grasonville, MD 21638 **Hold**

Requested approval for use in New York City of your Emergency Exit Signs Crystal Series CRR and CRS.

44119 Sigtex Inc. Sub. #02A0402
220 VFW Avenue
Grasonville, MD 21638 **Hold**

Requested approval for use in New York City of your Emergency Lighting Fixtures Coverlite Series CVR.

Carry-overs:

<u>Cal. #</u>	<u>Original Meeting Date</u>	<u>Disposition</u>
42112	June 28, 2000	Approved
43680	February 13, 2002	Approved
43926	May 1, 2002	Approved
43951	May 1, 2002	Approved
43983	May 15, 2002	Approved
43989	May 15, 2002	Approved
43997	May 15, 2002	Approved
44004	May 15, 2002	Approved
44005	May 15, 2002	Approved
44006	May 15, 2002	Approved
44007	May 15, 2002	Approved

Note-Advisory Board approvals are specific to the condition and specification detailed in the request and should not be construed as precedent for other installations.

