

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45685CO2	04A0230CO2	Illuminous Electric Inc. 1425 37th Street Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	739 East New York Avenue Brooklyn NY	Denied	\$0.00
Carry over from 6/16/04 meeting. 1) The parallel conductors must terminate at one location. 2) Increase bus sizes in panelboard or reduce fusing in the service switch.						
47877CO	07A0216CO	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	New Yorker Hotel 481 Eighth Avenue New York NY	Approved	\$0.00
1) Transformer location must allow ventilation space along wall as recommended by manufacturer. 2) Confirm transformer primary switches can handle in rush. 3) Show missing bus sizes. 4) Clarify emergency generator connection on service #4. 5) Correct discrepancy in 400A switch/fuse size. Job finalized 6/19/07.						
47953CO	07A0265CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The (New) Yankee Stadium 1 Yankee Stadium Way Bronx NY	Approved	\$0.00
Carry over from May 23, 2007 meeting.						
47958	07A0298	Jeminis Electrical Contractors, Inc. 18-01 120th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	480 Humbolt Street Brooklyn NY	Approved	\$650.00
1) Show service entrance conductors entering trough sizes and # of sets. 2) Show tap detail inside of service entrance trough, if taps. 3) Provide coordination curves for 1200A house distribution panel. Job finalized 10/29/07.						
47959	07A0272	Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	140-142 West 22nd Street New York NY	Approved	\$650.00
1) Service room doors to open out with panic hardware. 2) Service entrance conductors feeding the fire pump service switch not shown. 3) Fire pump service entrance conductors to comply with Amendment 695.6A. 4) Provide coordination curves for new 1200A CB panels. Job finalized June 13, 2007.						

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47960	07A0281	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	BT Phase 2A Part 1 111 8th Avenue New York NY	Approved	\$650.00
No fuse coordination with 600A TRS, 400A TRS and 1200A A4 BQ. Job finalized 11/9/07.						
47961	07A0275	Douglas Paskor, Inc. 248 Nassau Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Jetro Cash & Carry 566 Hamilton Avenue Brooklyn NY	Approved	\$650.00
47962	07A0279	Katco Electric, Inc. 44-15 Barnett Avenue Long Island City NY 11104	Requested approval for the electric service equipment proposed to be installed	1 Pace Plaza New York NY	Approved	\$650.00
47963	07A0289	Rosselco Co., Inc. 988 Morris Park Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	140 Riverside Blvd. New York NY	Approved	\$650.00
Clarify method of tapping in 8" x 8" trough. Both sets of 500 KCM must be tapped. Job finalized 8/2/07.						
47964	07A0288	Avalon Electric Corp. 3632 Kingsbridge Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	400 West End Avenue New York NY	Approved	\$650.00
Provide signage indicating 2 service rooms. Job finalized 8/2/07,						

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47965	07A0287	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 Church Street New York NY	Approved	\$650.00
Doors to swing out. Job finalized 8/2/07.,						
47966	07A0286	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	11-15 50th Avenue Long Island City NY	Approved	\$650.00
47967	07A0282	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	80 Wall Street New York NY	Approved	\$650.00
47968	07A0285	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1965 Broadway New York NY	Approved	\$650.00
47969	07A0295	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Haru 82 Beaver Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47970	07A0297	Sierra Electric Inc. 535 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Stuyvesant H.S. 345 East 15th Street New York NY	Approved	\$650.00
47971	07A0302	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	NYC Dept. of Environ. Protection rds Island Water Pollution Control P Wards Island NY	Approved	\$650.00
1) Provide drawings in Advisory Board format with bus sizes. 2) Siemens drawings too small to read fonts. Job finalized August 16, 2007.						
47972	07A0304	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Pratt Institute 200 Willoughby Avenue Brooklyn NY	Approved	\$650.00
47973	07A0273	WB Engineers Consultants PLLC 110 William Street New York NY 10038	Requested Concept Approval for:	Verizon Network Retention 1775 Grand Concourse Bronx NY	Ok, but	\$650.00
1) System as shown not suitable for legally required emergency loads. 2) Interlocks required for perm. Generator breaker and portable generator breaker. 3) Although not a code violation, it is recommended to provide neutral grounding at generator with 4-pole transfer. 4) Must show fuse/breaker coordination on 2 levels. 5) Short circuit and coordination study would be required.						
47974	07A0306	Yonkers Electric Contracting Corp. 4280 Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard Brooklyn NY	Hold	\$650.00
1) Provide Elec. Interlock schemes for sub stations. 2) Provide short circuit and coordination study. 3) Switchgear room door to open out. 4) Confirm clearances to columns and rear walls.						

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47975	07A0271	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	98 Co-op City Blvd. Bronx NY	Ok, but	\$650.00
1) Provide buss sizes. 2) Conductive cement wall shall be insulated behind switchboard. 3) All issues in the coordination study must be addressed.						
47976	07A0299	Ampere Electric Corp. 200-06 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	168-23 Jamaica Avenue Jamaica NY	Approved	\$650.00
47977	07A0280	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NY Times 229 West 43rd Street New York NY	Approved	\$650.00
1) Provide egress door in service room A,B,C, and Switchboard 1 and doors to open out with panic hardware. 2) Conductors sizes missing between side of ATS not provided. 3) Is the 600 amp emergency feeder tapped ahead of the main generator switch? 4) Is the emergency feeder to FAC tapped on line side of main generator switch and show size of conductors. Job finalized 6/23/08						
47978	07A0276	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Plaza Residences Fifth Avenue at 59th Street New York NY	Approved	\$650.00
47979	07A0278	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	101 Classon Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47980	07A0274	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	211 North End Avenue Battery Park NY	Approved	\$650.00
47981	07A0283	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	15 East Clarke Place Bronx NY	Approved	\$650.00
47982	07A0277	Colony Electric Company, Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	NYU Dormitory 334 East 26th Street New York NY	Denied	\$650.00
Void as per Cal. #48724						
47983	07A0293	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	205 East 42nd Street New York NY	Approved	\$650.00
47984	07A0292	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	201 East 42nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47985	07A0291	A & R Electrical Maintenance, Inc. 69-61 Juniper Boulevard South Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	5-05 48th Avenue Long Island City NY	Approved	\$650.00
47986	07A0290	Merit Electrical Contracting Corp. 648 4th Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	465 2nd Avenue New York NY	Approved	\$650.00
47987	07A0284	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1269 Lexington Avenue New York NY	Approved	\$650.00
47988	07A0294	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hub Parking Renovation 3000-3002 3rd Avenue Bronx NY	Ok, but	\$650.00
F.C.O. shall be tapped ahead of service switch						
47989	07A0296	Sierra Electric Inc. 535 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Art and Design H.S. & P.S. 59 228 East 57th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47990	07A0300	Klear Electrical Corp. 31-00 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia Presbyterian Hospital 177 Fort Washington Avenue New York NY	Approved	\$650.00
47991	07A0301	Hanington Engineering Consultants 1 Gold Mine Road Flanders NJ 07836	Requested approval for the electric service equipment proposed to be installed	49 East 86th Street Corporation 49 East 86th Street New York NY	Approved	\$650.00
47992	07A0303	Absolute Electrical Contracting, Inc. One Cross Island Plaza New York NY 11422	Requested approval for the electric service equipment proposed to be installed	809 United Nations Plaza New York NY	Approved	\$650.00
1) Service equipment not bonded grounded. 2) Increase service entrance conductors to service switches #2 and #3 or clarify drawing for service switches #2 and #3. Job finalized 8/2/07.						
47993	07A0305	Babaro Electric Co., Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Paerdegat Water Quality Fac. Brooklyn NY	Approved	\$650.00
With the stipulation						
47994	\$	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to install concrete encased underground service entrance conductors in Schedule 40 non metallic conduit.	PS244Q 132-7- Franklin Avenue Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47995	\$\$	Marriott Electric Corp. 182-25 150 Avenue Springfield Gardens NY 11413	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit on 4 single family houses.	ad 727 Beck Rd, 797 and 803 Empire Far Rockaway NY	Approved	\$0.00
47996	\$\$\$	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a Solar photovoltaic system	Jacob's Place 2348 Webster Avenue Bronx NY	Approved	\$0.00
47997	\$\$\$\$	Duce Green Building 412 West 127th Street New York NY 10027	Requesting concept approval for the installation of 3 Solar photovoltaic systems at 3 different locations	., N.Y., 234 Madison St., Bklyn, 417 NY	Approved	\$0.00
47998	\$\$\$\$\$	GB Electrical Corp. 1874 Clove Road Staten Island NY 10304	Requesting permission not to group together service equipment in a 2 family building where the existing service switches are installed indoors and the new service for site lighting will be installed on the outside of the building.	29 Tessa Court Staten Island NY	Approved	\$0.00
47999	\$\$\$\$\$\$	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission to leave as installed service equipment that was not originally grouped together where one store is upgrading their service.	54-23A Myrtle Avenue Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

June 13, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48000	\$\$\$\$\$\$	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as installed a 480 volt, non ground fault protected 1200 amp disconnect switch that will contain 900 amp fuses with a permanent affixed sign on the switch stating "use 900 amp fuses max".	Battery Park City-Site 18B 211 North End Avenue New York NY	Approved	\$0.00
48001	\$\$\$\$\$\$	Colony Electric Company, Inc. 178 Industrial Loop Staten Island NY 10309	Requesting permission due to hardship to correct to leave as installed secondary protection of a step up 500 KVA transformer on the roof of a 36 story building where the transformer is located in the basement.	18 West 48th Street New York NY	Approved	\$350.00
With the stipulation that the primary fuses are changed to 1600 amps and the secondary fuses are changed to 700 amps and signage is affixed to the 2000 amp primary switch stating "the maximum size fuse allowed in this switch is 1600 amps" and a sign affixed to the secondary switch stating "the maximum size fuse allowed in this switch is 700 amps."						
48002	\$\$\$\$\$\$\$\$	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission on a one for one replacement of second fuses to replace 5 existing Pringle switches with new ground fault Pringle switches all rated at 2000 amps on an existing 480 volt 1000 KVA service	425 Park Avenue New York NY	Approved	\$0.00
48003	07A0307	Cooper Lighting 1121 Highway 74 South Peachtree City GA 30269	Requested approval for use in New York City of your Cooper Lighting MWS, Manufactured Wiring System. Model /Series Numbers: "ST", "EC", "FC". "SF". "SD". "SP", "TC", "DC", "CT", "TS" and "DS".		Approved	\$200.00