

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0000	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	45 Main Street Brooklyn NY	Hold	\$650.00
1) Load calculations not provide to clarify that installation conforms with 240121(B)(1) for 10' tap rule (panels F.E.B.). 2) Confirm access to pillbox behind disconnect switch #1. 3) Confirm clearance behind G.D.C. panels or block it out.						
50345CO2	10A0366CO2	T & R Alarm and Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Lehman College 250 Bedford Park Blvd. West Bronx NY	Approved	\$0.00
Carry over from March 10, 2011 meeting. Where is fire pump and provide fire pump FLA? Job finalized 8/29/12.						
50913CO2	12A0069	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	150 Delancey Street New York NY	Pending	\$0.00
Carry over from November 9, 2011. Emergency side fusing for fire pump oversized, submit cut sheet NSJ circuit breaker.						
50973CO		Alef Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	53 West 36th Street New York NY	Approved	\$0.00
Carry over from November 9, 2011 meeting.						
51081CO2	12A0071	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	500 Hamilton Avenue Brooklyn NY	Approved	\$0.00
Carry over from April 18, 2012 meeting. 1) All ATS are 3 pole type throughout emergency system, the generator is a separately derived system and the neutral in the generators switchboard shall be bonded to enclosure and grounded. 2) Disconnect switches fed from the generator switchboard shall not have the neutrals bonded and grounded. 3) C-ATS-04 shall be 3 phase, 3 poles and no neutral bonding. 4) Generator fire alarm tap is not required a neutral. Job finalized 3/15/13. 7/28/16 Swapped Drawing 2-Revision 7.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51165CO	12A0073	Schulte Electro Systems Corporation 41W020 Seavey Rd Sugar Grove IL 60554	Requested approval of equipment for use in New York City of your EVOLine Port 1636, EVOLine Dock 2122		Denied	\$0.00
Relocatable power taps are not intended to be permanently secured to building structures, tables, work benches or similar structures, nor are they intended to be used as a substitute for fixed wiring						
51169CO	12A0070	A to Z Electrical Maint. & Serv. Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	650 Park Avenue New York NY	Hold	\$0.00
Carry over from April 18, 2012 meeting. * Special permission 12A0061, for requesting new service to be installed in the adjacent room denied. 1) Separate new electrical equipment area from tenant storage area. 2) Verify if a 2nd means of egress can be installed.						
51172CO		Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2315 Broadway New York NY	Approved	\$0.00
Carry over from April 18, 2012 meeting.						
51177CO2	12A0074	Linhill Electrical Contractors Inc. 4850 White Plains Road, 2nd Floor Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	2416 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Carry over from May 2, 2012 meeting. The service room door adjacent to the service switch is provided with panic hardware. Job finalized 6/21/12.						
51226CO	12A0072	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	New York University 21 Washington Place New York NY	Hold	\$0.00
Carry over from May 2, 2012 meeting. Secondary devices rating (Total) are not in compliance with 450 requirement including fire pump load (secondary OCPD).						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51256	12A0003	Team Electric, Inc. 20 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Museum of Mathematics 11 East 26th Street New York NY	Approved	\$650.00
51257	12A0007	Coast 2 Coast Electric Cabling, Inc. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	222 East 16th Street New York NY	Approved	\$650.00
51258	12A0010	Aero Electric Corp. 159 Eldridge Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	301 West 45th Street New York NY	Approved	\$650.00
51259	12A0011	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1 East 33rd Street New York NY	Approved	\$650.00
51260	12A0012	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	28 West 25th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51261	12A0014	A.L. Electrical Corp. 307 7th Avenue, Suite 404 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	885 Avenue of the Americas New York NY	Approved	\$650.00
51262	12A0015	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	206 East 52nd Street New York NY	Approved	\$650.00
51263	12A0016	MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	880 3rd Avenue New York NY	Approved	\$650.00
51264	12A0018	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	619 West 54th Street New York NY	Approved	\$650.00
51265	12A0024	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	346 West 17th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51266	12A0034	Kramer Electric, LLC 28 West 27th Street, Suite 701 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Goddard School 2495 Broadway New York NY	Approved	\$650.00
51267	12A0039	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	154 West 57th Street New York NY	Approved	\$650.00
51268	12A0041	Klear Electrical Corp. 31-00 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1285 6th Avenue New York NY	Approved	\$650.00
51269	12A0042	Arc Electrical Construction Co., Inc. 40 West 57th Street, 26th Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	One Liberty Plaza New York NY	Approved	\$650.00
51270	12A0045	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Glenwood Management 10 Barclay Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51271	12A0047	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	845 Columbus Avenue New York NY	Approved	\$0.00
5/27/15 Swapped B, Revision 3.						
51272	12A0048	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	840 Columbus Avenue New York NY	Approved	\$0.00
5/27/15 Swapped A, Revision 3.						
51273	12A0049	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	860 Columbus Avenue New York NY	Approved	\$0.00
5/37/15 Swapped E, Revision 2.						
51274	12A0050	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	865 Columbus Avenue New York NY	Approved	\$0.00
5/27/15 Swapped C, Revision 1.						
51275	12A0051	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	875 Columbus Avenue New York NY	Approved	\$0.00
5/27/15 Swapped D, Revision 3.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51276	12A0052	Arcadia Electrical Co., Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Harper St. Asphalt Plant 131-05 Northern Blvd. Corona NY	Approved	\$650.00
7/15/14 Swapped A and B, Rev 2 and address correction. 8/2/16 Swapped Drawing A-Revision 3 and Drawing B-Revision 2.						
51277	12A0053	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	U.P.S. Manhattan South 325 Spring Street New York NY	Approved	\$650.00
51278	12A0055	Midland Electrical Co. 37-31 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Queens Council of the Arts 37-11 35th Avenue Astoria NY	Approved	\$650.00
51279	12A0057	Kleinberg Electric Inc. 437 West 16th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	375 Front Street Staten Island NY	Approved	\$650.00
51280	12A0058	Midland Electrical Co. 37-31 58th Street Woodside NY 11377	Requesting permission on a 1000 KVA installation where a 2nd fusing open front switchboard is being replaced with new in its existing location to leave as originally installed where the front clearance between the front of the existing service switch and the side of the new distribution board is 4 feet	Queens Council of the Arts 37-11 35th Avenue Astoria NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51281	12A0059	New York City Housing Authority 90 Church Street New York NY 10007	Requesting permission due to vandalism and building design to allow unspliced elevator main feeders in existing hoistways where 75 elevators are being upgraded.	comments for addresses in various b	Approved	\$0.00
120 E. 123rd St., 1761, 1809, 1851 and 1875 3rd Avenue, 219 E. 97th St., 1895, 1905 and 1955 2nd Ave., 225 E. 99th St., 210, 220, 230, and 215 E. 102nd St., 218 E. 104th St., and 1945 Amsterdam Avenue, Manhattan; 103-07 Flatlands Ave., 757 and 719 E. 103rd St., 103-12, 104-06 and 105-13 Glenwood Rd., 716, 671 and 621 E. 105th St., 105-12, 106-02, 106-12, 106-22, 107-02 and 107-12 Farragut Rd., 620, 617, 619, 567, 569, 543, 553, and 523 E. 108th St., 254 Stanley Avenue, Brooklyn; 34-03, 34-21, 35-21, 35-05, 35-35, 35-51, 35-34, 35-50, 35-20 and 35-06 21st St, 21-20,23-02, 12-20, 13-06, and 13-10 34th Ave., 34-20, 34-04, 34-34, 34-50, 35-06, 35-20, 35-36, 35-52, 24th St., 21-51, 21-15, 21-25, 21-09, 21-30, 21-40, 12-22, 12-50, 12-35 and 12-21 35th St., 23-03, 22-01,14-01 and 12-15 36th St., 35-37, 35-53, 35-03, 35-19, 34-35, 34-55, 34-05 and 34-15 12th Ave-L.I.C, Queens.						
51282	12A0060	Linphill Electrical Contractors Inc. 4850 White Plains Road, 2nd Floor Bronx NY 10470	Requested permission to leave as installed a service switch with a front clearance of 4 feet where a 48 inch wide door is installed in front of the switch to provide the 5' clearance needed for a 1000 KVA service	Kings Hotel 2416 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Code: 230.64(B)(1) With the stipulation that the service room door adjacent to the serve switch is provided with panic hardware.						
51283	12A0063	awless & Magione Architects & Engs. LL 480 North Broadway Yonkers NY 10701	Requested permission to leave as installed due to lack of space inside of the service room to locate a new service switch in a remote location where signage will be provided.	247 West 12th Street New York NY	Approved	\$350.00
Code: 230.72(A). With Signage						
51284	12A0064	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requesting permission to leave as installed a defective service switch that was replaced in the same location outside of the service room due to there being no space to install the switch in the service room.	Apple Store 72 Greene Street New York NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51285	12A0066	Evenlite, Inc. 3161 State Road Bensalem PA 19020	Requested approval of equipment for use in New York City of your Recessed LED Emergency Light Fixture. Model/Series Numbers: WAY/LTP followed by LC/NC/NM		Approved	\$200.00
Model Way w/LC, NC. NR suffix approved. However, provide report for model LTP.						
51286	12A0067	Workrite Ergonomics 2277 Pine View Way Petaluma CA 94959	Requested approval of equipment for use in New York City of your Lincoln Undercabinet LED Lights.		Approved	\$200.00
51287	12A0068	Teknion, LLC 350 Fellowship Road, Suite 100 Mt. Laurel NY 08054	Requested approval of equipment for use in New York City of your Teknion District Office Furniture Systems		Approved	\$200.00
51331	12A0004	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Mail at Bay Plaza 1441 Metropolitan Avenue Bronx NY	Approved	\$650.00
Confirm the fence is bonded to service. Job finalized 7/25/12.						
51332	12A0006	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	590 6th Avenue New York NY	Approved	\$650.00
Correct typo, ATS feeds new disconnect switches, should be terminated into switchboard. Job finalized 8/6/12.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51333	12A0008	Multi-Tech Electric, Inc. 25-26 50th Street, Suite 208A Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1294 3rd Avenue New York NY	Approved	\$650.00
1) Where does gas room door open to? 2) Show tap lengths to 200 amp disconnect switch. 3) How are all the taps made? At the sw #6? Job finalized 8/6/12.						
51334	12A0009	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	451 Lexington Avenue New York NY	Approved	\$650.00
Provide 12" clearance on both sides of fire pump service switch. Job finalized 8/3/12.						
51335	12A0013	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 200 Hudson Street New York NY	Approved	\$650.00
Service room to have mechanical ventilation. Job finalized 8/3/12.						
51336	12A0020	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	330 West 34th Street New York NY	Approved	\$650.00
Change fuses to 1000 amp in service switches 2 and 3. Job finalized 8/3/12.						
51337	12A0022	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	P.S. 470M 145 West 84th Street New York NY	Approved	\$650.00
Size of su pp ground is under sized for building steel . Building steel refer to 250.66. Job finalized 8/6/12.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51338	12A0054	Amber Lite Electric Corp. 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	21 East 1st Street New York NY	Approved	\$650.00
1) Show load side conductors off of service switches #3 and #4. 2) Pain fire pump switch red. Job finalized 7/26/12.						
51339	12A0043	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	111 Second Avenue New York NY	Approved	\$650.00
1) Show physical of the routing of the trough, and how the feed to the fire pump service switch is established. 2) Show how trough is physically connected to the equipment. Job finalized 7/30/12.						
51340	12A0046	Dooley Electric Company, Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NY Institute of Technology 1855 Broadway New York NY	Approved	\$650.00
Provide signage on service room doors 230.2(E). Job finalized 7/31/12. 9/30/14 Swapped A-Revision 3.						
51341	12A0025	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	10 Rockefeller Plaza New York NY	Approved	\$650.00
Describe key interlock sequence on ATS-SB-4. Job finalized 8/2/12.						
51342	12A0035	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	145 4th Avenue New York NY	Approved	\$650.00
Explain how the installation of trough over the end box will not interfere with access to the end box. Job finalized 8/6/12.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51345	12A0030	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	250 North 10th Street Brooklyn NY	Approved	\$650.00
1) #4 service entrance conductors are over fused. 2) Explain 60 amp main in panel. Job finalized 8/3/12.						
51348	12A0026	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	375 Pearl Street New York NY	Approved	\$650.00
1) Fire pump equipment grounding conductors undersized. 2) Rear of Boards to comply with Table 110.34. 3) M1-05-USS-A01 BNS sizes undersized and M1-06-USS-B01. Job finalized 8/9/12,						
51364	12A0021	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Queens West Parcel #1 45-60 Center Boulevard Long Island City NY	Approved	\$650.00
Tap conductors undersized. Job finalized 8/17/12.						
51365	12A0023	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	120 West 42nd Street New York NY	Approved	\$650.00
1) Pump feeds to be fire rated. 2) Confirm fire pump tap as in same enclosure w/s.#1. Job finalized 8/6/12,						
51372	12A0017	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Church Pension Group 19 East 34th Street New York NY	Approved	\$650.00
1) Provide lengths of transformer tap. 2) Verify coordination between 3000 amp breaker and 1200 amp switch. Job finalized 8/30/12.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51377	12A0032	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	360 Lexington Avenue New York NY	Approved	\$650.00
1) Verify that fire pump is located above street level. 2) Service switches misidentified as safety switches. 3) Clarify box on top right of floor plan. If ATS, cannot be in service room. Job finalized 8/29/12.						
51413	12A0038	P & H Electric Corp. 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	627 Broadway New York NY	Approved	\$650.00
1) Service entrance conductors feeding ss#1 not shown. 2) Tap conductors to 800 amp disconnect switch undersized. 3) Does service room extend after the break line on room layout drawing. Job finalized 9/24/12.						
51540	12A0044	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Trevor Day School 312-318 East 95th Street New York NY	Approved	\$650.00
1) Provide ampere rating of ATS switches. 2) Verify wire size to 60 amp service switches. 3) Fire pump feed misidentified on 4 conductors. 4) Provide gen set cut sheets. Job finalized 1/15/13.						
51541	12A0036	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	930 Grand Concourse Bronx NY	Approved	\$650.00
1) What is AIC at the house panel, short circuit calculation not provided. 2) Bus feeding 2 1200 amp disconnect switches undersized. Job finalized 1/14/13. 11/27/13 Swapped Rev 3.						
51601	12A0002	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	1601 80th Street Brooklyn NY	Approved	\$650.00
1) Service bus undersized. 2) Verify service bus feeding ss1, 1-4x 1/4". 3) Show trough bus size in MDB-C-D. 4) Verify if rear covers are tamper resistant on galaxy equipment. 5) Show clearance between galaxy to existing equipment under bus duct. Job finalized 3/21/13.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51607	12A0001	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	2802B Victory Blvd. Staten Island NY	Approved	\$650.00
1) Show fuse size on incoming 5KV feeder. 2) 4000 amp disconnect switch overfused table 450.4(A). 3) Remove neutral bonds in fire pump switches. 4) Fire pump feeders to be fire rated 3-4000 amp feeder is undersized. Job finalized 3/28/13. 11/26/13 Swapped 2 of 3.						
51608	12A0029	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	College of Staten Island 2802C Victory Blvd. Staten Island NY	Approved	\$650.00
1) Show fuse size on line side of incoming 5 KV feeder. 2) Fire pump feeder to be fire rated. 3) Verify that free standing switchboard does not have rear covers. Job finalized 3/28/13. 11/26/13 Swapped drawing 2 of 3.						
52138	12A0033	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	205 East 42nd Street New York NY	Approved	\$650.00
1) Explain 2 hour fire rated access panel to 4000 amp CT, and trough. 2) Service SS4 fire pump taps taken from switchboard section that contains overcurrent protective devices. 3) Where is fire pump splice box located? 1/24/14 job finalized. 8/14/15 Swapped AB50 1 of 4, 2 of 4, 3 of 4-Revision 2s. SB10 1 of 4-Revision 3, 2 of 4-Rev 2, 3 of 4-Rev 3. SB50-4 of 4-Rev 1. 4/14/2017 - swapped dwg AB50-02 rev 3, SB10-02 rev 3, PB50-03 Rev 2, SB50-04 Rev 2						
aaaaa	12A0005	Kramer Electric, LLC 28 West 27th Street, Suite 701 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Hold	\$650.00
1) Show all clearances in service room. 2) Physicals of equipment not submitted. 3) Show bus and feeder sizes on existing equipment. 4) Show bonding and grounding of existing equipment. 5) Service entrance to existing 2000 amp service switch 1B undersized. 6) fuse pullout types not shown. 7) Show neutral connection to ground bus, and size of ground in new 4000 amp service switch.						
bbb	12A0019	Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	920 East 132nd Street Bronx NY	Pending	\$650.00
Provide physicals of equipment.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
bbbbbbbbbb	12A0027	Robert MaGoolaghan Inc. 240 Beach 116th Street Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Metro Bio-Fuels 435 Greenpoint Avenue Brooklyn NY	Hold	\$650.00
1) P.O.E. conductors undersized to property line box. 2) SS@ fuse oversized. 3) Gen roll up rewires external ok protection (external). 4) Grounding Electrode (water main & supplemental ground) missing in PSWB. 5) Generator input breakers missing LSIA. 6) Explain how roll up gen will interface to fire pump. 7) Explain load shed scheme. 8) Show keylock between breakers where required. 9) Switch for FACP missing. 10) Paralleling bus undersized for 3rd future generator. 11) Gen breaker need neutral disc.						
bbbbbbbbbb b	12A0028	atore Campisi & Sons Lic. Electl Contrs. 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	237 West 35th Street New York NY	Hold	\$650.00
1) Show all clearances and elevations in service room with oil tank, it is recommended that the wall between service rooms be opened to comply with Section 110.26. 2) No additional electrical equipment to be installed in service room that contains oil tank.						
bbbbbbbbbb bbbb	12A0031	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	29-01 Borden Avenue Long Island City NY	Hold	\$650.00
1) Verify that emergency feeders are not run through the service room. 2) Disconnect link not to be used in main bonding jumper bus. 3) Fire pump feeders not fire rated and fuse undersized. 4) Provide side views of equipment. 5) Verify if emergency panels are feeding life safety loads. 6) Verify what is new and existing in service room. 7) Fire alarm service switch not shown on drawing. 8) Correct typo for rating of generator.						
cccc	12A0037	Bestco General Electrical Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	71 5th Avenue New York NY 2	Pending	\$650.00
Tap conductor undersized.						
cccccc	12A0040	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue New York NY	Hold	\$650.00
1) Generator cut sheet does not match installation, is generator and switchboard listed as a complete assembly. 2) Provide cut sheet of the 535 RNW cable and provide the temperature at the terminations on each side of the run, conductors undersized.						

ADVISORY BOARD CALENDAR

June 13, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
dddd	12A0056	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	WTC Tower #3 175 Greenwich Street New York NY	On Hold	\$650.00
1) Verify that switchboards have rear hinged doors. 2) Remove neutral bonds in fire pump switches, 3) Fire pump emergency fusing undersized.						
ddddddddd	12A0061	A to Z Electrical Maint. & Serv. Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requesting permission due to lack of space inside of the existing service room to install additional service equipment in an adjacent room.	650 Park Avenue New York NY	Denied	\$0.00
1) Separate new electrical equipment area from tenant storage area. 2) 2nd means of egress in new service area required.						
ddddddddd	12A0062	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requesting permission to leave as installed due to a hardship to relocate service equipment on a 1000 KVA service where the front clearances of service switches does not comply with Section 230.64(B)(1).	55 Hope Street Brooklyn NY	Denied	\$0.00
ddddddddd ddd	12A0065	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to replace a defective 2500 KVA transformer with new and replace 10 feet of 5 KV feeder cable to the transformer with new 5KV shielded conductors.	Fordham University 441 E. Fordham Rd. Bronx NY	Denied	\$0.00
Drawings are to be submitted for approval.						