

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46793CO	06A0530CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering New York NY	Hold	\$0.00
Carry over from November 16, 2005 meeting. New drawings must be submitted.						
46915CO3	06A0031CO3	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	375 Park Avenue New York NY	Approved	\$0.00
Carry over from March 15, 2006 meeting.						
47035CO	06A0121CO	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Approved	\$0.00
Carry over from March 15, 2006 meeting.						
47091CO	06A0214CO	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Columbia University 615 West 131st Street New York NY	Approved	\$0.00
Carry over from April 12, 2006 meeting. Need GF scheme. Provide sequence of operator of the ground fault. Job finalized 7/14/06.						
47093CO	06A0169CO	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY 11217	Requested approval for the electric service equipment proposed to be installed	Alph Plastics 10203 Avenue D Brooklyn NY	Hold	\$0.00
Carry over from April 12, 2006 meeting. Drawing need more details wire and fuse sizes.						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47121CO2	-----	Murray Diamond, Licensed Electrician 35-05 169th Street Flushing NY 11358	Requesting permission due to ground water conditions to run service entrance conductors in overhead troughs within a two hour fire rated room instead of concrete encased conduits (Cal. #42541).	Fresh Direct 23-30 Borden Avenue Queens NY	Approved	\$0.00
Carry over from May 24, 2006 meeting.						
47137CO	06A0254CO	Lite Tron Electrical Corp. 236 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Woolworth Building 233 Broadway New York NY	Approved	\$0.00
Carry over from May 24, 2006 meeting.						
47187CO	06A0234CO	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	270 Greenwich Street New York NY	Approved	\$0.00
Carry over from May 24, 2006 meeting.						
47190CO	06A0282CO	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	353 4th Avenue Brooklyn NY	Approved	\$0.00
Carry over May 24, 2006 meeting.						
47191CO	06A0283CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	112-20 Rockaway Blvd. Queens NY	Approved	\$0.00
Carry over from May 24, 2006 meeting..						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47194CO	06A0286CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	The Hub Core & Shell 3000-3002 3rd Avenue Bronx NY	Approved	\$0.00
Carry over from May 24, 2006 meeting.						
47205CO	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic conduit for three outdoor free standing services, distribution panels, site lighting and bollard lighting in a corrosive area, Far Rockaway, Queens.	Dr., 7602 C Aquatic Dr. and 7718 C Queens NY	Approved	\$0.00
Carry over from May 24, 2006 meeting.						
47215CO	06A0229CO	Elliot Energy Systems, Inc. 2901 S.E. Monroe Street Stuart FL 34997	Requested approval for use in new York City of your TA 100 Microturbines, Model/Series Number: TA100-CHP,-Monogen.		Hold	\$0.00
Carry over from May 24, 2006 meeting. Listing of overall product must be listed by a Nationally Recognized Testing Laboratory(NRTL) and evaluated to be compliant with documents or standards.						
47217	06A0294	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 685 Third Avenue New York NY	Approved	\$650.00
47218	06A0293	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	15 Broad Street New York NY	Approved	\$650.00
1) Block access behind Switchboard "D". 2) Provide egress door near Switchboard "D". 3) Provide fuse sizes for FCO's. 4) Show bonding in FCO's. Job finalized 7/18/06.						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47219	06A00290	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New Museum of Contemporary 235 Bowery New York NY	Ok, but	\$650.00
1) Line side bus of 3000A service switch undersized. 2) Verify F.A. feeders 30 4W or 10 3W? 2p ATS? 3) Confirm sp. Service fire pump loc. Above street level.						
47220	06A0292	Compsec Electric Corporation 39-12 Crescent Street Queens NY 11106	Requested approval for the electric service equipment proposed to be installed	26 Court Street Brooklyn NY	Approved	\$650.00
Tap conductors undersized with derating for 2 sets in 1 conduit. Job finalzaed 07/18/06.						
47221	06A0295	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	161 Williams Street New York NY	Approved	\$650.00
47222	06A0297	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	R/GA Media Group 350 West 39th Street New York NY	Approved	\$650.00
47223	06A0299	J. McCarfrey T. T. McGovern, Electric Inc 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	1125 Park Avenue New York NY	Ok, but	\$650.00
Tenants storage gates inside of service room?						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47224	06A0301	C.B. Electric, Inc. 130-43 92nd Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	35 Kent Avenue Brooklyn NY	Approved	\$650.00
1) 4-Pole ATS required. 2) Provide bus sizing on Square D equipment. Job finalized 7/18/06.						
47225	06A0305	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Verizon Cell Site 211 West 40th Street New York NY	Approved	\$650.00
47226	06A0307	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Beth Israel Dazin-Emergency 330 East 17th Street New York NY	Approved	\$650.00
47227	06A0309	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Museum of Arts & Design 2 Columbus Circle New York NY	Approved	\$650.00
Verify clearance in front of S.E.B. Job finalized 7/18/06.						
47228	06A0311	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	250 East 53rd Street New York NY	Approved	\$650.00
1) Fire pump services switch located at end of switchboard. 2) Primary to XFMR undersized. 3) Eliminate 7th service switch. Job finalized 6/21/06.						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47229	06A0313	Kleinknecht Electric Company, Inc. 252 West 37th Street-9th Floor New York NY 11018	Requested approval for the electric service equipment proposed to be installed	Club H Fitness Center 423 West 55th Street New York NY	Approved	\$650.00
47230	06A0315	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Home Depot 1806 East Gunhill Road Bronx NY	Approved	\$650.00
47231	06A0317	J.H. Electric of New York 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Dept. of Sanitation Man. District 780-786 12th Avenue New York NY	Hold	\$650.00
1) Normal f.p. disconnect undersized. 2) Normal f.p. disconnect must be in dedicated enclosure. 3) Service fuse distribution fused not coordinated. 4) Feeder size to ATS #3 not shown. Show 3P or 4P. 5) Provide generator room layout. Show loc. of f.p. switches. 6) Gen feeder to 'EMDP' undersized. 7) 'MSSA 52': provide code clearances. 8) Provide section views.						
47232	06A0319	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Judith Leiber Retail Store 680 Madison Avenue New York NY	Approved	\$650.00
1) Feed to existing All City service switchboard undersized. 2) Verify available short circuit current at new 400A panel. Job finalized 6/26/06.						
47233	06A0321	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	IS 113X 3710 Barnes Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47234	06A0303	Jemco Electrical Contractors, Inc. 21-71 Steinway Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Vivarium City College Convent Avenue & 138th Street New York NY	Approved	\$650.00
47235	06A0287	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	360 West 11th Street New York NY	Hold	\$650.00
1) Fire pump must be fed from Con-Ed box. 2) Fuse types not provided for pullouts. 3) Remove neutral bond in 400 amp disconnect switch. 4) Provide elevator drawing of 1200A service switch.						
47236	06A0288	Hanington Engineering Consultants 1 Gold Mine Road Flanders NJ 07836	Requested approval for the electric service equipment proposed to be installed	Sack Residence 895 Park Avenue, Apt. 12/13 B New York NY	Approved	\$650.00
47237	06A0289	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	825 Eighth Avenue New York NY	Approved	\$650.00
47238	06A0291	Shally Electrical Contractor, Inc. 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	2801 Emmons Avenue Brooklyn NY	Hold	\$650.00
One line missing.						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47239	06A0302	L.&R. Electl Contg and Repair Service Inc 145 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	416 West 13th Street New York NY	Approved	\$650.00
47240	06A0296	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	20 West 55th Street New York NY	Approved	\$650.00
47241	06A0298	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	110 3rd Avenue New York NY	Approved	\$650.00
47242	06A0300	Livingston Electrical Assoc. Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	406-410 East 79th Street New York NY	Approved	\$650.00
47243	06A0304	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Claremont Square 36 East 14th Street New York NY	Hold	\$650.00
Fire pump feed must be taken from the Con-Ed box.						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47244	06A0306	Douglas Paskor, Inc. 248 Nassau Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Brooklyn Renaissance Plz,LLC 350 Jay Street Brooklyn NY	Approved	\$650.00
Relocated 800 amp service switch.						
47245	06A0308	Jusler Electrical Corp. 2616 Skillman Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The Kimpton Hotel 70 Park Avenue New York NY	Approved	\$650.00
47246	06A0310	Colony Electric Company Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	555 West 59th Street New York NY	Approved	\$650.00
47247	06A0314	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	735 6th Avenue New York NY	Approved	\$650.00
47248	06A0312	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	729 7th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47249	06A0323	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	50 Court Street Brooklyn NY	Hold	\$650.00
1) Manufacturers cut sheets of equipment not provided. 2) Bus size in Con-Ed box not provided. 3) Verify length of service entrance conductors. 4) Provide supplemental ground. 5) Provide details of service room (elevations). 6) Provide signage in each service room.						
47250	06A0316	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Home Depot 75-09 Woodhaven Blvd Queen NY	Ok, but	\$650.00
Fire pump feeder undersized.						
47251	06A0318	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Home Depot 2501 Forest Avenue Staten Island NY	Approved	\$650.00
47252	06A0322	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Con Edison Van Nest Station 1610 Matthews Avenue Bronx NY	Hold	\$650.00
1) Key interlock scheme not provided. 2) No coordination between 3000A main and 3000A 2nd level breaker. Show 3rd level. 3) Confirm front accessible equipment . 4) Provide section views. 5) Provide code clearances in front of equipment.						
47253	06A0320	Levinson & Santoro Electric Corp. 20-16 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	IS 10/PS 200 2581/2589 7th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47254	,	Jata Electrical Construction Corp. 16 West 36th Street, 10th Floor New York NY 10018	Requesting permission to install a seventh service switch where one of the switches will power a fire pump.	137 Duane Street New York NY	Approved	\$0.00
47255	,,	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requesting permission to install a seventh service switch where one of the service switches powers a special service fire pump.	20 West 55th Street New York NY	Approved	\$0.00
47256	,,,	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requesting concept approval to allow Schedule 80 non metallic conduit as a underground wiring method for service entrance conductors that will run approximately 100 feet into a building.	101 East 10th Street New York NY	Approved	\$0.00
With the stipulation that all stup ups and elbows are metallic.						
47257	,,,,	Watts Your Problem Electric 30-91 12th Street Long Island City NY 11102	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit for three buildings(1-2 family and 2-3 family) located in a corrosive area, Far Rockaway, Queens.	133 Beach 11th St. and 29-14 Brooha Far Rockaway NY	Approved	\$0.00
47258	,,,,,	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to install a second overhead service on the outside of eight single family dwellings to provide power for private street lighting, the services will not be grouped together signage will be provided at each service indicating where the other service is located.	25,37,48,56,78,86 and 96 Gwenn Lo Staten Island NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47259	WB Engineers Consultants PLLC 110 William Street New York NY 10038	Requesting permission to install a 100 amp disconnect switch painted red, pad locked in the closed position and permanently labeled "fire alarm power supply do not disconnect" in lieu of an 90 amp fuse cut-out that will power a fire alarm system.	137-34 Northern Blvd. Flushing NY	Approved	\$0.00
With the stipulation that approval is subject to other jurisdictions.						
47260	I.S.M. Electric Contractor Inc. 512 73rd Street Brooklyn NY 11209	Requesting permission to install kitchen counter receptacles 22 inches above the counter instead of the required 20 inches in a building that has 29 apartments.	163 West 18th Street New York NY	Denied	\$0.00
47261	Flack and Kurtz 475 Fifth Avenue New York NY 10017	Requesting permission to wire a fire alarm system that was filed under the old New York City Electrical Code Bulletin #134 and RS17-3A, RS17-5 of the New York City Building Code on a installation that was presently violated by the New York City Fire Department	New Bronx Criminal Courthouse 231-265 East 161st Street Bronx NY	Hold	\$0.00
Bulletin #134 is for the entire fire alarm system not partial. The buildings classification requires an entire fire alarm system not a partial system. "More information needed".						
47262	Up Town Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requesting permission to leave as installed a fire alarm fuse cut-out in a weatherproof enclosure mounted on the outside of a commercial building grouped together with the existing service equipment.	Olive Garden 505 Gateway Drive, Ground Floor Brooklyn NY	Approved	\$350.00
47263	Jeminis Electrical Contractors, Inc. 122-11 18th Avenue College Point NY 11356	Requesting permission to leave as installed exhaust hoods connected to small appliance branch circuits in a multi dwelling with 80 apartments	1669 University Avenue Bronx NY	Denied	\$350.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47264	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requesting permission due to lack of space inside of the existing service room to install a new 800 amp service outside of the service room, signage will be provided at each service indicating where the other service is located.	216 East 99th Street New York NY	Approved	\$350.00
47265	Matros Automated Electl Constn. Corp. 214 West 29th Street New York NY 10001	Requesting permission to install a demand controller device in a residential dwelling where 2 apartments were combined into one, the existing feeders are undersized and the owner won't allow new feeders to be installed	Central Park W. Apts. Nos. 25D & 2 New York NY	Denied	\$0.00
Section 215.2(A)(1) requires that the feeder conductors shall have an ampacity not less than required to supply the load served. The feeder conductors shall be sized so that the maximum voltage drop at the last overcurrent device does not exceed 3% and the total maximum conductors to the last outlet does not exceed 5%.						
47266	J.M. Electrical Corp. 122 East 42nd Street New York NY 10168	Requesting permission to replace the defective interior of a 3000 amp 120/208V service switch with a new interior	122 East 42nd Street New York NY	Approved	\$0.00
with the stipulation that the installation complies with Article 408 of the 2002 NEC and local amendments.						
47267	06A0324	Inncom, International 277 West Main Street Niantic CT 06357	Requested approval for use in New York City of your S217 Line-voltage Light Switch with low-voltage P564 DND/MUR/Chime in voltage separated double-gang box. Model/Series Numbers: S217 1R light switch, PN: 01-9603; P564 DND/MUR/Chime, PN: 01-9825.3.		Approved	\$200.00
Concept only						

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47268	06A0325	BTicino USA 2800 De La Cruz Blvd. Santa Clara CA 95050	Requested approval for use in New York City of your Low voltage lighting control system and/or European-style Wiring Devices for use in single residence. Model/Series Numbers: "My home Comfort Automation" Cat. and/or N4001, N4003, N4188GF, N44402, N4703 and N4803.		Denied	\$200.00

Product must be listed by a Nationally Recognized Testing Laboratory as a complete assembly.