

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46083CO	04A0546CO	A to Z Electl Maint. & Service Corp. 307 Seventh Avenue, Suite 403 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	438 West 19th Street New York NY	Approved	\$0.00
Carry over from December 15, 2004 meeting.						
46107CO	04A0561CO	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	800 Second Avenue New York NY	Ok, but	\$0.00
Carry over from January 12, 2005 meeting. Abandoned service switch must be disabled.						
46348CO	05A0230CO	Al s Best Electric Co., Inc. 915 Broadway, Suite #607 New York NY 10010	Requested approval for the electric service equipment proposed to be installed	210 11th Avenue New York NY	Approved	\$0.00
Carry over from May 25, 2005 meeting.						
46351CO	05A0234CO	Heso Electrical Inc. 33-06 Ditmars Blvd. Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	200 Willoughby Avenue Brooklyn NY	Approved	\$0.00
46407	05A0244	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NYC Housing Authority 10-20 Beach Channel Drive-Bldg. #1 Queens NY	Hold	\$650.00
1) Provide short circuit amps and impedance. 2) Service conductors undersized. 3) Feeder to "AFDP-1" undersized. 4) Justify reduced neutral fire panel "BRP". 5) Remove reference to bulletin 124 add reference to current NYCEC. 6) Clarify arrangement of service end box/P.O.E.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46408	05A0245	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NYC Housing Authority 453 Beach 40th St.-Bldg. #3 Queens NY	Hold	\$650.00
1) Provide short circuit amps and impedance. 2) Service conductors undersized. 3) Feeder to "AFDP-1" undersized. 4) Justify reduced neutral fire panel "BRP". 5) Remove reference to bulletin 124 add reference to current NYCEC. 6) Clarify arrangement of service end box/P.O.E.						
46409	05A0246	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	152 West 25th Street New York NY	Approved	\$650.00
46410	05A0247	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	89-63 163rd Street Jamaica NY	Ok, but	\$650.00
^Fire alarm requires fuse cut-out(not disconnect switch).						
46411	05A0248	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	USTA Tennis Center Flushing NY	Approved	\$650.00
Justify bus sizing ins existing service switchboard						
46412	05A0249	Stanco Systems Electrical Contrg, Inc. 4061 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	50 West 34th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46413	05A0250	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Fit Residence Hall 406 West 31st Street New York NY	Approved	\$650.00
1) Eliminate fuse cut-out on 208V side of fire alarm XFMR. 2) Confirm fire pump XFMR located in service room. 6/27/05 job finalized.						
46414	05A0251	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Ed Sullivan Theater 1680 Broadway New York NY	Approved	\$650.00
46415	05A0252	Pabst Electric Company Incorporated 45-48 51st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	205 East 42nd Street New York NY	Approved	\$650.00
46416	05A0253	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	752 Pacific Street Brooklyn NY	Approved	\$650.00
46417	05A0254	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Helena 601 West 57th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46418	05A0255	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Century 21 Department Store 22 Cortland Street New York NY	Approved	\$650.00
46419	05A0256	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	HSBC Atlantic Terminal 2 Hanson Place Brooklyn NY	Approved	\$650.00
46420	05A0257	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	325 5th Avenue New York NY	Hold	\$650.00
1) Provide reduced neutral calculations. 2) XFMR for auto fire pump undersized. 3) Secondary conductors of 1000 KVA XFMR undersized. 4) Neutral conductors not required for fire pump feeders. 5) Provide 3 ft clearance both sides of MS-A.						
46421	05A0258	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	15 Broad Street New York NY	Approved	\$650.00
1) Clarify existing XFMR grounding. 2) Confirm adequate interrupting rating of bus duct circuit breakers. 6/22/05 job finalized.						
46422	05A0259	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	St. Barnabas 183rd Street & 3rd Avenue Bronx NY	Denied	\$650.00
1) The service entrance conductors feeding the 2000 amp service switch are undersized. 2) The feeders on the load side of the 2000 amp service switch are undersized.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46423	05A0260	Switch Electric Co., Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	18 West 48th Street New York NY	Approved	\$650.00
46424	05A0261	Stanco Systems Electrical Contrg, Inc. 4061 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	NYSCA New High School 49 Flatbush Avenue Brooklyn NY	Approved	\$650.00
1) Provide bus size in EMPD panel. 2) Provide supplemental ground. 6/22/05 job finalized.						
46425	05A0262	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	850 Grand Avenue Brooklyn NY	Approved	\$650.00
46426	05A0263	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	I.S. 2 333 Midland Avenue Staten Island NY	Approved	\$650.00
46427	05A0264	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bowery Bay WPCP 45-41 Berrian Boulevard Queens NY	Approved	\$650.00
1) Provide complete submission for low voltage substations. 2) Indicate MCC's to be removed (ref. Comment in short circuit study). 6/22/05 job finalized.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46428	05A0285	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Mutual Redevelopment Houses 321 Eight Avenue New York NY	Hold	\$650.00
1) Verify Advisory Board approval of previous installations. 2) Appear at next meeting to discuss intent.						
46429	05A0288	Hal Electrical Contractors Inc. 32 East 31st Street, Suite 812 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	810 East 152nd Street Bronx NY	Approved	\$650.00
1) Provide series ratings of circuit breakers or calculations. 2) Provide physical of panels manufacturers. 3) Show bonding of fuse cutout and size and type of fuses.						
46430	05A0290	Up Town Electric, Inc 5-28 47th Road, Long Island City, NY 11101	Requested approval for the electric service equipment proposed to be installed	2900 Veterans Parkway West Staten Island NY	Hold	\$650.00
1) Advisory Board rules require only an electrical contractor or consulting engineer to submit application to the Advisory Board. 2) Justify general note #5(200KA). 3) Generator in same room as service not submitted.						
46431	05A0297	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	4 West 21st Street New York NY	Approved	\$650.00
46432	05A0265	Alco Electric, LLC 5790 Broadway Bronx NY	Requested approval for the electric service equipment proposed to be installed	180-190 72nd Street Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46433	05A0267	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	11 East 26th Street New York NY	Approved	\$650.00
46434	05A0268	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	44 West 18th Street New York NY	Approved	\$650.00
46435	05A0269	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	425 Park Avenue South New York NY	Approved	\$650.00
46436	05A0270	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	32 Trinity Place aka 42 Trinity Place New York NY	Approved	\$650.00
46437	05A0271	New Grand Electric Inc. 71-73 Allen Street #302 New York NY 10002	Requested approval for the electric service equipment proposed to be installed	224 West 30th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46438	05A0272	M & R Electl Contg and Repair Servs. Inc. 149 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	416 West 13th Street New York NY	Approved	\$650.00
3000A service switch can be moved into generator room. Job finalized 6/22/05.						
46439	05A0273	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gramercy Park Hotel #2 Lexington Avenue New York NY	Approved	\$650.00
46440	05A0274	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	55 Central Park West New York NY	Approved	\$650.00
46441	05A0275	Cedar Electrical Contractors, Inc. 325 East 41st Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	1100 Park Avenue New York NY	Approved	\$650.00
46442	05A0276	H.P. Electric Design Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	310 East 53rd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46443	05A0277	Cedar Electrical Contractors, Inc. 325 East 41 Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	1160 Park Avenue New York NY	Approved	\$650.00
46444	05A0278	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Montefiore Medical Center 3450 Wayne Avenue Bronx NY	Approved	\$650.00
46445	05A0279	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	119 East 23rd Street New York NY	Approved	\$650.00
46446	05A0280	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	5 Hanover Square New York NY	Approved	\$650.00
46447	05A0281	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	45-01 Northern Blvd. Long Island City NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46448	05A0282	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	119-49 Union Turnpike Forest Hills NY	Approved	\$650.00
46449	05A0283	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	150 East 61st Street New York NY	Approved	\$650.00
46450	05A0284	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	1 Liberty Plaza New York NY	Approved	\$650.00
46451	05a0286	B & G Electrical Contractors 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Stop & Shop Retail 89-89 Union Turnpike Forest Hills NY	Approved	\$650.00
46452	05A0287	Judd Electric Inc. 1097 Second Avenue-Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	1412 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46453	05A0289	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	527 W. 42nd St. aka 621 W. 42nd St. New York NY	Approved	\$650.00
1. Provide reduced neutral calculations. 2) Change fuses to 150 amp in service switch for fire pump.						
46454	05A0291	Positive Electrical Associates Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Med. Ctr Nurses Res. 1400 Pelham Parkway South Bronx NY	Denied	\$650.00
1) The manufacturer information for the generator was not provided.. 2) Automatic transfer switch not labeled 3 or 4 pole on drawing. 3) Manufacturer's physical drawing of equipment not provided. 4) Main disconnect for generator not provided. 5) There is no coordination between the 1600 and 1200 amp switches. 6) Protection not provided on line and load sides of transformer. 7) Information on what the ATS is feeding was not provided. 8) AIC at circuit breakers not provided.						
46455	05A0292	Charan Electrical Enterprises Inc. 2714 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYCHA Audobon Apartment 1909 Amsterdam Avenue New York NY	Approved	\$650.00
1) Provide neutral to enclosure bonds on service switches. 2) Provide supplemental ground.						
46456	05A0293	All Pro Electric of New York, Inc. 166 E. Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Pergament Properties Mall 2795 Richmond Avenue Staten Island NY	Approved	\$650.00
46457	05A0294	DiFazio Electric NY, Inc. P.O. Box 140219 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 125 West 23rd Street New York NY	Ok, but	\$650.00
1) Correct address. 2) Bond new service switch.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46458	05A0295	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	25 West 51st Street New York NY	Denied	\$650.00
1) The service bus is undersized. Should be 4-1/4"x6". 2) Fusing size and type for service switches are not shown on drawing. 3) Bonding and grounding of service switches are not shown on drawing. 4) 1200 amp protection on 1000 amp ATS is oversized. 5) Service entrance conductors feeding the 200 amp service switch are undersized. 6) Grounding of generator frame not provided. 7) Vertical bus undersized. 8) One line drawing not submitted in complete Advisory Board format.						
46459	05A0296	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Restaurant Deport 4340 57th Avenue Queens NY	Denied	\$650.00
1) One line diagram not submitted in Advisory Board format. 2) The service bus is undersized. 3) An 800A fuse cut out is used as service switch. 4) The feed to the fire pump is not fire rated. 5) Fusing size and type not provided. 6) Neutral bonds are not shown on one line drawing. 7) Full load amperage of fire pump not shown on one line drawing. 8) The physical drawings of equipment does not match the service room layout.						
46460	-	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requesting permission not to file Advisory Board drawings where 4 existing 27 KV conduit duct banks are being replaced and slightly relocated from manhole to manhole.	St. John's University 8000 Utopia Parkway Queens NY	Approved	\$0.00
46461	*	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requesting permission due to a high water level to install a 6" tall trough on the floor with sloped concrete sides painted yellow on a previously approved Advisory Board job showing underground trough Cal. #46165.	230 Park Avenue New York NY	Denied	\$0.00
46462	***	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to leave as installed 120 volt underwater lighting that is ground fault protected.	Green Wood Cemetary Brooklyn NY	Denied	\$350.00
Article 680, Sections 680-.230 and 680.51(B) of New York City's Amendments to the NEC require that all luminaires shall be operated at 15 volts or less between conductors.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46463	****	A.J. Ianni Electrical Contractor, Ltd. 1402-B Blondell Avenue Bronx NY 10461	Requesting permission due to hardship to correct and lack of space inside of the service room to leave as installed a seventh service switch in a commercial building without a fire pump.	133 Canal Street New York NY	Hold	\$0.00
Provide room layout and one line diagram						
46464	*****	Lilker Associates Consulting Engs. P.C. 10001 Avenue of the Americas New York NY 10018	Requesting permission due to lack of space inside the 19th floor electrical closet to install a 800 amp GE busway circuit breaker tap switch rated at 65,000 AIC in lieu of 2 400 amp plug in disconnect switches with FRN 400 amp fuses. See Cal. #46261 and attached short circuit calculations.	1359 Broadway, 19th & 20th Floors New York NY	Approved	\$0.00
With the stipulation that 2 copies of revised one line drawings showing the changes is forwarded to the Advisory Board Chairman.						
46465	*****	Robert Derecor Associates 19 West 44th Street New York NY 10036	Requesting permission to install electrical equipment 4 feet beneath existing ductwork, the total height from the floor to the bottom of the ductwork will be 11 feet 3 inches.	Wachovia Securities 375 Park Avenue New York NY	Approved	\$0.00
46466	*****	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requesting permission to leave in place the existing Con-Ed box due to space restrictions.	45-01 Northern Blvd. Long Island City NY	Approved	\$0.00
46467	*****	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requesting permission to install a seventh service switch where one of the existing service switches powers a fire pump.	Montefiore Medical Center 3450 Wayne Avenue Bronx NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46468	**	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to leave as installed on building located in a corrosive area, Far Rockaways, Schedule 80 PVC conduit standpipes.	183 thru 199 Beach 29th Street Far Rockaway NY	Approved	\$350.00
46469	*****	J.P.E. Electrical Contractors, Inc. 7426 Amboy Road Staten Island NY 10307	Requesting permission to install two 400 amp service switches on the outside of a commercial building that does not have any common area.	680 Sharrotts Road Staten Island NY	Denied	\$0.00
This installation does not conform with the tap rules in Article 240.						
46470	*****	Ramdeen s Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to leave as installed service equipment that is not grouped together in a commercial building without any common area.	14-02,114-04&114-06 Farmers Blvd Queens NY	Approved	\$350.00
With the stipulation that signage is provided at the outdoor meters and indoor service switches indicating where the other services are located.						
46471	05A0298	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Abak Line of Modular Systems Office Furnishings. Model/Series Numbers: Frame: AK110, HHWWX; Power Entry Box AK130.WW; AK131. WW Power Harness Kit; AK132 Access Zone Power Harness.		Hold	\$200.00
1) AK 132, port cover must be metal in accordance with the New York City Electrical Code. All covers shall be metal. 2) Follow the guideline for office furnishings.						
46472	05A0299	Modulight LLC 1300 South Wolf Road Des Plaines IL 60017	Requested approval for use in New York City of your Energy and Labor Saving Wiring System.		Approved	\$200.00
With the stipulation that the luminaires must comply with New York City's amendments to the National Electrical Code, Section 410.40.						

ADVISORY BOARD CALENDAR

June 15, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46473	05A0266	Alco Electric, LLC 5790 Broadway Bronx NY	Requested approval for the electric service equipment proposed to be installed	181-191 73rd Street Brooklyn NY	Approved	\$650.00