

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45419CO3	04A0017CO3	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Random House 235 West 55th Street New York NY	Hold	\$0.00
Carry over from the January 14, 2004 meeting. Appear at next Advisory Board meeting.						
45452CO	04A0034CO	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Hold	\$0.00
Carry over from February 18, 2004 meeting.						
45585CO2	04A0142CO2	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environ. Protection 593 East 132nd Street Bronx NY	Hold	\$0.00
Carry over from April 14, 2004 meeting. 1) Provide junction box for fire and jockey pump. 2) MI an emergency side feeding fire pump not required by Code. 3) Clarify rotation on fire and jockey pump (2 pole). 4) Short circuit study recommendation shall be considered.						
45586CO2	04A0143CO2	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environ. Protection 432 East 110th Street New York NY	Hold	\$0.00
Carry over from April 14, 2004 meeting.						
45626CO	04A0182CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Story Avenue High School  Bronx NY	Ok, but	\$0.00
Carry over from May 19, 2004 meeting. Generator neutral shall not be grounded(3P/solid N ATS).						

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45635CO	04A0215CO	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	27 Murray Street New York NY	Approved	\$0.00
Carry over from May 19, 2004 meeting. With the stipulation that the splice for the jockey pump be made in a junction box ahead of the fire pump controller.						
45668CO	04A0195CO	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Bloomberg 731 Lexington Avenue New York NY	Hold	\$0.00
Carry over from May 19, 2004 meeting.						
45685CO	04A0230CO	Illuminous Electric Inc. 1425 37th Street Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	739 East New York Avenue Brooklyn NY	Hold	\$0.00
Carry over from May 19, 2004 meeting. Run portable sets to last panelboard.						
45712	04A0248	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Staten Island Boat Sales 222 Mansion Avenue Staten Island NY	Approved	\$650.00
45713	04A0249	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	AIG 70 Pine Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45714	04A0250	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00
Submit coordination study for record.						
45715	04A0251	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	60 Broadway Brooklyn NY	Approved	\$650.00
45716	04A0252	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Pierpont Morgan Library 29 East 36th Street New York NY	Ok, but	\$650.00
1) CU bus to be sized per Code, Section #2:2-3x1/4 = 1500A, need 1600A. 2) Indicate voltage rating of fire pump XFMR. 3) Must resubmit for addition of 500KVA XFMRs in future.						
45717	04A0253	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	96 Spring Street New York NY	Approved	\$650.00
45718	04A0254	Jeminis Electrical Contractors, Inc. 122-11 18th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Manhattanville Houses 530 West 133rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45719	04A0255	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requested approval for the electric service equipment proposed to be installed	242-248 East 25th Street New York NY	Ok, but	\$650.00
Modify entrance so one does not enter service room to access telephone room.						
45720	04A0256	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NYS Liquidation Bureau 123 William Street New York NY	Approved	\$650.00
45721	04A0257	GMA Electrical Corp. 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Adam Housing Projects 710 Tinton Avenue Bronx NY	Approved	\$650.00
Confirm Con Ed service capacity does not exceed 4000A. 6/16/04 job finalized.						
45722	04A0258	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 4 Metrotech Center Brooklyn NY	Approved	\$650.00
Provide key interlocks for main-tie-main on UPS input bypass switchboard.						
45723	04A0259	A & S Electric Inc. 45 East 7th Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	372 Fifth Avenue-Bsmt New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45724	04A0260	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	One State Street Plaza New York NY	Approved	\$650.00
45725	04A0261	Salavatore Campisi & Sons Elecl Conts, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	519 8th Avenue New York NY	Approved	\$650.00
45726	04A0262	YS Electric 39-39 63rd Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	35 West 33 Street New York NY	Approved	\$650.00
45727	04A0263	Qnce Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Eldorado Apts 300 Central Park West New York NY	Approved	\$650.00
45728	04A0264	Judd Electric Inc. 1097 Second Avenue-Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	1441 Broadway New York	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45729	04A0265	Adelante Electrical Company, Inc. 137-11 Booth Memorial Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	NYC Police Academy 205 E. 20th Street New York NY	Approved	\$650.00
45730	04A0266	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1115 Broadway New York NY	Approved	\$650.00
45731	04A0267	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	1995 Broadway New York NY	Approved	\$650.00
45732	04A0268	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	45-25 Kissena Boulevard Flushing NY	Approved	\$650.00
45733	04A0269	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	1010-1032 E. 163rd Street Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45734	04A0270	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	30-48 Linden Place Flushing NY	Approved	\$650.00
45735	04A0271	Samco Electric Corp 12-24A 30th Avenue Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	South Bronx H.S. 639 St. Anns Avenue Bronx NY	Approved	\$650.00
45736	04A0272	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	32-00 Skillman Avenue Long Island City NY	Approved	\$650.00
45737	04A0273	Bass Electric Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	45-10 94th Street Corona NY	Approved	\$650.00
45738	04A0274	CMS Electrical Services Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Starbuck's 4 Columbus Circle New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45739	04A0275	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	2075 Second Avenue New York NY	Approved	\$650.00
45740	04A0276	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	421 7th Avenue New York NY	Approved	\$650.00
45741	04A0277	J.A. Lee Electric Co. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	284 Mott Street New York NY	Approved	\$650.00
45742	04A0278	UL Electrical Corp. 115-05 Liberty Avenue, 2nd Floor Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	Beth Rivkah School 470 Lefferts Avenue Brooklyn NY	Approved	\$650.00
What is transfer for? If for life safety build wall in service room. Item finalized 12/15/04.						
45743	04A0279	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	S.I. Children's Museum 1000 Richmond Terrace Staten Island NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45744	04A0280	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 300 Cadman Plaza West Brooklyn NY	Ok, but	\$650.00
1) Submit UPS switchboard cuts and coordination study. 2) Submit generator and generator main breaker cuts.						
45745	04A0282	Rothstein & Hoffman Electric Service, Inc 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	79-29 Albion Avenue Flushing NY	Approved	\$650.00
1) Change feed to 2000A SS to 6-set 500. 2) Provide supplemental ground and water ground lug.						
45746	.....	Lizardos Engineering Associates, P.C. 200 Old Country Road Mineola NY 11501	Requesting permission whether to file Advisory Board drawings where work will be performed at Long Island Jewish Medical Center where the existing service is located in Queens, NY and the portion of work which includes the replacement of a 5KV switch and transformer is located in Nassau County, NY	North Shore-LIJ Health Sys.  New Hyde Park NY	Approved	\$0.00
45747	--	All City Switchboard Corp. 35-41 11th Street Long Island City NY 11106	Requesting permission to terminate the neutral of the transformer secondary and the neutral of the utility source together and to utilize a 3 pole automatic transfer switch for a dual fed load.	75 Ninth Avenue New York NY	Approved	\$0.00
With the stipulation that the neutral conductor must be routed together with the other phase conductors and must be terminated in the automatic transfer switch.						
45748	----	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting concept approval on a service upgrade to replace 60 feet of existing service entrance wireway with barriers and the conductors not bundled together in sets causing inductive heating, and replace it with a new wireway without barriers and the sets of conductors bundled in a fire rated service room.	1440 Broadway New York NY	Approved	\$0.00
Concept approval is acceptable with the stipulation that the service entrance wireway is isolated by a doorway and full Advisory Board drawings must be submitted in the future.						

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45749	----	Atria 2000 Associates, LLC 158-13 72nd Avenue Flushing NY 11365	Requesting permission to leave as installed unprotected aluminum conduits that penetrate through a concrete slab into the bottom of an 1000 KVA switchboard.	159-10 72nd Avenue Flushing NY	Denied	\$0.00
Section 344.10(A) of the New York City Electrical Code and Underwriter Laboratory standard DYWV prohibit aluminum conduit to be installed in concrete or in contact with soil unless supplementary corrosion protection is applied.						
45750	-----	Powerhouse Electrical Contractors, Inc. 224 Great Kills Road Staten Island NY 10308	Requesting permission on a commercial building to install a new combination panel on the outside of the building and not group it together with the existing service switches located inside the building.	1259 Richmond Avenue Staten Island NY	Denied	\$0.00
The New York Electrical Code Section 230.72(A) requires that the service disconnects be grouped together. Section 230.70(A) requires the service disconnects for a commercial building to be located inside.						
45751	-----	Bayside Electrical Contractor Corp. 40-18 31st Avenue Astoria NY 11103	Requesting permission to leave as installed service equipment that feeds power from one building through another in a commercial building.	212 West 233rd Street Bronx NY	Denied	\$0.00
Section 230.3 of the New York City Electrical Code states that service conductors supplying a building or other structure shall not pass through the interior of another building or other structure.						
45752	-----	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requesting permission to run a 20 HP fire pump normal and emergency feeder in electrical metallic tubing in a J-Z(assisted independent living) occupancy.	71-61 159th Street Queens NY	Approved	\$0.00
With the stipulation that revised Advisory Board drawings are submitted.						
45753	-----	Lens Electric, Inc. 2802 Avenue Y Brooklyn NY 11235	Requesting permission due to lack of space inside the service room to leave as installed service equipment that is not grouped together in a commercial building.	141-08 84th Drive Queens NY	Approved	\$0.00
Code 230.72(A) With the stipulation that signage is provided at each service indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45754	-----	Candela Systems Corporation 148 Route 202 Somers NY 10589	Requesting permission to install power packs for a low voltage sensor system inside of circuit breaker panels throughout a school.	S.U.N.Y F.I.T.  New York Ny	Denied	\$0.00
Section 725.55 of the New York City Electrical Code prohibit power, Class 1, 2 and 3 wiring systems to be installed in the same raceway or device box.						
45755	-----	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requesting permission on a previously approved Advisory Board drawing to leave as installed a seventh 200 amp service switch.	230 West 55th Street New York NY	Approved	\$0.00
45756	---	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requesting permission to waive fuse coordination and selectivity on the emergency side of a 1000 KVA service.	JP Morgan Chase 4 Metrotech Center Brooklyn NY	Approved	\$0.00
45757	-----	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requesting permission to install cable TV termination boxes in 3 electrical closets.	63 Wall Street New York NY	Hold	\$0.00
Pending code correction.						
45758	----	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requesting permission to install two 208 volt air conditioning receptacles on one 20 amp circuit breaker in seventy units, each A/C is a maximum of 6.9 amps.	300 West 20th Street New York NY	Denied	\$0.00
Sections 210.52(I) and 220.16 ( c ) of the New York City's Electrical Code amendments prohibit the installation of two air conditioner receptacles on a single circuit.						

# ADVISORY BOARD CALENDAR

**June 16, 2004**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45759	-----	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission not to install receptacle outlets on a kitchen island that is solid stone.	650 West End Avenue New York NY	Approved	\$0.00
45760	04A0281	Starfire Lighting 7 Donna Drive Wood Ridge NJ 07075	Requested approval for use in New York City of your Recessed Lighting . Model/Series Number: Versalux.		Approved	\$200.00