

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee    |
|--|--------------|---|--|---|----------|--------|
| 49107CO3   | 08A0562CO3   | Tru-Val Electric Corporation<br>2550 Park Avenue<br>Bronx NY 10451                  | Requested approval for the electric service equipment proposed to be installed | Red Hook Water Pollution Plant<br>63 Flushing Avenue<br>Brooklyn NY | Approved | \$0.00 |
| Carry over from November 18, 2009 meeting.   |              |   |  |   |          |        |
| 49829CO  | 09A0487CO    | Danco Electrical Contractor, Inc.<br>40-17 24th Street<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Jacobi Medical Center<br>1400 Pelham Parkway South<br>Bronx NY      | Hold     | \$0.00 |
| Carry over from November 18, 2009 meeting. 1) Spare breakers to be noted spare. 2) Feeders are overfused. 3) Chart ratings do not match 1-Line, no charts to be used in the future. 4) Switchgear layout to comply with 230.64 clearances. 5) Show ductwork for generator. 6) Portable generator to have permanent disconnecting means in or outside of building with fusing. 7) Coordination study not complete. 8) Provide door between generator board. 9) Show emergency loads for life safety. 10) Show 3 or 4 pole ATS'. 11) Provide key interlock system. Permanent and temp. breakers. |              |   |  |   |          |        |
| 49957CO  | 10A0058CO    | Global Electrical Contr. of Westchester, Inc<br>4065 Boston Road<br>Bronx NY 10466  | Requested approval for the electric service equipment proposed to be installed | Harlem Hospital<br>506 Lenox Avenue<br>New York NY                  | Hold     | \$0.00 |
| Carry over from February 10, 2010 meeting. 1) 1000 KVA secondary breaker 1200 amp to 3000 amp breaker. 2) Include drawing SSL-3294.  |              |   |  |   |          |        |
| 50035CO  | 10A0105CO    | Qncc Electrical Contracting Corp.<br>86-40 122nd Street<br>Richmond Hill NY 11418   | Requested approval for the electric service equipment proposed to be installed | Americana Apartments<br>17-85 215th Street<br>Bayside NY            | Approved | \$0.00 |
| Carry over from April 14, 2010 meeting.  |              |   |  |   |          |        |
| 50098CO  | 10A0160CO    | Fas Electrical Contractors Inc.<br>78-10 67th Drive<br>Middle Village NY 11379      | Requested approval for the electric service equipment proposed to be installed | VBC Industries<br>156 Sandford Street<br>Brooklyn NY                | Hold     | \$0.00 |
| Carry over from May 19, 2010 meeting. 1) Change 750KVA transformer to delta Y. 2) MCC load to be 3 phase 3W. 3) Ground neutral in cogen switchboards.  |              |   |  |   |          |        |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status                 | Fee      |
|---|--------------|---|--|--|------------------------|----------|
| 50105CO   | 10A0167CO    | Platinum Electrical Contracting Inc.<br>478 Wild Avenue<br>Staten Island NY 10309 | Requested approval for the electric service equipment proposed to be installed | Internap<br>75 Broad Street<br>New York NY                   | Approved               | \$0.00   |
| Carry over from May 19, 2010 meeting. 1) Maximize inst. trip on 2000A and 2500A generator breakers. 2) Provide interlocks to prevent paralleling. Job finalized 6/28/10.  |              |   |  |  |                        |          |
| 50111CO   | 10A0173CO    | Verde Electric Corp.<br>1402 Blondell Avenue<br>Bronx NY 10461                    | Requested approval for the electric service equipment proposed to be installed | Public Safety Answering Ctr<br>1200 Waters Place<br>Bronx NY | Hold                   | \$0.00   |
| Carry over from May 19, 2010 meeting.   |              |   |  |  |                        |          |
| 50118CO   | 10A0180CO    | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416            | Requested approval for the electric service equipment proposed to be installed | Lowe's Kings Plaza<br>5100 Kings Plaza<br>Brooklyn NY        | Approved               | \$0.00   |
| Carry over from May 19, 2010 meeting.   |              |   |  |  |                        |          |
| 50130CO   | 10A0192CO    | Hugh O Kane Electric Company, Inc.<br>90 White Street<br>New York NY 10013        | Requested approval for the electric service equipment proposed to be installed | National Sept. 11 Memorial<br>New York Ny                    | Hold                   | \$0.00   |
| Carry over from May 19, 2010 meeting.   |              |   |  |  |                        |          |
| 50149   | 10A0197      | Pinnacle Electric<br>130-45 91st Avenue<br>Richmond Hill NY 11418                 | Requested approval for the electric service equipment proposed to be installed | 470 Vanderbilt Avenue<br>Brooklyn NY                         | Administrative Closure | \$650.00 |
| 1) Switchboard "A" no fuse coordination 3000 and 2500. 2) Switchboard "B" no fuse coordination 3000 and 2500. 3) Confirm HT of air duct on side of service switchboards. This drawing voided see resubmitted drawing Cal. #50637. |              |   |  |  |                        |          |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #   | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                       | Status   | Fee      |
|--|--------------|--|--|---|----------|----------|
| 50150  | 10A0198      | JMC Electric Corp.<br>172-02 39th Avenue<br>Flushing NY 11358                        | Requested approval for the electric service equipment proposed to be installed | 54-44 Little Neck Parkway<br>Little Neck NY | Approved | \$650.00 |
|  |              |  |  |   |          |          |
| 50151  | 10A0199      | JMC Electric Corp.<br>172-02 39th Avenue<br>Flushing NY 11358                        | Requested approval for the electric service equipment proposed to be installed | 10 Monroe Street<br>New York NY             | Approved | \$650.00 |
| 1) Verify length of #8 tapped conductor. 2) 3/0 feeder fused at 225 amps. 3) Where is new 200 amp disconnect located? 4) Neutral required for 3 phase meter. 5) Verify from Con-ED that meter can be installed after the service switch. 6) AIC not provided. 7/30/13 job finalized. |              |  |  |   |          |          |
| 50152  | 10A0200      | JMC Electric Corp.<br>172-02 39th Avenue<br>Flushing NY 11358                        | Requested approval for the electric service equipment proposed to be installed | 370 Park Avenue<br>New York NY              | Approved | \$650.00 |
| 1) Verify that meter can be installed after the service switch. 2) Cut sheet of new panel not provided. 3) AIC not provided. 7/29/13 job finalized.  |              |  |  |   |          |          |
| 50153  | 10A0201      | JMC Electric Corp.<br>172-02 39th Avenue<br>Flushing NY 11358                        | Requested approval for the electric service equipment proposed to be installed | 40 Worth Street<br>New York NY              | Approved | \$650.00 |
| 1) AIC not provided. 2) 3 phase meter to have neutral conductor. 3) Second fusing not shown. 4) Short circuit calculations not provided for panel that is 2nd fusing. 5) Provide overcurrent protection for portable generator connection. 7/29/13 job finalized.                    |              |  |  |   |          |          |
| 50154  | 10A0202      | Control Electrical Contracting Corp.<br>85 Tompkins Street<br>Staten Island NY 10304 | Requested approval for the electric service equipment proposed to be installed | 63 East 9th Street<br>New York NY           | Approved | \$650.00 |
| Verify tapped conductor length, 10' or 25' tap. Job finalized 7/26/10.   |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #             | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|------------------------|--------------|---|--|--|----------|----------|
| 50155                  | 10A0203      | CRM Electric Corporation<br>461 West 261st Street<br>New York NY 10001          | Requested approval for the electric service equipment proposed to be installed | Myrtle Ave Development<br>218 Myrtle Avenue<br>Brooklyn NY   | Approved | \$650.00 |
|                        |              |   |  |  |          |          |
| 50156                  | 10A0204      | Reliant Electrical Contracting, Inc.<br>628 Classon Avenue<br>Brooklyn NY 11238 | Requested approval for the electric service equipment proposed to be installed | Frederick Douglass Blvd. a.k.a. 2280 E<br>New York NY        | Approved | \$650.00 |
|                        |              |   |  |  |          |          |
| 50157                  | 10A0205      | CRM Electric Corporation<br>461 West 261st Street<br>New York NY 10001          | Requested approval for the electric service equipment proposed to be installed | 10 Westchester Ave. a.k.a 967 Kelly St<br>Bronx NY           | Approved | \$650.00 |
|                        |              |   |  |  |          |          |
| 50158                  | 10A0206      | Hugh O Kane Electric Company, Inc.<br>90 White Street<br>New York NY 10013      | Requested approval for the electric service equipment proposed to be installed | Cobble Hill Health Center<br>380 Henry Street<br>Brooklyn NY | Approved | \$650.00 |
| Job finalized 6/28/10. |              |   |  |  |          |          |
| 50159                  | 10A0207      | Nead Electric, Inc.<br>500 5th Avenue, Suite B-15<br>New York NY 10110          | Requested approval for the electric service equipment proposed to be installed | Soros<br>888 Seventh Avenue<br>New York NY                   | Approved | \$650.00 |
|                        |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee      |
|--|--------------|---|--|---|----------|----------|
| 50160  | 10A0208      | Rockmor Electric Enterprises, Inc.<br>1042 39th Street<br>Brooklyn NY 11219                   | Requested approval for the electric service equipment proposed to be installed | Alexandria<br>450 East 29th Street<br>New York NY                   | Approved | \$650.00 |
|  |              |   |  |   |          |          |
| 50161  | 10A0209      | J.A. Lee Electric, Inc.<br>23-55 Borden Avenue<br>Long Island City NY 11101                   | Requested approval for the electric service equipment proposed to be installed | Pier 36 @ South Street<br><br>New York NY                           | Approved | \$650.00 |
|  |              |   |  |   |          |          |
| 50162  | 10A0210      | Joseph Marchese Electric<br>5801 Amboy Road<br>Staten Island NY 10309                         | Requested approval for the electric service equipment proposed to be installed | 700 Rosewood Street<br>Bronx NY                                     | Hold     | \$650.00 |
| 1) Short cut calculations not provided. 2) Equipment grounding conductors feeding fire pump switch and controller undersized. 3) AIC does not match.   |              |   |  |   |          |          |
| 50163  | 10A0211      | Eric & Ng Electrical Inc.<br>153 Suffolk Street<br>New York NY 10002                          | Requested approval for the electric service equipment proposed to be installed | 7 Main St. a.k.a. 136-20 Roosevelt Pkwy<br>Flushing NY              | Approved | \$650.00 |
|  |              |   |  |   |          |          |
| 50164  | 10A0212      | C.M.S. Electrical Services Co., Inc.<br>306 West 37th Street, 11th Floor<br>New York NY 10018 | Requested approval for the electric service equipment proposed to be installed | Sony Building Gen. Replacement<br>550 Madison Avenue<br>New York NY | Hold     | \$650.00 |
| 1) Set trip on generator breaker to protect (4) 500KMIL/phase?. 2) 1200A trip on norm. breaker feeding ATS #1 too high, 3) Provide Advisory Board approval of existing conditions. 4) Engineer to appear at next meeting |              |   |  |   |          |          |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #   | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|--|--------------|--|--|--|----------|----------|
| 50165  | 10A0213      | Zwicker Electric Co., Inc.<br>360 Park Avenue South<br>New York NY 10010                   | Requested approval for the electric service equipment proposed to be installed | Fiterman Hall<br>30 West Broadway<br>New York NY                               | Approved | \$650.00 |
| 1) Show fuse types on panels. 2) Show main bonding jumper connection on transformer secondary. Job finalized 9/17/10.        |              |  |  |  |          |          |
| 50166  | 10A0214      | Danco Electrical Contractor, Inc.<br>40-17 24th Street<br>Long Island City NY 11101        | Requested approval for the electric service equipment proposed to be installed | Kings County Hospital<br>451 Clarkson Avenue<br>Brooklyn NY                    | Approved | \$650.00 |
| Provide method of ensuring MTS-6 & MTS-7 remains in normal position unless roll-up gen. is connected. Job finalized 9/20/10. |              |  |  |  |          |          |
| 50167  | 10A0215      | Lakhani and Jordan Engineers, P.C..<br>315 Madison Avenue, 10th Floor<br>New York NY 10017 | Requested Concept Approval questions   | City Hall Building Modernization<br>Between Broadway & Park Row<br>New York NY | Approved | \$0.00   |
| 2. a Yes. 3. a Yes. 3b. No.  |              |  |  |  |          |          |
| 50168  | 10A0216      | Delco Electrical Corp.<br>766 Fifth Avenue<br>Brooklyn NY 11232                            | Requested approval for the electric service equipment proposed to be installed | 548 West 22nd Street<br>New York NY  | Approved | \$650.00 |
| Feeders to be derated or use 2 troughs. 12/18/13 job finalized.  |              |  |  |  |          |          |
| 50169  | 10A0217      | Broadway Electric, LLC<br>1261 Broadway, Suite 609<br>New York NY 10001                    | Requested approval for the electric service equipment proposed to be installed | Ace Hotel Oyster Bar<br>16 West 29th Street<br>New York NY                     | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee      |
|--|--------------|---|--|---|----------|----------|
| 50170  | 10A0218      | Arc Electrical Construction Co., Inc.<br>739 Second Avenue<br>New York NY 10016 | Requested approval for the electric service equipment proposed to be installed | 32 Avenue of the Americas<br>New York NY                      | Ok, but  | \$650.00 |
| Verify that service bus complies with 368.109.   |              |   |  |   |          |          |
| 50171  | 10A0219      | Atlas-Acon Electric Service Corp.<br>283 Hudson Street<br>New York NY 10013     | Requested approval for the electric service equipment proposed to be installed | Kings Plaza Mall<br>Flatbush Avenue & Avenue U<br>Brooklyn NY | Hold     | \$650.00 |
| 1) Provide signage that KI can be energized when open. 2) Indicate trip rating of existing switches for 500MCM conductors. 3) Verify that switch can handle transformers in rush current. 4) Provide output device to prevent backfeed to transformer. 5) Verify that 1 transformer can handle the load. |              |   |  |   |          |          |
| 50172  | 10A0220      | Lowy & Donnath, Inc.<br>10-37 49th Avenue<br>Long Island City NY 11101          | Requested approval for the electric service equipment proposed to be installed | NYPH<br>523 East 70th Street<br>New York NY                   | Approved | \$650.00 |
| 1) Show bonding and grounding of existing service switch. 2) Barrier off back of switchboards to prevent access to all boards. Job finalized 7/26/10.  |              |   |  |   |          |          |
| 50173  | 10A0221      | S.J. Electric, Inc.<br>601 Union Street<br>Brooklyn NY 11215                    | Requested approval for the electric service equipment proposed to be installed | 122 Greenwich Avenue<br>New York NY                           | Approved | \$650.00 |
| 50174  | 10A0222      | Jim Electric Corp.<br>223 52nd Street<br>Brooklyn NY 11220                      | Requested approval for the electric service equipment proposed to be installed | 45 East 20th Street<br>New York NY                            | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee      |
|---|--------------|---|--|---|----------|----------|
| 50175   | 10A0223      | Queens Electrical Contractors, Inc.<br>34-05 34th Street<br>Astoria NY 11106          | Requested approval for the electric service equipment proposed to be installed | Newtown Apartments<br>30-15 Newtown Avenue<br>Astoria NY      | Approved | \$650.00 |
| Transformer marked backwards. Job finalized 9/28/12.                  |              |   |  |   |          |          |
| 50176   | 10A0224      | Unity Electric Co., Inc.<br>65-45 Fresh Meadow Lane<br>Flushing NY 11365              | Requested approval for the electric service equipment proposed to be installed | Grand Hyatt<br>109 East 42nd Street<br>New York NY            | Approved | \$650.00 |
| Transformer marked backwards. Job finalized 9/28/12.                  |              |   |  |   |          |          |
| 50177   | 10A0225      | Alef Electric Inc.<br>247 West 38th Street<br>New York NY 10018                       | Requested approval for the electric service equipment proposed to be installed | 40 Harrison Street<br>New York NY                             | Approved | \$650.00 |
| Transformer marked backwards. Job finalized 9/28/12.                  |              |   |  |   |          |          |
| 50178   | 10A0226      | Delco Electrical Corp.<br>766 Fifth Avenue<br>Brooklyn NY 11232                       | Requested approval for the electric service equipment proposed to be installed | Modell's Sporting Goods<br>795 Columbus Avenue<br>New York NY | Approved | \$650.00 |
| Very size of existing 3000 amp service switch. Job finalized in 2013. |              |   |  |   |          |          |
| 50179   | 10A0227      | Charan Electrical Enterprises, Inc.<br>27-14 39th Avenue<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | PS 600<br>901 Classon Avenue<br>Brooklyn NY                   | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|---|--|--|----------|----------|
| 50180   | 10A0228      | P.E. Stone, Inc.<br>50 Watts Street<br>New York NY 10013                        | Requested approval for the electric service equipment proposed to be installed | NYU<br>20 East 16th Street<br>New York NY                          | Approved | \$650.00 |
| Job finalized 6/28/10.  |              |   |  |  |          |          |
| 50181   | 10A0229      | Vista Electrical Contractors, Inc.<br>2377 Washington Avenue<br>Bronx NY 10458  | Requested approval for the electric service equipment proposed to be installed | Hilton Theatre<br>214 West 43rd Street<br>New York NY              | Approved | \$650.00 |
|   |              |   |  |  |          |          |
| 50182   | 10A0230      | Egg Electric Inc.<br>24 West 25th Street<br>New York NY 10010                   | Requested approval for the electric service equipment proposed to be installed | Mt. Sinai School of Medicine<br>1470 Madison Avenue<br>New York NY | Hold     | \$650.00 |
| 1) Submission not in Advisory Board format. 2) Is all work new? 3) Coordination study? 4) Not reviewed in entirety.   |              |   |  |  |          |          |
| 50183   | 10A0231      | Forest Electric Corp.<br>Two Pennsylvania Plaza, 4th Floor<br>New York NY 10121 | Requested approval for the electric service equipment proposed to be installed | Jane Street Capital<br>One New York Plaza<br>New York NY           | Approved | \$650.00 |
| 1) Indicated if generator is feeding life safety. 2) No normal source to existing motor. 3) Indicate whether GF is actual or indication. Job finalized 9/20/10. |              |   |  |  |          |          |
| 50184   | 10A0232      | Primiano Electric Co.<br>599 11th Avenue, 6th Floor<br>New York NY 10036        | Requested approval for the electric service equipment proposed to be installed | Lincoln Center Theatre 3<br>150 West 65th Street<br>New York NY    | Hold     | \$650.00 |
| No drawings.  |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request   | Installation Location                              | Status   | Fee    |
|---|--------------|---|---|--|----------|--------|
| 50185   |              | Powercon Engineering, P.C.<br>29 Broadway<br>New York NY 10006                          | Requesting permission to utilize less than 10' of existing through that presently runs from an end box located in the adjacent room to the fire rated service room where the service entrance conductors will be replaced with new.   | 390 Park Avenue<br>New York NY                     | Approved | \$0.00 |
|   |              |   |   |  |          |        |
| 50186   |              | Motroneo & Marino s United Elec. Co., Inc.<br>58-15 Fresh Pond Road<br>Maspeth NY 11378 | Requesting reconsideration of a previously denied special permission to allow the use of rigid nonmetallic conduit to be installed for the branch circuit wiring of five vapor proof lighting fixtures located in the vaulted area outside of the building wall due to water leakage causing corrosion problems to existing conduits and lighting fixtures. | 97 Chambers Street<br>New York NY                  | Approved | \$0.00 |
|   |              |   |   |  |          |        |
| 50187   |              | Samson Electric Corp.<br>3300 Northern Blvd.<br>Long Island City NY 11101               | Requesting permission to install schedule 80 nonmetallic conduit for branch circuit wiring in a jewelry manufacturing room where acids and other corrosive chemicals are present  | 31-00 Northern Blvd.<br>Long Island City NY        | Hold     | \$0.00 |
| As per Article 500.4 what is this room classified as? Provide proof that this room containing chemicals is not a hazardous location. This request is on hold until you provide further documentation. |              |   |   |  |          |        |
| 50188   |              | Walter Patterson<br>530 Beach 126th Street<br>Rockaway NY 11694                         | Requesting permission to leave as installed due to the interior of the building being finished and a hardship to reopen the interior to replace #14 nonmetallic sheathed cable with #12.  | 530 Beach 126th Street<br>Queens NY                | Denied   | \$0.00 |
|   |              |   |   |  |          |        |
| 50189   |              | New York City Housing Authority<br>90 Church Street<br>New York NY 10007                | Requesting permission on 43 elevator upgrades to install unspliced elevator main feeders inside of the shaftways.   | Various NYCHA Developments<br>Bronx, Man, Bklyr NY | Approved | \$0.00 |
|   |              |   |   |  |          |        |

# ADVISORY BOARD CALENDAR

**June 16, 2010**

| Calendar # | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                           | Status   | Fee    |
|------------|--------------|---|--|---|----------|--------|
| 50190      |              | A.S.R. Electrical Contracting, Inc.<br>177-04 93rd Avenue<br>Jamaica NY 11433 | Requested permission to leave as installed one circuit breaker panel mounted over a transformer where the transformer extends out 14 inches. | Barnard College<br>3015 Broadway<br>New York NY | Approved | \$0.00 |
|            |              |   |  |   |          |        |