

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48096CO	07A0407CO	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Alliance Bernstein 1345 Avenue of the Americas New York NY	Hold	\$0.00
Carry over from August 15, 2007 meeting. . 1) Provide bus sizes of paralleling switchgear and ground fault protection required on standby. 2) With 3-P ATS's generator neutrals to be ungrounded. May cause issues with ground fault protection. 3) Clarify utility feeds to fire pumps(top of drawing). 4) fire pump service switches are undersized. 5) Fire pump branch circuits are not fire rated. 6) Physical bus taps in switchboard C and D shown different on floor plan and 1 line is main bus tapped. 7) Show protection of emergency fire alarm feed. 8) 1-Line config. of paralleling switchgear shown on Galaxy drawing not consistent with Asco drawings. 9) Provide GFP tripping on standby breakers in Asco switchgear. 10) coordination study. 11) Provide cuts of 5000A ATS 'D' and 'C'. 12) Provide load shed sequence for new switchgear.						
48213CO	07A0474CO	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Medgar Evers College 1638 Bedford Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 17, 2007 meeting.						
48302CO2	07A0547CO2	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metropolitan Television Allicane 500 19th Street Brooklyn NY	Approved	\$0.00
Carry over from March 12, 2008 meeting.						
48404CO2	08A0002CO2	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Beacon Capital 1211 6th Avenue New York NY	Approved	\$0.00
Carry over from March 12, 2008 meeting.						
48630CO	08A0195CO	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NYU Epilepsy 225 East 34th Street New York NY	Approved	\$0.00
Carry over from April 16, 2008 meeting.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48709CO	08A0288CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Baclays Capital 200 Park Avenue New York NY	Approved	\$0.00
Carry over from May 14, 2008 meeting.						
48713CO	08A0289CO	PJS Electric, Inc. 10 43rd Street, Box #L15 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	DEP Spring Creek Auxiliary Plant Brooklyn NY	Approved	\$0.00
Carry over from May 14, 2008 meeting. 1) Indicate 480/277V for generator voltage. 2) Correct typo 11-sets of cable in 1 conduit ( 2 places). Job finalized 7/31/08.						
48717CO	08A0291CO	Linco Electrical Contracting and Maint Inc 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	140 58th Street Brooklyn NY	Approved	\$0.00
Carry over from May 14, 2008 meeting.						
48718CO	08A0235CO	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Myrtle Avenue Condominiums 225 Flatbush Avenue Extension Brooklyn NY	Approved	\$0.00
1) Install barrier to block off back of the switchboard MSB1. 2) Feeder to 1600 amp service switch undersized. 3) Special permission is required for non-coordination 4000 to 4000. 4) Provide new sets of drawings including all job comments. Job finalized 4/9/10.						
48719CO	08A0232CO	Compsec Electric Corporation 31-54 12th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	41-17 Crescent Street Long Island City NY	Approved	\$0.00
Carry over from May 15, 2008 meeting.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48738CO	08A0260CO	R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Ronald McDonald House 267-07 76th Avenue New Hyde Park NY	Approved	\$0.00
Carry over from May 14, 2008 meeting.						
48772	08A0295	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	36 East 116th Street and F.D.R. Driv New York NY	Approved	\$650.00
48773	08A0299	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	20 West 86th Street New York NY	Approved	\$650.00
48774	08A0297	Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	160 Riverside Drive New York NY	Hold	\$650.00
Job changes new drawings.						
48775	08A0347	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Eye and Ear Infirmary 310 East 14th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48776	08A0335	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Shelburne Hotel 303 Lexington Avenue New York NY	Approved	\$650.00
1) In new panel 600A fuse to change from A2D to A2K. 2) Verify job address. Job finalized July 11, 2008.						
48777	08A0332	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	605 West 42nd Street New York NY	Approved	\$650.00
1) Transformer secondary ground to terminate to building steel or water main. 2) Verify size of service switch and fuses for 500 KVA step-up transformer. Job finalized 8/20/08.						
48778	08A0331	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Crosby Street Hotel 150 Lafayette Street New York NY	Approved	\$650.00
1) Verify that emergency feeders are not ran through the service room. 2) Transformer secondary be bonded to building steel or water main,(3 transformers). 3) Fire pump emergency branch circuit not fire rated. 4) Provide fuse cutout after step-down transfer for fire alarm. Job finalized 8/18/08.						
48779	08A0328	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	111 Lawrence Street Brooklyn NY	Approved	\$650.00
48780	08A0325	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	370 Greenpoint Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48781	08A0323	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	333 East 38th Street New York NY	Approved	\$650.00
48782	08A0321	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	61 Jane Street New York NY	Approved	\$650.00
48783	08A0319	Hub Electric Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Calvin Klein 205 West 39th Street New York NY	Approved	\$650.00
48784	08A0317	RNH Electric Co., Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1013 Broadway Brooklyn NY	Approved	\$650.00
Only 6 service switches allowed when none of the existing switches powers a fire pump. Job finalized 12/1/08.						
48785	08A0338	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 627 West 165th St-B3 Level New York NY	Hold	\$650.00
1)Submit cuts on generator and generator breakers. 2) Provide Advisory Board detail for 5KV Asco switchgear. 3) Provide cuts on substations and switchboards.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48786	08A0342	Fresh Meadow Communs & Electl Contg Co 65-42 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Starbucks Service 130 Fulton Street New York NY	Approved	\$650.00
1) Neutral in 400 amp disconnect switch bonded to enclosure. 2) 400A disconnect switch orientartion incorrect (fuse are hot when switch is off). Job finalized July 11, 2008						
48787	08A0340	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
48788	08A0312	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 38 East 37th Street New York NY	Approved	\$650.00
48789	08A0343	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Pepsi Cola Bottling Co. of N.Y. 650 Brush Avenue Bronx NY	Hold	\$650.00
1) Transformer secondary to water main building steel. 2) 4000A breaker does not coordinate with downstream 800ACB,						
48790	08A0336	inco Electrical Contracting and Maint., Inc 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	East River Plaza 36 East 116th Street and F.D.R. Driv New York NY	Hold	\$650.00
1) Not submitted in Advisory Board format. 2) Indicate what is new.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48791	08A0346	AARCO Electric Inc. 5902 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	32 West 18th Street New York NY	Approved	\$650.00
1) 2 sets of 350 MCM fused at 800 amps. 2) New 800 service switch neutral not bonded to enclosure. 3) Provide short circuit calculations. Job finalized 4/29/09.						
48792	08A0304	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	160 5th Avenue New York NY	Approved	\$650.00
1) Provide front clearance in front of MDP-C2. 2) Verify that there is no life safety panels in service room. Job finalized 6/23/09.						
48793	08A0348	Rothstein & Hoffman Electric Service, Inc 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Four Point Sheraton Hotel 66 Charlton Street New York NY	Hold	\$650.00
1) Verify that there is no life safety equipment and feeders in the service room. 2) Busing to 4000 amp service switch undersized. 3) Feeder conductors on load side of 4000 amp switch do not comply with tap rules. (Mains may be required in last two sections). 4) Load side of service switch says 12 sets and each section is marked 5 sets.						
48794	08A0315	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	IHOP 276-282 Livingston Street Brooklyn NY	Approved	\$650.00
48795	08A0308	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Cablevision 2100 Bartow Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48796	08A0306	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Tishman-Speyer Properties 1 Rockefeller Plaza New York NY	Approved	\$650.00
48797	08A0309	Corporate Electric Group, Inc. 14-34 110th Street-Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Village Nursing Home 214-218 West Houston Street New York NY	Approved	\$650.00
48798	08A0345	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hunts Point DEP Water Treatment Costar Street and Ryawa Avenue Bronx NY	Approved	\$650.00
Show dimensions on floor plan for clearances. Job finalized 8/7/08.						
48799	08A0294	B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	East River Plaza 36 East 116th Street and F.D.R. Driv New York NY	Approved	\$650.00
48800	08A0300	Norlin Electrical Contractors, Inc. 385 Rider Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	-	Approved	\$650.00
1) New service entrance conductors feeding existing C.T. are undersized. 2) Provide conductor tap sizes on load side of 1600 amp service switch. 3) Service entrance to 1600 amp service switch wiring method not shown. 4) Verify if meter bank can be moved closer to the doorway to provide better access. Job finalized 10/29/08.						



# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48801	08A0298	Compsec Electric Corporation 39-12 Crescent Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	305 East 85th Street New York NY	Approved	\$650.00
48802	08A0296	I.K.E. Electrical Corporation 601 West 26th Street 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	216-218 18th Street New York NY	Hold	\$650.00
Job changed no drawings.						
48803	08A0334	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	31 West 27th Street New York NY	Approved	\$650.00
1) Transformer secondary to be bonded to building steel or water main not ground rod. 2) justify reduced neutral off of 400 amp service switch. Job finalized July 11, 2008.						
48804	08A0333	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	455 East 148th Street Bronx NY	Approved	\$650.00
48805	08A0330	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Edge Building 4 34 North 7th Street Brooklyn NY	Approved	\$650.00
1) Emergency side fire pump fusing undersized. 2) Tap conductor undersized to 200 amp switch. 3) Provide calculations, not results. Job finalized 8/18/08.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48806	08A0327	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	150 Amsterdam Avenue New York NY	Approved	\$650.00
1) Remove neutral bonds in 800 and 400 amp Trans S cabinets. 2) Transformer secondary bonding to go to building steel on watermain. Job finalized 8/20/08.						
48807	08A0329	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	505 West 37th Street New York NY	Approved	\$650.00
Provide calculations not results. Job finalized April 24, 2009.						
48808	08A0326	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	316 Eleventh Street New York NY	Approved	\$650.00
1) Feeders undersized in switches #1 in panel TDP-A and switch #2 in panel TDP-B 3 sets of 500 MCM fused at 1200. 2) Transformer secondary to be bonded to building steel not ground rod. Job finalized 9/24/08.						
48809	08A0324	Samson Electric Corp. 47-10 33rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	498 7th Avenue New York NY	Approved	\$650.00
48810	08A0322	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	475 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48811	08A0320	amdeen & Sons Electrical Contracting Cor 132-10A Liberty Avenue Richmond Hills NY 11419	Requested approval for the electric service equipment proposed to be installed	16 Sutton Place New York NY	Approved	\$650.00
48812	08A0318	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	255 Butler Street Brooklyn NY	Approved	\$650.00
48813	08A0341	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Double Tree Hotel 8 Stone Street New York NY	Approved	\$650.00
Line side FACO neutral not bonded to enclosure. Job finalized 8/8/08.						
48814	08A0273	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	East River Science Park 450 East 29th Street New York NY	Hold	\$650.00
1) Neutral in FACO not bonded to enclosure SSB-B. 2) Verify that there is no ATS between generator and DPE-EMA, 3) Provide generator room layout.						
48815	08A0310	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	220 South Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48816	08A0311	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	510 Atlantic Avenue Brooklyn NY	Approved	\$650.00
48817	08A0344	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Sleepy Hudson 371 Broadway New York NY	Denied	\$650.00
<p>1)Bus sizes not provided in panelboard of service switchboard #1. 2) Tap detail to two 200 amp disconnect switches not shown on drawing. 3) Fire pump service entrance conductors are undersized. 4) Fire pump branch circuit conductors are undersized. 5) Fire pump branch circuit conductors are not fire rated. 6) Grounding electrode conductor and termination in switchboard not shown on drawing. 7) Supplemental ground termination in switchboard not shown on drawing.</p>						
48818	08A0339	Accurate Electrical Contractors Corp. 180 Rose Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	141 5th Avenue New York NY	Approved	\$650.00
Provide 2nd copy of drawing. Job finalized July 21, 2008.						
48819	08A0337	P & M Electrical Contracting Corp. 1921 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	126-02 82nd Avenue Queens NY	Approved	\$650.00
48820	08A0294	Northgate Electric Corporation 225 West 34th Street, Suite 901 New York NY 11746	Requested approval for the electric service equipment proposed to be installed	The Crosby Street 79 Crosby Street New York NY	Approved	\$650.00
<p>1) Life safety LP-C-EM panel located in service room. 2) Remove neutral bond in FACO on emergency side. 3) Remove FACO on load side of ATS. 4) 3/0 conductors feeding ATS #2 are overfused. 5) Show 2nd fusing for chillers. Job finalized 10/1/08.</p>						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48821	08A0303	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Breslin Hotel 1186 Broadway New York NY	Approved	\$650.00
1) Is panel DP-EM located on roof or in service room? 2) Service entrance bus is undersized. 3) Bus in 4000 amp services switches undersized. 4) Feeder to distribution panel undersized. MLO 5) Emergency side 3 sets of 500 fuses at 1200. Job finalized 1/19/10.						
48822	08A0313	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	1504 Sheridan Avenue Bronx NY	Approved	\$650.00
1) Service entrance conductors undersized for 1200 amp switch. 2) Feeder to HDP not shown. 3) Provide short circuit calculation for circuit breakers. Job finalized 2/17/10.						
48823	08A0316	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Cablevision 1315 Seabury Avenue Bronx NY	Approved	\$650.00
1) 2 doors needed for service room. 2) Verify feeders on load side of 800 amp service switch. 3) Bonding and grounding not shown on normal and emergency sides. 4) Provide short circuit calculations at line side of breaker panel. Job finalized 7/1/08.						
48824	08A0314	C.M. Richey Electrical Contractors, Inc. 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	2865 Brighton 3rd Street Brooklyn NY	Approved	\$650.00
48825	08A0307	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	1797 Park Place Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48826	08A0301	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Lucky Strike Lanes 650 West 42nd Street New York NY	Approved	\$650.00
48827	08A0305	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Credit Suisse 1 Madison Avenue New York NY	Hold	\$650.00
1) Confirm switch can sustain transformer inrush currents. 2) Provide SC calcs(pp-B1 & 7 CB) 3) Indicate bus sizes and voltage on single line. 4) Conform single line to Asco drawings. 5) Provide sections and Manu one line for BA and BB.						
48828	08A0349	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 11001	Requested approval for the electric service equipment proposed to be installed	Monday Properties 230 Park Avenue New York NY	Approved	\$650.00
Fire pump service switch to be remote from service switchboard. Job finalized 6/2/11.						
48829	08A0356	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	One Bryant Park  New York NY	Hold	\$650.00
1) Confirm if generators are emergency or standby. 2) ATS with neutral to be 4 pole. 3) Confirm distributions breakers on parallel switchgear have GFP over 1000A. 4) Provide bonding jumper on BSS-BA-S. 5) Provide SC study. 6) Confirm BOA ATS to fire pump are secondary transfer to building ATS.						
48830		Triangle Electric Inc. 102-04 89th Street Ozone Park NY 11416	Requesting permission in to a corrosive area, Far Rockaway, Queens to install overhead service entrance conductors in Schedule 80 non metallic conduits for 23 one and two family buildings	Bch 39th St and Bch Channel Dr Queens NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48831		Valmar Electric Corp. 2826 Westchester Avenue, Suite 202 Bronx NY 10461	Requested permission to leave as installed service equipment mounted on the side of a commercial building in NEMA 3R enclosures.	Top Tomato 1071 Bay Street Staten Island NY	Approved	\$350.00
48832		Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requesting permission due to extreme financial hardship and lack of space to mount a bypass meter to leave as installed on 19 three family homes common area branch circuits connected to the owners meter and panelboard	Vandalia Avenue Brooklyn NY	Approved	\$0.00
48833		GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requesting permission to replace a defective 2 section circuit breaker panel with new where the left quarter side of the panel does not have a 36" clearance	28-11 Exterior Street Bronx NY	Approved	\$0.00
48834		A.S.R. Electrical Contracting, Inc. 845 Lexington Avenue, Suite 3R New York NY 10021	Requesting permission to leave as installed in a 1000 KVA service room one access door that opens inward instead of outwards into the building's means of egress.	1072 Havermeyer Avenue Bronx NY	Approved	\$0.00
48835		Verizon 140 West Street, 11th floor New York NY 10007	Requesting permission to use second fusing off of the generator to supply power to a fire pump in a building that has standby generators and a portable roll up generator	Verizon 118-15 115th Avenue South Ozone Park NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48836		Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requesting permission on a 1000 KVA service to replace defective end box, feeders, and 1600 amp service switch one for one and to allow 500 MCM to be rated at 400 amps as per the old electrical code.	500 East 83rd Street New York NY	Approved	\$0.00
48837		Hub Electric Inc. 247 West 38th Street New York NY 10018	Requesting permission to allow a 45" instead of 60" clearance in front of a service switch due to limited space inside of the electric room.	calvin Klein 205 West 39th Street New York NY	Approved	\$0.00
48838		RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requesting permission to install a seventh service switch due to a new tenant requiring a separate meter and no existing service switches being unmetered.	1013 Broadway Brooklyn NY	Denied	\$0.00
48839		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requesting permission to leave as installed with drip pans above electrical equipment 7 panelboards with ducting and piping located in the restricted zone and partially blocking panelboards.	246 Spring Street New York NY	Denied	\$0.00
48840		Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requesting permission to leave as installed due to a hardship to replace in a place of assembly AC cable that does not contain an insulated grounding conductor	42-15 147th Street Queens NY	Approved	\$0.00



# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48841		Ramdeens Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to install overhead service entrance conductors in non metallic Schedule 80 PVC conduits in a corrosive area Far Rockaway, Queens	1,1023, 1025,1027, 1029 and 1031 N Far Rockaway NY	Approved	\$0.00
48842		Compsec Electric Corporation 39-12 Crescent Street Long Island City NY 11101	Requesting permission due to lack of space and glass curtain wall to omit the installation of outdoor receptacles on "Juliet" style balconies 14" to 16" deep.	41-17 Crescent Street Long Island City NY	Denied	\$0.00
As per field inspection on June 26, 2008 , it was determined that outdoor receptacles can be installed on the balconies.						
48843		Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requesting permission due to lack of space inside of the basement level service room to install a new 200 amp service switch inside of the 2nd floor service room.	162-45 Crossbay Blvd. Howard Beach NY	Approved	\$0.00
48844		Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requesting permission to leave as installed 10 sets of 500MCM service entrance conductors that feeds a 5000 amp service switch that will be fused at 3800 amps with signage on the switch indicating maximum 3800 fuses allowed and to not group together service equipment where each service feeds a different part of a large building.	270 Greenwich Street New York NY	Approved	\$350.00
48845		Ettinger Engineering Associates 505 Eighth Avenue New York NY 10018	Requesting permission to have Violation #B300940 cancelled due to the electrician filing the job prior to July 1, 2007 under the 2002 code that did not have 110.25 in the New York City Amendments.	147 Flabush Avenue Brooklyn NY	Approved	\$0.00
With the stipulation that barriers are installed behind and on the sides of the bus ducts to separate them from the water and gas piping. Provide on each floor for the maintenance of the bus ducts.						

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48846	08A0350	Colmet Spray Booth, Inc. 1635 Innovation Drive Rockwall TX 75302	Requested approval for use in New York City of your Line of Paint Booths and Mixing Rooms. Model/Series Number: Line of Paint Booths and Mixing Rooms. Model/Series Numbers: ECC, ESD, EMD, EPS & EZPMR.		Approved	\$200.00
48847	08A0351	Colmet Spray Booth, Inc. 1635 Innovation Drive Rockwall TX 75302	Requested approval for use in New York City of your Open-Front Industrial Booth, Model/Series Numbers: IB0407 - IB2012.		Approved	\$200.00
48848	08A0352	Colmet Spray Booth, Inc. 1635 Innovation Drive Rockwall TX 75302	Requested approval for use in New York City of your EZ Heat and Cure Air Make Up Units. Model/Series Numbers: EHC /EH/EC/EHCR 812, 1216, 2026, 2734 and 3440.		Approved	\$200.00
48849	08A0353	Evenlite, Inc. 3161 State Road Bensalem PA 19020	Requested approval for use in New York City of your Emergency Lighting. Model/Series Numbers: MIRSD-25-XX-XX		Approved	\$200.00
48850	08A0354	Evenlite, Inc. 3161 State Road Bensalem PA 19020	Requested approval for use in New York City of your Emergency Lighting. Model/Series Numbers: APR-25-XX-XX.		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**June 18, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48851	08A0355	Evenlite, Inc. 3161 State Road Bensalem PA 19020	Requested approval for use in New York City of your Exit Sign. Model/Series Numbers: SOV-XX-XX-XX-XX-XX.		Approved	\$200.00
48852		B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requesting permission to install Article 604 "Manufactured Wiring System" (Calendar #41001, approved in 1999) exposed (no ceiling) beneath the metal-corrugated sheet roofing decking that will provide power for overhead lighting, and to install below the ceiling line general purpose branch circuits for lighting, switches and receptacles.	Circuit City 1778 E. Gun Hill Rd, 400 E. Fordham Bronx NY	Approved	\$0.00

With the stipulation that amendment 604.1 (A)(1) is complied with.