

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0136	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>Verify if installation in new building and add asbestos note to the drawing as per DOB Regulation or ACRS control # with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p>				
56128	18A0142	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fix typo in all 800A JNN to JJN. 2) Confirm short circuit current @DB-1. 3) FP OCPD oversized. 4) Selective short circuit coordination study does not match. Downstream short circuit values are not consistent with short circuit values. 10/4/2019 1) Add generator and ATSS in the short circuit study. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/27/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55899	18A0145	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide bonding to main service switchboard "SWB-1" &amp; bonding grounding to F.P. S.SW 2) Tap conds feed life safety C.Bs are undersized - 240.21(B) 3) Fix missing connection of "ATS-1" &amp; "ATS-E2" normal side and "SWB-1" 4) F.P. OCPD normal side is overfused 5) Add "ACP-5" control number on the drwg. 6) Feeder for "ATS-E2" normal side is undersized. 7) Verify AIC rating of ATS &amp; Provide cut sheet. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/4/19 1) Confirm that service room is included within the provided asbestos compliance document or provide ACP-5 control # 5/10/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/2/2021 Amended Plan 1 Rev- 4.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 4/8/2021 Amended Plan 1 Rev- 5.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55523	18A0149	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Sectional service bus feeds SS#1,2,3, 4 and 5. 2) Comply with 450.3(B) note 2 and provide transformer secondary tap length. 3) Provide coordination between 800A KRPC fuse and downstream 400A AJT fuse signed and sealed by P.E. 4) Oneline doesn't match floor plan-MSB switchbox. 5) Physical of MSB Section #2 doesn't match oneline. 8/17/18 1) Comply with 240.21(c)(6)(2). 2) Transformer primary OCPD is overfused.. 10/15/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/19 Swap Dwg #1 of 3 &amp; 2 of 3 Rev-3 and 3 of 3 Rev-1.</p>				
	18A0196	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Bus bar feeds 2500A disc. Sw in SB-B2 section - 4 is undersized. 2) Remove bonding from "FA-SW-3", "FP-1-SW-E" and "FP-2-SW-E" 3) Comply with 408.36 for "DP-Gen-B1" switchboard - Provide Main OCPD 4) Provide Cond size feeds load bank. 5) Cond feeds 4000A "DP-Gen-B1" sw board is undersized 6) Bus bar feeds 3000A disc sw in 'DP-Gen-B1' section # 3 7) Physical doesn't match one line or "AB-POE-100 Dwg 'SB-B2' switchboard 8) Provide coordination between SS# 1 3000A fuse for downstream 1600A fuse. And s.sw # 3 downstream 2500A fuse. Please review the dwg. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55543	18A0220	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide vertical bus size in "DP-Gen" panel 2) Provide coordination between 2000A BR- &amp; downstream breakers and 800A A4BQ fuse &amp; upstream fuse 4000A KRPC signed and sealed by P.E.                      3) Provide 5' clearance to F.P. S.S.W 4) Verify NRTL listing of "DS-A" &amp; "DS-B" after adding new section. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/19/18 1) Verify the existing NRTL Listing of 'DS-A' and 'DS-B' after modification. 2) Existing horizontal bus bars in 'DS-A' and 'DS-B' are undersized-Section 408.608.60(E)(4). 10/29/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	18A0228	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Condi from 600A C.B. and feeding exiting panel is undersized - (Generator Panel) 2) Show new verses exiting in main electrical room. If all equipment existig add note on the dwg. 3) Provide sequence of operation 4) Provide coordination between new 200A TR fuse &amp; upstream 1600A C.B. and 1200A C.B Gen &amp; downstream fused in existing dist. Section 5) Provide ATS cut sheet 6) Provide emergency room floor plan dwg &amp; gen detail 7) Provide voltage to existing normal service 8) Fix typo of kitchen A.T.S connection of normal side. 9) Provide cut sheets to Gen &amp; ATSS 10) Confirm 200 KA short circuit from utility. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
55441	18A0280	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide cond size from existing pull box to new 800A disc sw 2) Provide asbestos abatement compliance doc. 3) verify grounding to existing service. 8/16/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/18 Swap dwg #A031803-Revision 2.</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55596	18A0285	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Remove bonding from 200A disc - SW 2) Cond feeds "HDB-1" is undersized 3) Coordination study doesn't match submitted EAB one line. 4) Provide vertical bus size feeding SS # 3 in SSWB - 1 5) Fix typo for 800A wire trough 6) Verify no of sets of incoming service - one line doesn't match floor plan.. 10/10/18 1) SS# 3 is not included within coordination study. 2) Physical doesn't match one line-"swwB1" Section 1. 12/11/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/16/19 Swap Dwg # LNY0019235-S1-OL Rev 3 and -S2FP Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/20/2020 Amended Dwg# 1,2, &amp; 3 Rev 4 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
56093	18A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify voltage rating of incoming service with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. 2) Comply with 230.7.1-Remove spare ss#5. 3) Provide taps length of comply with 240.21(B). For tap cond size (service sw#2 and feeders). 4) Provide main OCPD to meter banks "MB-17", "MB-14", "MB-5,8 &amp; 11" and "MB-2-Sec 240.21(B). 5) Provide available short current at F.P. controller and 'APL-RTL' panel. 6) Series rating for APL-RTL panel required. 9/19/19 1) Provide coordination between 800A fuses SS # 3 &amp; 4 and downstream breakers signed and sealed by P.E. 10/1/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
56156	18a0325	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide cover sheet include license number. 2) Provide OCPD trip size connected to Co-gen-EG-1 in "MV-swg-KP-20-2". 3) Drawing does not meet requirements for EAB list. 8/16/18 1) Verify compliance with 705.12(D)(2). 2) Verify new work in floor plan-bubble new work. 11/1/18 1) Provide the sequence of operation. 2) Provide detail Dwg of co-gen as per 110.2(B)(5). 7/29/19 1) Item #2 from last revision is not addressed. -Provide details on cable &amp; OCPD sizes &amp; types for Co Gen as per NYC 34-05 Rule. -Provide Generator room layout showing clearances. 1/28/2020 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55329	18A0353	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55995	18A0357	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Provide coordination between 400A FRS & upstream 2000A circuit breaker 8/2/18 - Provide coordination between New fuses & upstream breaker 6/27/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/16/19 1) The tap conductor feeds new 'Disc switch' is undersized per 240.21 tap rule. 9/10/2019 Swap Dwg #23765 AB20-02 of 2 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs..				
55449	18A0360	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Grounding electrode conductor of fire pump service switch is undersized. 2) F.P. conductor feeds the controller is undersized and provide conductor size between controller and fire pump. 3) Physical doesn't match one line-Section A in 'MDB' service switchboard. 8/23/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/2020 Amended dwg # 23764AB10-01 of 1-Rev 10; 23764FP60-01 of 1-Rev 1; ans 23764SB30-01 of 1-Rev-7.; Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55394	18A0376	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide coordination between new 400A FRS-R & upstream 2000A A4BQ fused. Signed and sealed by P.E. 7/27/28 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/19 Swap Dwg #233788FP21-01 of 1-Revision 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55631	18A0379	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos compliance doc. 2) Tap conds. Are undersized - 240.21 (B) 3) Provide coordination between 800A SS# 5 & downstream fuses signed and sealed by P.E. 8/16/18 1. Item #2 is partially addressed-Tap cond. Feeds (Tenant space #2) 400A sw is undersized-the provisions of 240.4(B) shall not be permitted for tap cond. Sec. 240.21(B). 12/31/18 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55685	18A0380	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) F.A. tap to be before neutral disconnect link. 2) Remove bonding &amp; connecting for F.A - SW - E 3) Cond. Feeds EDP is undersized 4) Provide AIC rating of MB-A &amp; B 5) Retail trough shall have a service disconnect 6) Physical doesn't match one line - Bus bar sizes 7) Provide EGC with all PVC conduits. 8) confirm bus size In main switchboard section # 1 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/29/18 1) Provide bonding &amp; grounding to "R-SW-1" and "R-SW-2". 2) Correct main horizontal busbar size in MSB switchboard to match physical. 1/29/2019 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/19 Swap Dwg #1 of 3 Rev-2, 2 of 3 &amp; 3 of 3 Rev-1. 12/23/2020 Amended Plan # 1 of 3, 2 of 3 &amp; 3 of 3 Rev- 3.. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55388	18A0385	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Remove bonding on Trans-s. 2) Fuse switches on Trans-s are backwards, (fix old and new). 7/20/18 Job finalized . Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
55578	18A0402	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Provide Asbestos Abatement compliance document. 10/12/18 1) Provided Asbestos doc does not include the location of the new work. 11/23/19 Job finalized.Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55337	18A0409	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/1/2020 Swap drawings # 1 &amp; 2 Rev1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 8/31/2020 Amended Dwgs# 1 &amp; 2 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0418	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Selective coordination study is required between SS#2, SS#5 and downstream. 2) Service rating for SS#6 required..				
55456	18A0422	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between 800A KRPC & upstream breaker and 1000A KRPC fuse & upstream breaker in existing parallel switch gear. 8/24/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55442	18A0427	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Remove bonding from 200A disconnect switches. 2) Provide series rating document. 3) Verify supplemental ground to all remote service switch. 8/16/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/12/2020 Amended Dwgs# Sheet 1-Revision 2, Sheet 2-Revision 2 and Sheet 3-Revision 3 .Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs 5/29/2020 .Amended plan # 1 of 3 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55540	18A0428	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that F.P. cond within the building is 2 hr fire rated 2) Provide cut sheets of ATSS & Gen with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55643	18A0429	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance doc. 10/12/18 1) Provides Asbestos doc. Doesn't include the location of new work. 1/8/19 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/2019 Swap Dwg #B Rev-2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs..				
55475	18A0431	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Tap cond is undersized 2) Provide coordination between 800A A4BQ & upstream fuse 3) Provide asbestos document. 8/21/18 1) Verify ss#1 fuse, for coordDisclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.dination provided doesn't match latest submitted one line. 9/19/18 Job finalized. 1/31/19 Swap dwg A-Revision 1 and Dwg B-Revision 3				
55393	18A0432	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance document.. 7/27/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/21/18 Swap dwag #A-Revision 1				
55488	18A0435	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination & short circuit study signed & sealed by P.E. 2) Provide cond. Size feeds load bank. 3) Verify compliance with 700.6(G) 4) Verify grounding & bonding on the cam - lock alternate side of double throw switch. 5) Verify 10 KA short circuit rating of double throw switch & provide available S.C. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9/24/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				



# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55338	18A0439	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55341	18A0440	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance doc .6/22/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/27/18 Swap dwg #B-Revision 1. 2/7/19 - Swap dwg #B Rev-2.				
55439	18A0441	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos doc. 2) Verify "FDOW" switch for it is not shown on the one line dwg . 8/14/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55818	18A0442	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement compliance document. 2) Provide coordination between new 3000A breaker and upstream 4000A KPPC fuse in existing "SWBD-B" 8/24/18 1) Provided TCC to be signed and sealed by P.E. 4/3/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0443	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Drawings not in Advisory Board format. 1) Provide 5 ft clearance between the two substation lineup per table 110.34(A). 2) Show bonding after the transformer (size). 3) Provide detail for the 480/277v equipment, busbars, OCPDs, equipment short circuit ratings. 4) Include the 480/277V in the coordination and short circuit study. 5) Clearance behind each substation wireup shall comply with Table 110.34A Condition 2(4#)(unless wireup are front accessible only) 6) Verify that primary trip settings are according to Table 110.34A supervised locations only with no secondary protection is required otherwise comply with note 2 on same Table. 7) Provide physical of all equipment. 8) Provide panic hardware for electric service room (110.26C3). 9) Show bus sizes and provide cuts for manufacture. 10) Provide drawings in Advisory Board sizes (standard). 11) Provide note with a room is mechanically ventilated.				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0445	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
1) F.A. tap to be before N.D. L. 2) Provide coordination study signed & sealed by P.E. 3) Provide asbestos abatement compliance doc. 1/30/19 1) 1200 A breaker and downstream 800A KRPC fuse are not coordinated. Verify if curves are overlapped above oil sec or not. 2/11/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/30/19 1) Confirm fuses in 400A & 800A switches didn't change from previously approved plans or update coordination study.				
	18A0446	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR - 1) Provide coordination between new 900A fuse & upstream fuse.				
55512	18A0447	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination between SS# 2 & MB - 1 and SS # 3 & MB-2. 8/23/18 1) Provide 7' clearance between FA & F.P. service switches. 9/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/4/19 Swap Dwgs 1 of 3 rev 2, 2 of 3 rev 3, 3 of 3 rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55332	18A0448	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/24/18 1) Provide 5' clearance to existing F.A. service switch. 2/6/19 - Swap dwg #A Rev-3, #B Rev-1, #C Rev-1. 7/18/2019 Swap Dwg # D-1805-30304-A Rev 4 and Dwg # D-1805-30304-C Rev 2.				
55409	18A0449	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide tap length 2) Verify if installation in new building and add asbestos note in the dwg as per DOB regulation. 8/3/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55395	18A0450	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 408.36 and 240.21(B)(L)(b) "Apt-PB" and "Apt-PA2" panels. 2) Fix note regards scope of work. 8/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/18 -Swap dwg #A.2				
55445	18A0451	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Meter banks cuts are required. 2) Selective coordination study is required. 3) Verify F.P. feeder in adjacent room o concrete encased. 8/20/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/26/18 Swap Dwg # 1 of 3-Revision 2.				
55886	18A0452	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Existing main service bus bar is undersized 2) Provide cut sheet of new dist. Switch board & panels 3) Verify compliance with 408.36 for DP-1 & DP - 2 & provide rating of each panel. 4) Provide asbestos abatement compliance doc. 9/21/18 1) Provide Asbestos Abatement compliance document. 5/6/19 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55385	18A0453	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide cut sheets showing AIC rating & NRTL listing for new equipment 2) Service switchboard shall not be used as a raceway for cond. Tapping off to the switches, comply with UL 891 7/23/18 Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55366	18A0454	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos Abatement required documents. 7/6/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/20/2020 Amended Sheet # 1 Rev- 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/26/2021 Amended Dwgs# 1 Rev 2, 2 Rev 1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55484	18A0456	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement doc. 2) Provide 5' clearance to F.A. S.Sws. 9/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55331	18A0457	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/18 Swap dwgs 1 and 2-Revision 1. 11/26/18 Swap dwgs 1 and 2-Revision 2. 7/1/2020 Swap drawings # 1 & 2 Rev3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55339	18A0458	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55330	18A0459	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 7/29/2019 1) Provide AIC rating of new service switches ss # 4 &amp; 5. 2) Provide submission # of generator on the dwg. 8/21/19 1) Plans cannot be approved due to missing future work. 11/29/19 Swap Dwg # sheet 1 rev.3, sheet 2 rev.3, sheet 3 rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55346	18A0460	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Bus bar feeds 800A SW is undersized. 6/27/18 . Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/14/18 Swap dwg #1-Revision 1.				
55335	18A0461	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/19 - Swap dwg #1 Rev-1. 7/16/19 Swap Dwg #1 Rev-2.				
55371	18A0462	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) 800A A4BQ fuse doesn't coordinate with new 400A A20 fuse. 7/17/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
55333	18A0463	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/29/2021 Amended plans# 1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55398	18A0464	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify grounding with supplement to existing ssw #4 and S-250.64(D)(2). 8/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55515	18A0466	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination and short circuit study signed and sealed by P.E. 10/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55566	18A0467	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide available S.C current at meta banks "MB-1, 2 & 3" & ATs 2) Provide ATs cut sheet & gen. 11/15/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/9/19 Swap Dwg # sheet 1 rev.2 and sheet 2 rev.2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/28/2021 Amended dwgs# 1 & 2 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55458	18A0468	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos compliance doc. 8/24/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55372	18A0469	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply with 230.64(B)(4).. 7/17/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/31/2021 Amended dwgs# 1 & 2 Rev 2 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4/22/2021 Amended Dwgs# 1 & 2 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55336	18A0470	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/20/18 - swap dwg 1 & 2 Rev 1. 1/21/2021 Amended Plan # 1 & 2 Rev- 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 3/1/2021 Amended dwgs # 1 & 2 Rev 3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55764	18A0471	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Verify bonding & grounding to existing service 2) Provide coordination between 1200A KRPC & upstream 2000A KRPC fuses signed & sealed by P.E.. 3/6/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55467	18A0474	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos document. 8/21/18 1) Verify that tap length is not more than 10'.. 9/17/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/29/20 - swap dwg # 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	18A0475	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Verify supplemental ground to S.SWs 2) F.P. conductor is undersized 3) Main Service cond feeds meter of F.A., F.P. & SS # 4 & service cond feeds 1200A SS# 5 are undersized 4) Provide vertical bus size in 600A service SW w/ elevator dis. Panel. 5) Provide tap cond size & length feeds 200A disc. Sw 6) Provide available S.C current at point of entry, & 200A panels and AIC rating of all service equipment's 7) Provide cut sheets to panel boards showing NRTL listing 8) Provide panic bars to service room door. 9) Comply with 230.64(B)(1) - provide 7' clearance in front of SS # 5,3,2 & 6 10) Provide asbestos abatement compliance doc				

# ADVISORY BOARD CALENDAR

**June 20, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55502	18A0477	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Asbestos Abatement compliance document . 2) Provide bonding and grounding to new PV disconnect switch "89L". 3) Provide transformer and disconnect switch cut sheets 9/27/18                      .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 12/2/19 Swap Dwg # rev.1 Disclaimer:                      Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
56076	18A0478	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide bonding &amp; grounding to new PV disconnect switch '89L'. 2) Provide cutsheet of transformer and disconnect switch. 3) Provide Asbestos Abatement compliance document. 10/3/18 1) Provide 2 copies of full size dwgs. 11/30/18 1) Verify the job address for filing adress doesn't match address on one line or Asbestos docu. 7/15/19 1) Verify the job address for filing address doesn't match address on one line diagram or asbestos doc. 2) Provide the distance in the rear of 1200A pv sw '89L' 3) Confirm the conductor size which is feeding 1200A fuse for '89L' sw. 8/6/19 1) Resubmit the new plan with all the changes marked and noted on the plan. 9/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/19/19 1) Provide standard size dwg. 2) Show (note and mark) all changes from previously approval plans. 2/19/2020 Swap dwg A-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				