

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
BK00827A1	BK00827	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/7/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK01001A1	BK01001	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK01005	BK01005	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK01006A1	BK01006	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/11/2021 1. Confirm the fire alarm disconnection device is complied with per 760.41(B)(2) at generator side 2. Submit asbestos abatement document covers the new area of work 3. Coordination study only has the cover page, please resubmit with the entire study. 9/16/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00966A1	BX00966	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00996A1	BX00996	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/30/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
BX01024A	BX01024	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/16/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX01025A	BX01025	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/11/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX01061A2	BX01061	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/1/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
BX01064A1	BX01064	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7/13/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00278A	MN00278	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7/2/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/28/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00611A1	MN00611	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/2/2021 Job finalized Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
MN00839A1	MN00839	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/10/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00871A1	MN00871	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
7/8/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00914A1	MN00914	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00964A1	MN00964	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/11/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00970A1	MN00970	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/28/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
	MN00976	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>8/3/2021 1. The engineering plans shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: A. One-line plan should include all required information as follow: i. Include all new equipment in one drawing, clearly showing new versus existing, showing all conductors, OCPD sizes, and new equipment ratings (e.g. amperage, voltage and AIC ratings.....) ii. Another one line could be added to show the sequence of operation to all available modes. iii. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing. B. Floor plans shall clearly show the equipment clearances as per 110.26 and/or 110.34 and new versus existing equipment. The required floor plans are as follow: i. Co Gen Floor plans (it is required for it is more than 1000KVA) ii. Any new or existing service room with changes was made for this submission (e.g. Service room/s include SS#1 &2 and SS#3&4 if include new equipment). 2. Provide the breaker setting (trip setting) of the 1200A “52-P1”. 3. The P.E. stamp shall be signed by the P.E. 4. Confirm that the provided asbestos form includes the new scope of work- add note on the plan with the ACP5 control number. 5. Confirm service room/s are 2Hr. fire rated constructions. 6. Confirm service room/s include doors equipped with panic-bars as a legal egress. 7. Confirm service room/s are Mechanically ventilated if include transformers or equipment with 2000KVA rating..</p>				
MN00995A1	MN00995	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>7/9/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants’ liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
MN01012A	MN01012	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/24/2021 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: a. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing. 7/29/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN01017A1	MN01017	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>7/21/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN01031A1	MN01031	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>7/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
	MN01037	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>7/9/2021 1. Comply with 110.26C(3) – personal doors shall open outward and equipped with panicbars when installing a 1200A equipment with a working space edge less than 25 feet from the door.</p>				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
MN01039A2	MN01039	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/21/2021 1. In case the building is new building: a. A note can be added in the EPR submittal/plan (signed and sealed by P.E/RA) stating, "The proposed electrical work is exempt from any filing of ACP forms because such work is occurring in a new building, wholly new building wing, floor, etc. or in an existing building or building wing, floor etc. that was wholly constructed pursuant to plans submitted for approval on or after April 1, 1987." b. A copy of the PW1(if available) to show the building is new. 2. Confirm the 2500A and 1200A switches have the Ground Fault Protection devices at both generator switchboard. 3. Please submit generator floor plan since it is over 1000KVA 4. Clarify the 1200A panel is new or exiting, and what level is the 1200A panel? 9/3/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/25/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
MN01044A1	MN01044	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/23/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/6/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN01046A1	MN01046	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>7/1/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/22/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
MN01049A1	MN01049	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/23/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
MN01051A1	MN01051	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/29/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/29/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/29/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01057A1	MN01057	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/24/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01076A2	MN01076	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/24/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/26/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
	QN01007	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
6/21/2021. In case the building is new building: a. A note can be added in the EPR submittal/plan (signed and sealed by P.E/RA) stating, "The proposed electrical work is exempt from any filing of ACP forms because such work is occurring in a new building, wholly new building wing, floor, etc. or in an existing building or building wing, floor etc. that was wholly constructed pursuant to plans submitted for approval on or after April 1, 1987." b. A copy of the PW1 (if available) to show the building is new. 2. Confirm the 2500A and 1200A switches have the Ground Fault Protection devices at both generator switchboard. 3. Please submit generator floor plan since it is over 1000KVA 4. Clarify the 1200A panel is new or exiting, and what level is the 1200A panel?				
QN01007A1	QN01007	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/24/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
QN01026A1	QN01026	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/15/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01027A2	QN01027	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/15/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/2/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
QN01028A2	QN01028	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/15/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/2/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
QN01029A1	QN01029	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/15/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01032A1	QN01032	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/28/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

June 30, 2021

Approval #	Submission #	Type of Request	Status	Fee
QN01038A1	QN01038	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/21/2021 1. In case the building is new building:</p> <p>a. A note can be added in the EPR submittal/plan (signed and sealed by P.E/RA) stating, "The proposed electrical work is exempt from any filing of ACP forms because such work is occurring in a new building, wholly new building wing, floor, etc. or in an existing building or building wing, floor etc. that was wholly constructed pursuant to plans submitted for approval on or after April 1, 1987."</p> <p>b. A copy of the PW1(if available) to show the building is new.</p> <p>2. Confirm the 2500A and 1200A switches have the Ground Fault Protection devices at both generator switchboard.</p> <p>3. Please submit generator floor plan since it is over 1000KVA</p> <p>4. Clarify the 1200A panel is new or exiting, and what level is the 1200A panel? 7/9/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
SI01066A	SI01066	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>6/28/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				