

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47166CO	06A0247CO	BLZ Electric Co. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	20 Bayard Street Brooklyn NY	Approved	\$0.00
Carry over from May 24, 2006 meeting. Change 600 amp fuses to A3T. Job finalized 1/23/08.						
47171CO	06A0257CO	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	6 West 48th Street New York NY	Hold	\$0.00
Carry over from May 24, 2006. Provide 2 means of egress on each side of the service room.						
47172CO	06A0279CO	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	415 East 37th Street New York NY	Hold	\$0.00
Carry over May 24, 2006 meeting. 1) 3000 amp fuse protecting ATS is oversized change to 2000. 2) Change 2000 amp fused switch to a disconnect switch. 3) Show grounding of ATS and type of ATS.						
47231CO	06A0317CO	J.H. Electric of New York, Inc. 59-01 Grand Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Dept. of Sanitation-Manhattan 780-786 12th Avenue New York NY	Approved	\$0.00
Carry over from June 14, 2006 meeting. Change norm. fire pump fuse to 900A. Job finalized 7/26/06.						
47235CO	06A0287CO	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	360 West 11th Street New York NY	Approved	\$0.00
Carry over from June 14, 2006 meeting. Fire pump must be fed from Con-Ed box. Job finalized.						

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47243CO	06A0304CO	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Claremont Square 36 East 14th Street New York NY	Approved	\$0.00
Carry over from June 14, 2006 meeting.						
47249CO	06A0323CO	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	50 Court Street Brooklyn NY	Approved	\$0.00
Carry over June 14, 2006 meeting.						
47252CO	06A0322CO	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Con Edison Van Nest Station 1610 Matthews Avenue Bronx NY	Approved	\$0.00
Carry over from June 14, 2006 meeting.						
47269	06A0361	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 685 Third Avenue New York NY	Approved	\$650.00
47270	06A0347	Hylan Electrical Contracting, Inc. 1150 South Avenue, Corporate Park Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlas Park-Building #3 70-27 Cooper Avenue Glendale NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47271	06A0348	Up Town Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Circuit City 502-512 86th Street Brooklyn NY	Approved	\$650.00
47272	06A0342	Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Audi AG Forum 250 Park Avenue New York NY	Approved	\$650.00
47273	06A0351	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	508 East 120th Street New York NY	Approved	\$650.00
47274	06A0352	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	460 West 34th Street New York NY	Approved	\$650.00
47275	06A0353	A.C. Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	Paradise Theater 2401 Grand Concourse Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47276	06A0354	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering-MRI 305 East 55th Street New York NY	Approved	\$650.00
47277	06A0363	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Yeshiva University-Zysman Hall 500 West 185th Street New York NY	Approved	\$650.00
Confirm clearance for 350 KVA XFMR meet manufacturer ventilation requirements. Job finalized 7/26/06.						
47278	06A0336	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Whole Foods 229 Chrystie Street New York NY	Hold	\$650.00
1) Con-Ed won't crab 600 MCM conductors. 2) No bonding and grounding provided. 3) Dual neutral links. 4) No bus sizes in switchboard provided. 5) Provide clearances in service room.						
47279	06A0331	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Dalton School 108 El 89th Street New York NY	Approved	\$650.00
47280	06A0332	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	125 West 21 Street New York NY	Approved	\$650.00
Clarify feeder sizes to meter banks. Job finalized 8/06.						

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47281	06A0333	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	132 West 36th Street New York NY	Approved	\$650.00
Justify use of 10KAIC panel with 11KA available. Job finalized 7/25/06.						
47282	06A0335	BLH Electrical Contractors, Inc. 146 E. 151 Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	555 Park Avenue New York NY	Approved	\$650.00
Room layout unacceptable. New service panel and new CT cabinet block access. Rearrange or confirm minimum 24" clearance next to new service panel. Job finalized 7/15/06.						
47283	06A0337	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Kings County Hospital 604 Winthrop Street Brooklyn NY	Approved	\$650.00
1) AT 480V provide fused disconnect in lieu of fuse cut-out for fire alarm system. 2) Need XFMR for fire alarm system. 3) Confirm generator grounding. 4P ATS shown-would indicate grounded neutral. Job finalized 12/12/06.						
47284	06A0364	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC DEP-Manhattan Pump Sta, 13th Street and Avenue D New York NY	Hold	\$650.00
47285	06A0341	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	23-45 Caton Place New York NY	Hold	\$650.00
1) Provide coordination between service switches and meter bank overcurrent. 2) Bonding and grounding not provided. 3) 800 amp service switch not shown or room layout,. What is FOE? 4) Feeder undersized to 800A service switch. 5) Fuse types in 800A service switch not provided. 6) 2 switches installed before fire pump feeder. 7) Neutral not bonded to enclosure in 800 amp service switch. 8) Tap for fire pump feed taken off of switchboard. 9) Short circuit calculations not provided, service switch and meter banks. 10) 800 amp switch for fire pump in same room as service equipment. 11) Doors to service door to open out.						

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47286	06A0339	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Arverne by the Sea Bldg. #1A Beach 81st Street Arverne NY	Hold	\$650.00
Not properly submitted in Advisory Board format.						
47287	06A0343	AMC Electrical Services, Inc. 3819 Fort Hamilton Parkway Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	108 West 39th Street New York NY	Approved	\$650.00
47288	06A0344	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Yeshiva University 50 East 34th Street New York NY	Approved	\$650.00
47289	06A0345	Roland J. Wertz Inc. 436 Beach 129th Street Belle Harbor NY 11694	Requested approval for the electric service equipment proposed to be installed	Presbyterian Church & School 921 Madison Avenue New York NY	Approved	\$650.00
47290	06A0346	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	101 Willoughby Street Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47291	06A0355	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Stanhope 995 5th Avenue New York NY	Ok, but	\$650.00
1) ATS' for life safety not be in the service room. 2) ATS normal and emergency reversed on switch.						
47292	06A0356	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	261 West 28th Street New York NY	Approved	\$650.00
47293	06A0357	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	188 Ludlow Street New York NY	Approved	\$650.00
47294	06A0358	Matros Automated Electl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 East 66th Street New York NY	Ok, but	\$650.00
Provide signage on service room doors indicating where the other service is located.						
47295	06A0350	Twins Electric Corporation 460 Austin Place Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	600 West 113th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47296	06A0349	Hi-Tech Electric Inc. 34 Clovis Road Staten Island NY 10308	Requested approval for the electric service equipment proposed to be installed	240 West 40th Street New York NY	Approved	\$650.00
47297	06A0360	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	FISA 450 West 33rd Street New York NY	Approved	\$650.00
47298	06A0359	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Googles Services 111 8th Avenue New York NY	Approved	\$650.00
47299	06A0362	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Citigroup 111 Wall Street New York NY	Approved	\$650.00
Cable tap must be 1600A 4-500KCM undersized. Job finalized 8/06.						
47300	06A0334	BLH Electrical Contractors, Inc. 146 E. 151 Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	1220 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

July 12, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47301	06A0338	Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Hutchinson Metro Center 1200 Waters Place Bronx NY	Approved	\$650.00
<p>1) Service cables undersized. 2) Fire pump switch and fuse undersized. 3) Feeder to panel 'TTY' undersized. 4) Feeder to panel 'ELP' undersized. 5) Show neutral grounding. 6) Provide front view, section view, notes.</p>						
47302	06A0340	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Bradhurst Parc 102 Bradhurst Avenue New York NY	Hold	\$650.00
47303	+	Liker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY	Requesting concept approval of a 1000 KVA service room where full Advisory Board drawings will be submitted.	Health Profession H.S. 345 East 15th Street New York NY	Approved	\$0.00
<p>With the stipulation that the service entrance conductors are run in rigid metallic conduits and concrete encased, a fence encloses the distribution equipment in the wood storage area and confirm where the north egress door leads to.</p>						
47304	++	Hi-Tech Electric Inc. 34 Clovis Road Staten Island NY 10308	Requesting permission to install a seventh service switch where one of the service switches powers a fire pump.	240 West 40th Street New York NY	Approved	\$0.00
47305	+++	B & G Electrical Contractors 38-22 55th Street Woodside NY 11377	Requesting permission to have one means of egress to a 1000 KVA electrical service room.	Claremont Square 36 East 14th Street New York; NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47306	++++	Marino Gerazounis & Jaffe Associates, Inc 116 West 32nd Street New York NY 10001	Requesting permission to leave one means of egress to a 1000 KVA service room.	6 West 48th Street New York NY	Denied	\$0.00
47307	+++++	Flack + Kurtz Consulting Engs, LLP 475 Fifth Avenue New York NY 10017	Requesting permission to install emergency switchgear and cogeneration switchgear in the same fire rated room in a hospital.	N. Shore L.I.J. Hospital 265-25 76th Avenue New Hyde Park NY	Hold	\$0.00
What emergency loads exist in the plant? Is Con-Ed also providing power? Does Co-Gen supply power to their parts of the plant?						
47308	++++++	Dept. of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requesting permission on existing DEP pump sites that will be upgraded to meet all electrical code requirements to install components rated for Class I, Group D, Division 2 in an ordinary electrical box non-rated components.	NYC DEP  New York NY	Hold	\$0.00
47309	+++++++	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to add a 7th 30 amp, 240 volt service switch for cable TV on previously approved 1000 KVA service, Cal. #46431	4 West 21 Street New York NY	Approved	\$0.00
47310	+++++++	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requesting permission to leave as installed service equipment mounted on the outside of a commercial building that is fed directly by Con Ed.	207-05 Linden Blvd. Queens NY	Approved	\$350.00
With the stipulation that signage is provided at each service indicating where the other service is located.						

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47311	+++++++	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requesting permission to install a service switch on the outside of a commercial building that is fed separately from Con-Ed.	1107 Goethals Rd. N. Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
47312	+++++++	Action Light & Power, Inc. 383 Willoughby Avenue Brooklyn NY 11205	Requesting permission due to the building having no common areas to install the service equipment on the outside of the building wall underneath a walkway/stairway of a commercial building.	432 Bedford Avenue Brooklyn NY	Approved	\$0.00
47313	+++++++	B & G Electrical Contractors 38-22 55th Street Woodside NY 11377	Requesting permission to install electrical non-metallic tubing as a wiring method as per Section 362.130 of NYC amendments.	Kingswood Retail & Office Ctr 1630 East 15th Street Brooklyn NY	Approved	\$0.00
47314	+++++++	Cobra Electric Corp. 18-17 42nd Street Astoria NY 11105	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor in a place of public assembly	"H" Club 634 West 52nd Street New York NY	Approved	\$0.00
With the stipulation that ground fault circuit breakers are installed on all wiring that serves the public assembly area.						
47315	/	Zava Electric Co. 2290 Second Avenue New York NY 10035	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor in a place of public assembly.	1230 Virginia Avenue. Bronx NY	Approved	\$350.00
With the stipulation that ground fault circuit breakers are installed on wiring that serves the public assembly area.						

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47316	//	W.L. Squire Electric 113-37 Farmers Blvd. St. Albans NY 11412	Requesting permission to leave as installed AC cable without an insulated equipment grounding conductor in a place of public assembly where the branch circuits will be ground fault protected.	The Church of God 4444 White Plains Rd.. Bronx NY	Approved	\$350.00
With the stipulation that ground fault circuit breakers are installed on all wiring that serves the public assembly area.						
47317	06A0365	Lo Sardo General Contractors Inc. 35 Crescent Street Brooklyn NY 11208	Requested approval for use in New York City of your Electrical Materials and Equipment for Transportable Classroom Unit (TCU).		Hold	\$200.00
47318	06A0366	Universal Electric Corporation 3089 Washington Pike Bridgeville PA 15017	Requested approval for use in New York City of your Plug-in busway systems. Model/Series Numbers: B40/B50/B60C Busway		Approved	\$200.00
With the stipulation that each component is listed by a Nationally Recognized Testing Laboratory(NRTL).						
47319	06A0367	Nordic Logistics 311 S. Arlington Heights Rd., Suite 102 Arlington Heights IL 60005	Requested approval for use in New York City of your (1) 1x35W T5 Fluorescent Luminaire. Model/Series Number: (1) P036-48.		Approved	\$200.00
With the stipulation that the wiring trough on the fixture is extended to conceal all wiring.						
47320	06A0368	Nordic Logistics 311 S. Arlington Heights Rd., Suite 102 Arlington Heights IL 60005	Requested approval for use in New York City of your (2) 1x35W T5 Fluorescent Luminaire. Model/Series Number: (2) P063-03 (Version2).		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47321	06A0369	Nordic Logistics 311 S. Arlington Heights Rd., Suite 102 Arlington Heights IL 60005	Requested approval for use in New York City of your (3) Portable Electric Lamp with Cord, (3) IKEA Mini 120V and (3) Universal Clamp Spot Light.		Approved	\$200.00
47322	06A0370	B & G Electrical Contractors 38-22 55th Street Woodside NY 11377	Requested approval for use in New York City of your Integrated Power Centers (IPCs).		Approved	\$200.00
47323	06A0326	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	169 Hudson Street New York NY	Approved	\$650.00
47324	06A0327	Reliable Electrical Contractors Corp. 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	145 Avenue of Americas New York NY	Ok, but	\$650.00
Feeder to new meter bank undersized 3-500KCM fused at 1200 amps.						
47325	06A0328	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	508-526 West 26th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 12, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47326	06A0329	Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	58-25 Queens Blvd. Queens NY	Approved	\$650.00
47327	06A0330	P & M Electrical Contracting Corp. 1921 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	22 Reade St-Basement New York NY	Approved	\$650.00