

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50624CO2	11A0129CO2	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	The NYCDEP Pumping Station 84 West 11th Street Brooklyn NY	Approved	\$0.00
<p>Carry over from June 15, 2011 meeting. 1) Remove neutral links. 2) UL for Gen set. 3) Outdoor fused disconnect switch for generator. 8/26/14 Rejected Item 1 only address on drawing 1 of 10 not other drawings. 2) Item #2 not addressed. Please submit manufacturers installation instructions for the particular model generator being installed. 3) Conductors from generators to disconnect switches undersized. 4) Drawing 4 of 10 shows revision 4 with no details of changes made. 5) Drawing 5 of 10 shows revision 4 with no details of changes made. 6) Drawing 7 of 10 shows revision 4 with no details of changes made. 7) Drawing 8 of 10 shows revision 4 with no details of changes made. 8) Drawing 9 of 10 shows revision 4 with no details of changes made. 9) Drawing 10 of 10 shows revision 4 with no details of changes made. 10) 2 revised sets of drawings to be resubmitted not one set. 1/9/15 Job finalized With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
50643CO2	11A0146CO2	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Albert Einstein Coll. of Med. 1225 Morris Park Avenue Bronx NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50690CO	11A0183CO	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Lakeside Center 171 East Drive Brooklyn NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						
50718CO	11A0211CO	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Kupferberg Ctr for Arts Qns Coll 65-30 Kissena Boulevard Flushing NY	Approved	\$0.00
Carry over from May 25, 2011 meeting.						

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50744CO	11A0227CO	Sajun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	851 Grand Concourse Bronx NY	Approved	\$0.00
Carry over from June 15, 2011 meeting. 1) Cables from gen should be treated like service conductors run "outside building." Cable operating temp not to exceed rating of equipment terminal rating. 2) Review 1st and 2nd level coordination on switchgear. Special permission required for lack of coordination. Job finalized 8/7/12.						
50772	11A0246	Broadway Electric 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	29 West 36th Street New York NY	Approved	\$650.00
1st 4' feet of load side bus of the 5000 amp switch shall be rated at 700 Sq". Job finalized 7/21/11.						
50773	11A0247	AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requested Concept Approval:	World Financial Center Building D New York NY	Approved	\$0.00
50774	11A0248	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	735 Garden Street Bronx NY	Approved	\$650.00
1) Provide short circuit calculations for existing panel, show circuit breaker types. 2) Verify that service is 1000 KVA. Job finalized 9/27/12.						
50775	11A0249	Ramdeen s Electl Contg Corporation 132-10A Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	Riverway Apartments 230 Riverdale Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50776	11A0250	Alkem Electrical Corporation 557 Lefferts Avenue Brooklyn NY 11225	Requested approval for the electric service equipment proposed to be installed	Hotel De Point 20-07 127th Street College Point NY	Approved	\$650.00
6/26/15 Swapped Drawing 1, Revision 2.						
50777	11A0251	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	18 Gramercy Park South New York NY	Approved	\$650.00
50778	11A0252	Megan Electrical Enterprises, Inc. 36-51 Bell Boulevard, Suite 208 Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	Nazareth High School 475 East 57th Street Brooklyn NY	Approved	\$650.00
50779	11A0253	Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	Montefiore Methadone Treat. 2068 Jerome Avenue Bronx NY	Approved	\$650.00
Provide supplemental ground. Job finalized 1/15/13.						
50780	11A0254	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	HBO 120A East 23rd Street New York NY	Approved	\$650.00
1) Verify that UPS system is listed. 2) Verify existing 1600A HPC switch rated for transformer inrush or provide signage. Do not energize transformer with HPC switch. Job finalized 8/4/11.						

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50781	11A0255	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested Concept Approval:	WTC-Tower 3 175 Greenwich Street New York NY	Approved	\$0.00
50782	11A0256	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	769 Grote Street Bronx NY	Approved	\$650.00
1) Service room to have 2 doors. 2) Doors to swing out. 3) Confirm existing pull box(Svc B) prevents rear access for switchboard or block access. Job finalized 9/27/12.						
50783	11A0257	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	725 Garden Street Bronx NY	Approved	\$650.00
50784	11A0258	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	PS 59 and HS of Art & Design 250 East 57th Street New York NY	Approved	\$650.00
Corrected (existing) drawings to be submitted. Only new is 4000A CT and service switch. Job finalized 7/15/11.						
50785	11A0259	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC Dept. of Environ. Protection 259 Java Street Brooklyn NY	Hold	\$650.00
Not in Advisory Board format.						

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50786	11A0260	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	1515 Broadway New York NY	Approved	\$650.00
1) Verify the clearance under the overhead service bus. 2) Verify unfused or fused 1200 amp second switch. 3) Provide signage indicating where new 1200 amp service is located. Job finalized 9/22/11.						
50787	11A0261	Switch Electric 29 15th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	675 Morris Avenue Bronx NY	Approved	\$650.00
50788	11A0262	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	47-07 30th Place Long Island City NY	Approved	\$650.00
50789	11A0263	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	145 East 39th Street New York NY	Approved	\$650.00
50790	11A0264	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	233 West 34th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50791	11A0265	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1 West 72nd Street New York NY	Approved	\$650.00
50792	11A0266	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Court Square Project 24-01 44th Road Long Island City NY	Approved	\$650.00
Confirm that new equipment is not for life safety. Job finalized 8/4/11.						
50793	11A0267	Michael Schondorf, Inc. 545 West 45th Street, Suite 6F New York NY 10036	Requested approval for the electric service equipment proposed to be installed	224 12th Avenue New York NY	Approved	\$650.00
50794	11A0268	G. Poulakis Electrical Contracting, Inc. 119-12 29th Avenue Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	129-132 Blossom Avenue Flushing NY	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Provide short circuit calculations. 3) Show tap detail in troughs. Job finalized 8/2/11.						
50795	11A0269	Chase Argano Electric Inc. 97-46 99th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PCA Senior Residence 31-34 33rd Street Astoria NY	Approved	\$650.00
Feeder and conduit sizes to panel "HMDP" not shown. Job finalized 8/20/12.						

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50796	11A0270	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	861 Lexington Avenue New York NY	Approved	\$650.00
Verify routing of F.P. tap through Con ED CT compt. Job finalized 12/24/12. 5/6/14 Swapped Revision #3.						
50797	11A0271	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	2260 Crotona Avenue Bronx NY	Approved	\$650.00
Doors in switchboard room to swing out. Job finalized 9/27/12.						
50798	11A0272	Strand Electric Co., Inc. 160 Eleventh Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Marry Manning Walsh Home 1339 York Avenue New York NY	Approved	\$650.00
50799	11A0273	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Milford Plaza 270 West 45th Street New York NY	Approved	\$650.00
1) Wiring method from generator to ESBD and to retail distribution board not shown. 2) Vertical bus in Section 3 of ESBD not shown. 3) Equipment grounding conductor undersized from transformer to 400 amp disconnect switch drawing AB50-4 of 4, and fire pump 1 of 4. 4) Are new fire pump feeders fire rated? Drawing 3 of 4. 5)AB50 2 of 2 fire alarm tap misidentified. 6) Line and load in same cubicle SBD-1. 7) 200A UNF switch feeding F.A. not permitted. 7/28/13 job finalized. 12/10/13 Swapped AB501 1 thru 4 FP80 1 & 2 all Rev 3's.						
50800		Eastern Electrical Construction Inc. 149-07 14th Avenue Whitestone NY 11357	Requesting permission due to the building having no common areas to leave as installed 8 service switches that are not grouped together	42 Industrial Loop Staten Island NY	Approved	\$350.00
With the stipulation that signage is provided at the meter indicating where the other services are located. Each meter pan shall be labeled indicating which unit it serves.						

ADVISORY BOARD CALENDAR

July 13, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50801		Joseph R. Loring & Consulting Engs 21 Pennsylvania Plaza New York NY 10001	Requesting permission to install service bus duct approximately 25 feet in a locked fire rated service room	Court Officers Academy Brooklyn NY	Approved	\$0.00
50802		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to install UF cable or jacketed MC cable as a wiring method for rooftop garden lighting, or permission to install non metallic rigid conduit as a wiring method for rooftop garden lighting	850 Third Ave. 17th fl. roof terrace. New York NY	Approved	\$0.00
50803		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting a one-time one location special permission to install paralleling switchgear in an exterior enclosure and only provide 6-1/4 inch clearance between the enclosure floor and the load side bus	Deutsche Bank 60 Wall Street New York NY	Approved	\$0.00