

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48096CO2	07A0407CO2	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Alliance Bernstein 1345 Avenue of the Americas New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting.						
48774CO	08A0297CO	Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	160 Riverside Drive New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting. Undersized bus in Sec. 2. Job finalized April 23, 2009.						
48814CO	08A0273CO	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	East River Science Park 450 East 29th Street New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting.						
48853	08A0357	N.J.D. Wiring & Electric, Inc. 213--08 99th Avenue Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	PS/IS 366 963 East 107th Street Brooklyn NY	Approved	\$650.00
1) 3 sets of 500 mcm fused at 1200 amps. 2) 1 set of #2 fused at 300 amps. 3) Lack of fuse coordination between 400A fuse in 'LDB' and 1200A fuse in service switch. Job finalized April 24, 2009.						
48854	08A0358	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Queens College-Student Housing 64-80 Kissena Blvd. Flushing NY	Approved	\$650.00
1) Panel PDP does not match physical. 2) Provide bus size that feeds service switches 2 and 3. Job finalized 8/5/08.						

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48855	08A0359	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	301 East 64th Street New York NY	Approved	\$650.00
48856	08A0360	Urban Power & Lighting, Inc. 227 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Flushing Town Center 40-22 College Point Boulevard College Point NY	Approved	\$650.00
<p>1) Fire pump service switch and line side conductors are undersized (typical service 'B', ss #4, and 'C' ss #6). 2) Remove neutral bond on 2000A switch in: DSB-6A-T1", "DSB-6B-T2", "DSB-6C-T3". 3) 1/0 tap conductors fused at 1600A too small (future retail tenant 'B-01D'). 4) Room layout, mark switchboards where the service switches are located and show all clearances in inches. Job finalized 11/28/08.</p>						
48857	08A0361	RPM Electric 480 10th Avenue New York NY 10018	Requested approval for the electric service equipment proposed to be installed	4875 Baldwin Street Bronx NY	Approved	\$650.00
48858	08A0362	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Two Trees Development 194 Atlantic Avenue Brooklyn NY	Approved	\$650.00
<p>1) 5' clearance is required in front of service switch #5. 2) SEB bus is undersized. 3) Service conductors feeding 3000A CT cabinet undersized. Job finalized 7/30/08.</p>						
48859	08A0363	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	839 6th Avenue New York NY	Approved	\$650.00
<p>1) 2000 amp fusing requires 250 MCM equipment grounding conductor. 2) Is open bottom switch gear being used? Job finalized 7/31/08.</p>						

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48860	08A0364	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Mitsui 200 Park Avenue New York NY	Approved	\$650.00
Verify that tap is not over 10 feet. Job finalized 7/18/08.						
48861	08A0365	Guth Deconzo Consulting Engineers 242 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint Generator Reconnect 111 8th Avenue New York NY	Hold	\$650.00
1) 3000 amp fusing requires 300 MCM equipment grounding conductors. 2) Explain bonded neutral in emergency board. 3) Provide exact job detail work, what conductors were extended and where.						
48862	08A0366	Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	H.S. 440R 485 Clawson Street Staten Island NY	Approved	\$650.00
48863	08A0367	alvatore Campisi & Sons Electl Contrs, Inc 453 Onderdonk Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	460 West 34th Street New York NY	Ok, but	\$650.00
2000 amp fusing requires 200 MCM equipment grounding conductors.						
48864	08A0368	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	110 Lafayette Street New York NY	Ok, but	\$650.00
1) #4 equipment grounding conductor needed for 3/0 service entrance conductors. 2) Service switches #6 and 3 to pick up grounding electrode conductor.						

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48865	08A0369	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	401 East 110th Street New York NY	Approved	\$650.00
48866	08A0370	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Royal Plaza 132-35 41st Road Flushing NY	Approved	\$650.00
48867	08A0371	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	150-24 Northern Blvd. Flushing NY	Approved	\$650.00
1) Confirm 5' clearance in front of new 800A service switch. 2) Identify area adjacent to "No door egress" Job finalized 7/31/08.						
48868	08A0372	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Friendly Hands Apartments 225 East 118th Street New York NY	Approved	\$650.00
Confirm 5' clearance in front of fire pump service switch. Job finalized 7/31/08.						
48869	08A0373	Champion Electric, Inc. 33-70 Prince Street, Suite #C4 Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Rio Churrasna Restaurant 127 West 43rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48870	08A0374	Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Internap Expansion 111 Eighth Avenue New York NY	Hold	\$650.00
1) Provide generator room layout. 2) Bus sizes not on 1-lines. 3) Feeders conductors off of generator undersized. 4) It is recommended that a barrier be installed between line and load in the paralleling gear.						
48871	08A0375	Falcon Electrical Contracting Corp. 164 20th Street, Suite 2E Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	211 West 61st Street New York NY	Ok, but	\$650.00
Fuse size in fire pump service switch not provided.						
48872	08A0376	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Emigrant Savings Bank 6 East 43rd Street New York NY	Approved	\$650.00
1) Provide manufacturers information on the combo starter. 2) Is the starter listed for use as service equipment. Job finalized 8/20/08.						
48873	08A0377	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	823 Park Avenue New York NY	Approved	\$650.00
48874	08A0378	Redline Electric Inc. 1715 East 9th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	Precision Gear 112-07 14th Avenue College Point NY	Approved	\$650.00
1) Remove neutral bond in 600 amp disconnect switch. 2) Fuses in board TRS. Job finalized 7/31/08.						

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48875	08A0379	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	103-00 Foster Avenue Brooklyn NY	Approved	\$650.00
Provide ventilation in service room. Job finalized 7/31/08.						
48876	08A0380	erified Electrical & Technical Services, In 27 Williams Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	19 East 80th Street New York NY	Ok, but	\$650.00
Provide proof from the switch manufacturer that dual terminations can be installed on the load side of the service switch.						
48877	08A0381	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requested approval for the electric service equipment proposed to be installed	1345 6th Avenue New York NY	Approved	\$650.00
1) Feeder that are fused at 2500 amps requires 350 MCM equipment grounding conductors. 2) Verify that new and existing switchgear has open bottoms. Job finalized 8/8/08.						
48878	08A0382	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Jack Resnick & Sons 250 Hudson Street New York NY	Ok, but	\$650.00
1) Remove neutral bond at generator and ground frame only. 2) Equipment grounding conductors throughout drawing are undersized 250.122 for fused conductors. 3) Verify if open bottom equipment is being used. 4) FCO on emergency side not connected online side of generator main. 5) Provide emergency side feeder and conduit type for smoke purge circuit. 6) Remove neutral bonds in 2-200 amp disconnect switches. 7) Provide length of tap to switchboard B.. 8) Provide service room layout.						
48879	08A0383	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Lincoln Center Redevelopment New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48880	08A0384	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU-Cogen Expansion 240 Mercer Street New York NY	Ok, but	\$650.00
Service room door to open out.						
48881	08A0385	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Metro Campus Qns Global H.S. 91-30 Metropolitan Avenue Forest Hills NY	Approved	\$650.00
48882	08A0386	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 453 York Avenue aka East 77th Street New York NY	Approved	\$650.00
48883	08A0387	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	170 West 233rd Street Bronx NY	Ok, but	\$650.00
1) Provide feeder infor for "Metro PCS". 2) Why is Metro PCS doubled metered?						
48884	08A0388	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	424 West 33rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48885	08A0389	Techno-Volt Electric, Inc. 28-31 119th Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	Bronxdale Apartments 2011 Holland Avenue Bronx NY	Approved	\$650.00
48886	08A0390	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	155 West 68th Street New York NY	Approved	\$650.00
48887	08A0391	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	50 West 23rd Street New York NY	Approved	\$650.00
48888		Lizardos Mechanical & Electrical Eng. 240 West 35th Street, Suite 304 New York NY 10001	Requesting concept approval	Columbia University New York NY	Approved	\$0.00
With the stipulation that						
48889		ARUP 155 Avenue of the Americas New York NY 10013	Requesting permission to install an additional electrical service in a large single lot building where the existing service is to small to operate new equipment.	826 Washington Street New York NY	Approved	\$0.00



# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48890		Saylor Electric Inc. 153-44 South Conduit Avenue Jamaica NY 11434	Requesting permission due to extreme hardship to leave as installed in 16 new 2 and 3 family buildings no separate meter and panel for common area branch circuits.	2 and 3 Family homes at 172nd St. Queens NY	Approved	\$0.00
48891		June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requesting concept approval for electrical closet room layouts in a new building.	47-49 East 34th Street New York NY	Denied	\$0.00
This is a completely new building undergoing construction and the electrical closets shall be sufficient in size to comply with all sections of Article 110.26.						
48892		Liker Associates Consulting Engineers. 1001 Avenue of the Americas New York NY 10018	Requesting permission due to lack of space to install service equipment where the front clearances of service switches is less than 5 and 7 feet in a 1000 KVA service room.	444 Madison Avenue New York NY	Hold	\$0.00
Provide bigger and more detailed drawings showing where con-ed is feeding service not a one for one replacement with a new CT.						
48893		Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requesting permission to replace 2-2500, 1-800, 2-600 amp non ground fault 480 volt disconnect switches with ground fault type in the same enclosures in switchboard "I" and in switchboard "G" replace 4000 amp non ground fault service switch with new 4000 amp ground fault type in the existing enclosure.	Brookfield Properties 1 Liberty Plaza New York NY	Approved	\$0.00
48894		Principal Electrical Corp. 78-06 Jamaica Avenue Woodhaven NY 11421	Requesting permission due to severe hardship to replace to leave as installed AC cable that does not contain an insulated grounding conductor as a wiring method in a place of assembly	Islamic Culture Center 371 East 166th Street Bronx NY	Approved	\$350.00

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48895		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service entrance conductors in rigid non-metallic conduits.	New School-Cloth Academy West 158th Street New York NY	Approved	\$0.00
48896		DVL Consulting Engineers Inc. 137 Fifth Avenue New York NY 10010	Requesting permission to install underground concrete encased service entrance conductors in rigid non-metallic conduits.	New IS 230 Annex 33-55 74th Street Queens NY	Approved	\$0.00
48897		Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requesting permission to install 15 KV high voltage service lateral conductors in concrete encased reinforced thermosetting resin conduits 3 floors to the roof vault and feed the line side of four 2500 KVA network transformers leaving 2 spare empty conduits for future use in a building where con-ed will supply and maintain the network compartments.	East River Plaza 536 East 116th St. and F.D.R. Dr. New York NY	Approved	\$0.00
48898		Douglas Electrical Contracting Corp. 87-25 78th Street Woodhaven NY 11421	Requesting permission to use one field evaluation from a nationally recognized testing laboratory for 2 job sites where two identical component for component photovoltaic systems will be installed.	2 Barnes Ave., and 2925 Matthews / Bronx NY	Approved	\$0.00
With the stipulation that a New York City Electrical inspector verifies that both installations are completely the same.						
48899	08A0392	Conservation Technology, Ltd. 2783 Shermer Road Northbrook IL 60002	Requested approval for use in New York City of your Portable Metal Halide Track Lighting System for Troffer Area (Accessible) Model/Series Numbers: CTL8116R204B4SP.		Hold	\$200.00
1) UL Report(Report-Actual). 2) Including installation instructions-showing (Ballast mounting, track mounting), power supply cord location.						

# ADVISORY BOARD CALENDAR

**July 16, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48900		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to replace one for one all existing electrical equipment for a 1000 KVA service room with new and leave as installed 4-sets of 500 MCM that will feed frame ratings of 3600 amps where the peak electrical demand is 228 KW, 792 amps.	Grace Dodge Voc. H.S. 2474 Crotona Avenue Bronx NY	Hold	\$0.00

1) Does school operate during the summer. 2) Provide demand load from con-ed.