

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

BOARD MEMBERS PRESENT: BUNK, CATALANO, COHEN, COLUCCIO, DAUBERGER, GIMBUT, LORENZ, MARCOVICI, MAZZEO, MILLER, MONIZ, PACE, PANARIELLO, PESCATORE, PETROU, XANTHOS, CHAIRMAN ZEC AND DIRECTOR MINTZ.

- 44186 Alternative Power Inc. Sub. #02A0459
160 Fifth Avenue, Suite 711
New York, NY 10010-7003 **Hold**
- Requested approval of the **Photo Voltaic System** proposed to be installed in the building at: Greenpoint Mfg. and Design Ctr.
810 Humbolt Street
Brooklyn, NY
- 44187 Robert B. Samuels Inc. **Ok** Sub. #02A0461
48 West 25th Street **Revision Pending**
New York, NY 10010
- Requested approval for the electric service equipment proposed to be installed in the building at: NY Stock Exchange
14 Wall Street
New York, NY
- 44188 Zwicker Electric Co., Inc. **Ok** Sub. #02A0462
200 Park Avenue South **Revision Pending**
New York, NY 10003
- Requested approval of the **Emergency Paralleling Switchgear** proposed to be installed in the building at: 9 MetroTech Center South
Brooklyn, NY
- 44189 Electric Light & Power, Inc. Sub. #02A0463
463 Wild Avenue
Staten Island, NY 10314 **Hold**
- Requested approval for the electric service equipment proposed to be installed in the building at: Babies R' Us
2655 Richmond Avenue
Staten Island, NY
- 44190 Commercial Electrical Contractors, Inc. Sub. #02A0464
10-28 47th Avenue
Long Island City, NY 11101 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building at: Mount Sinai Medical Center
1176 5th Avenue
New York, NY
- 44191 James F. Volpe Electrical Contracting Corp. Sub. #02A0465
81 Sackett Street
Brooklyn, NY 11231 **Approved**
- Requested approval for the electric Polytech University Athletic Facility

service equipment proposed to be installed in the building at:

6 MetroTech
Brooklyn, NY

-1-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

- | | | |
|--|-----------------|--|
| 44192 Solar Electric Systems Inc.
452 West 55 th Street
New York, NY 10019 | Hold | Sub. #02A0466 |
| Requested approval for the electric installed in the building located at: | | 425 Fifth Avenue
New York, NY |
| 44193 Linco Electrical Contracting, Inc.
5442 Arthur Kill Road
Staten Island, NY 10307 | Hold | Sub. #02A0467 |
| Requested approval for the electric service equipment proposed to be installed in the building located at: | | Eger Nursing Home
140 Meisner Avenue
Staten Island, NY |
| 44194 Unity Electric Co., Inc.
65-45 Fresh Meadow Lane
Flushing, NY 11365 | Approved | Sub. #02A0468 |
| Requested approval for the electric service equipment proposed to be installed in the building located at: | | JP Morgan Chase
277 Park Avenue
New York, NY |
| 44195 Jen Electrical Contractors, Inc.
7812 New Utrecht Avenue
Brooklyn, NY 11214 | Approved | Sub. #02A0469 |
| Requested approval for the electric service equipment proposed to be installed in the building located at: | | 750 6 th Avenue
New York, NY |
| 44196 J.A. Lee Electric Inc.
10-18 47 th Road
Long Island City, NY 11101 | Approved | Sub. #02A0470 |
| Requested approval for the electric service equipment proposed to be installed in the building located at: | | 70 Washington Street
New York, NY |
| 44197 Kullman Industries, Inc. | | Sub. #02A0471 |

One Kullman Corporate Campus Drive
Lebanon, NJ 08833 **Hold**

Requested approval for the **wiring of the modular classroom building** located at:

P.S. 40
91 Henderson Avenue
Staten Island, NY

-2-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

44198 Lina Electric Corp.
32-51 56th Street
Woodside, NY 11377

Approved

Sub. #02A0472

Requested approval for the electric service equipment proposed to be installed in the building located at:

Pepsi-Cola
116-02 15th Avenue
Queens, NY

44199 Egg Electric Inc.
26 West 17th Street
New York, NY 10011-5710

Approved

Sub. #02A0473

Requested approval for the electric service equipment proposed to be installed in the building located at:

Grand Concourse Plaza
Fordham Service Entrance
2501-2525 Grand Concourse
Bronx, NY

44200 Barth-Gross Electric Co., Inc.
110 West 26th Street
New York, NY 10001

Approved

Sub. #02A0474

Requested approval for the electric service equipment proposed to be installed in the building located at:

2 East 61st Street
New York, NY

44201 E. Fitzgerald Electric Co., Inc.
98-16 Rockaway Beach Blvd.
Rockaway Park, NY 11693

Approved

Sub. #02A0475

Requested approval for the electric service equipment proposed to be installed in the building located at:

41 Union Square
New York, NY

44202 Conserve Electric, Inc.
1501 Broadway-Suite 414
New York, NY 10036

Approved

Sub. #02A0476

Requested approval for the electric service equipment proposed to be installed in the building located at:

75 Broad Street
New York, NY

44203 Savery S. Manfredonia, P.E., P.C.
14 Ponds Lane
Purchase, NY 10577

Sub. #02A0477

Approved

Requested approval for the electric service equipment proposed to be installed in the building at:

Tiffany Building
401 Fifth Avenue
New York, NY

-3-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

44204 H.P. Electrical Designs Inc.
32 West 44th Street-Suite 405
New York, NY 10036-5404

Sub. #02A0478

Approved

Requested approval for the electric service equipment proposed to be installed in the building at:

Liberty Lofts
43 West 64th Street
New York, NY

44205 Wade Electric, Inc.
30-91 12th Street
Long Island City, NY 11102

Sub. #02A0479

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

J.D. Weiler-Einstein Medical Center
1825 Eastchester Road
Bronx, NY

44206 Atkinson Koven Engineers, LLP
1501 Broadway-Suite 700
New York, NY 10036

Ok

Revision Pending

Requesting a one-time special permission to provide emergency power to the freight elevator by running a 20 foot vertical feeder via the freight shaftway, as per submitted specifications and sketch, in a building located at:

N.Y.C. Technical College
186 Jay Street
Brooklyn, NY

44207 Ambrosino DePinto & Schmieder Consulting Engineers, PC
275 Seventh Avenue
New York, NY 10001

Approved

Requesting a variance to allow for twelve junction boxes on a single 15 amp lighting circuit, where the total load

Burberry Retail Store

will not exceed 896 watts at 120V, as per submitted specifications and wiring diagram, in a building located at:

9 East 57th Street
New York, NY

44208 Robert Derector Associates
1156 Avenue of the Americas
New York, NY 10036

Approved

Requesting permission to energize two floor boxes (15 amp duplex receptacles) via a single 20 amp 120V circuit, developed in conjunction with renovated premises to accommodate additional tenants relocated to this location due to the 9/11/01 attack, as per submitted specifications, in a building located at:

Deutsche Bank
60 Wall Street
New York, NY

-4-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

44209 Robert B. Samuels Inc.
48 West 25th Street
New York, NY 10010

Ok

Revision Pending

Requesting permission to leave as installed grounding of the service to the building steel, in lieu of the water main, since the service is located at the 60th floor of the building:

405 Lexington Avenue
New York, NY

44210 Marty Dorkin
Licensed Electrical Contractor
547 Coney Island Avenue
Brooklyn, NY 11218

Approved

Requesting permission to use UL listed fiberglass conduit to be split lengthwise and fitted around conductors, as a suitable barrier in pull boxes, to be suitably clamped and with a label showing the voltage to be placed on the barrier, in a building located at:

406 West 31st Street
New York, NY

44211 L.E.A. Electric Service Corp.
2112 Broadway-Suite 204
New York, NY 10023

Approved

Requesting permission to replace two 100 amp distribution switches, fed from a 1200 amp service switch with one 200 amp distribution switch, on a 1000 KVA installation, without having to file a full

135 West 50th Street

submission to the Advisory Board, in a building located at:

New York, NY

44212 S.J. Electric, Inc.
601 Union Street
Brooklyn, NY 11215

Approved

Requesting permission to install switchboard 'B', which is 18" away from the foundation wall, instead of the 24" originally specified in the Advisory Board approved drawings (Calendar #44000), due to a construction error in the gear, that was already built and delivered to the site, as per submitted specifications and sketches, for a building located at:

500 West 56th Street
New York, NY

44213 Topaz Lighting Corp.
925 Waverly Avenue
Holtsville, NY 11742

Approved

Requested approval for use in New York City of your Steel EMT Set Screw Connectors and Couplings from ½" up to 4" and Steel EMT Compression Connectors and couplings from ½" up to 4".

Sub. #02A0457

-5-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

44214 Peerless Lighting
2246 Fifth Street
Berkeley, CA 94710

Hold

Requested approval for use in New York City of your Lightedge EG Wall Mount Lighting Fixtures, Models EGAW and EGSW with SWP90 Connector.

Sub. #02A0458

44215 Nippon Electric Co., Ltd.
1-22-16 Shinkamata, Otaku
Tokyo 144-0054 Japan

Hold

Requested approval for use in New York City of your Seamless Fluorescent Lighting Fixtures, Models: SAL-U500A (120V) and SAL-U500C (277V), Standard and Dimmable.

Sub. #02A0460

44216 Five Star Electric Corp.
101-32 101st Street
Ozone Park, NY 11416-2616

Approved

Requesting permission for the connection of a fire pump, which uses a generator for emergency power, as per submitted drawings, in a building located at:

Leon M. Goldstein H.S.
1830 Shore Boulevard
Brooklyn, NY

44217 G.G. Electric Corp.
57-37 Main Street
Flushing, NY 11355

Approved

Requesting permission to install a ten foot length of PVC conduit between a submersible pool light and the deck box, for swimming pool installation as per submitted sketch and equipment details, at a building located at:

82-16 214th Street
Hollis Hills, NY

44218 Pem Electrical Corp.
36-14 32nd Street
Long Island City, NY 11106

Approved

Requesting permission to use PVC conduit under slab from the end box to the service board, where each conduit will contain a grounding conductor, in a building located at:

2828 Broadway
New York, NY

44219 New York City Housing Authority
23-02 49th Avenue
Long Island City, NY 11101

Approved

Requesting permission to use existing elevator hoistways for the installation of the main feeders supplying power to the elevators, in eight buildings located at:

Pelham Parkway Development
2325, 2355 & 2385 Williamsbridge Rd.,
2324, 2354 & 2384 Paulding Avenue,
2460 Bronxwood Avenue and
2250 Wallace Ave.
Bronx, NY

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

- 44220 Pem Electrical Corp. Sub. #02A0480
36-14 32nd Street
Long Island City, NY 11106 **Approved**

Requested approval for the electric service equipment proposed to be installed in the building at:

Columbia University School and Faculty Housing
2828 Broadway @ 110th Street
New York, NY
- 44221 Spider Manufacturing Inc. Sub. #02A0481
#5 364 Loughheed Rd.
Kelowna, B.C. V1X7R8 **Approved**

Requested approval for use in New York City of your Modular Wired Device Box for SMI Desking System, Model: WSCS-FF.
- 44222 Columbia University
500 West 120th Street
New York, NY 10027 **Approved**

Requesting a reconsideration of a prior request (Calendar #44167) to run low voltage audio, video and control cables using plenum cable via the buildings electric closets, that was denied because the electrical code prohibits running exposed cables through electrical cabinets, which will be enclosed within flexible metal conduits, as per submitted specifications, in a building located at:

Columbia University
S.W. Mudd Building
New York, NY
- 44223 Solar Electric Systems, Inc.
456 West 55th Street
New York, NY 10019 **Approved**

Requesting permission to install seven service switches, where four are for fire pumps, and one each for retail, owner and tenant distribution, in a building located at:

425 Fifth Avenue
New York, NY
- 44224 Amerlux, Inc. Sub. #02A0482
23 Daniel Road East
Fairfield, NJ 07004 **Approved**

Requested approval for use in New York City of your Incandescent Lighting Fixture, Track Mount, Surface Mount or Portable, Model: Murro.
- 44225 Sportlite, Inc. Sub. #02A0483
5355 N. 51st Avenue, #26
Glendale, AZ 85301 **Approved**

Requested approval for use in New York City of your
Fluorescent Lighting Fixture, Model: LX-800.

-7-

**ADVISORY BOARD CALENDAR
JULY 17, 2002**

Carry-overs:

<u>Cal. #</u>	<u>Original Meeting Date</u>	<u>Disposition</u>
43823	(3/13/02) Equipment	Denied
43933	(5/1/02) Service	Approved
44038	(6/12/02) Service	Denied
44050	(6/12/02) Service	Denied
44114	(6/12/02) Equipment	Denied
44122	(7/3/02) Service	Approved
44137	(7/3/02) Service	Ok-Revision Pending
44166	(7/3/02) Special Permission	Approved

Note-Advisory Board approvals are specific to the condition and specification detailed in the request and should not be construed as precedent for other installations.

