

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51346	12A0005CO	Kramer Electric, LLC 28 West 27th Street, Suite 701 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Approved	\$0.00
Carry over from June 13, 2012 meeting. 1) Verify that new service equipment does not have removable rear covers, otherwise 2nd egress is required. 2) Pull out fuse missing type(coordination is ok). Job finalized 8/9/12. 7/29/15 Swapped Drawing 1-Revision 6 and Drawing 2-Revision 3.						
51328	12A0027CO	Robert Magoolaghan Inc. 240 Beach 116th Street Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	435 Greenpoint Avenue Brooklyn NY	Approved	\$0.00
Carry over from June 13, 2012 meeting.						
51329	12A0028CO	alvatore Campisi & Sons Electl Contrs, Inc 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	237 West 35th Street New York NY	Approved	\$0.00
Carry over from June 13, 2012 meeting.						
	12A0040CO	Kleinknecht Electric Co., Inc. 252 West 37th Street, 1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue New York NY	On Hold	\$0.00
Carry over from June 13, 2012 meeting. 1) Conductor sizing is not adequate for the ambient temperature. 2) Provide equipment grounding conductor for feeders. 3) Provide drawings showing how conductor enter switches and switchboard physically. 4) Confirm that generator enclosure has mechanical ventilation. 5) Confirm that generators don't feed life safely.						
51226CO2	12A0072CO	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	New York University 21 Washington Place New York NY	Approved	\$0.00
Carry over from June 13, 2012 meeting. 9/16/13 Drawing swapped for Rev. 2 on 2, Rev 2 on 1,						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50908CO	12A0075	Demand Electric, Inc. 1219 Rockaway Avenue Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	Linden Guild Hall 3859 Third Avenue Bronx NY	Approved	\$0.00
Carry over from October 19, 2011 meeting.						
	12A0076	C.M.Richey, Inc. Electrical Contractors 712 Fifth Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	CVS 300 Park Avenue South New York NY	Denied	\$0.00
Carry over from October 19, 2011 meeting. 1) 4th resubmittal is not in Advisory Board format. 2) Electrical room does not show the dimensions and clearances of equipment. 3) Fuse sizes for new and existing equipment not shown 4) Physicals of the new equipment not provided.						
51001CO3	12A0077	J & R Rey Electrical Contrs Inc. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	250 East 57th Street New York NY	Approved	\$0.00
Carry over from April 18, 2012 meeting.						
51136CO	12A0078	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	55 Water Street New York NY	Approved	\$0.00
Carry over from March 14, 2012 meeting.						
51137CO2	12A0079	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	85 St. Nicholas Terrace New York NY	Approved	\$0.00
Carry over from May 2, 2012 meeting. 11/24/14 Swapped SSL-3038 pages 1 of 2, and 2 of 2 Revision 3.						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0080	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Mutual of America 320 Park Avenue New York NY	On Hold	\$650.00
1) Provide cut sheets for generators showing that they are listed as a complete with 777 KCM and 4/0 DLO conductors. 2) Show fuse size on normal side for fire pump. 3) Equipment grounding conductor for fire pump undersized. 4) EGS-1 shall have 5' clearance. 5) EGS-1 shall have two means of egresses. 6) Provide cut for generators, grounding and bonding. 7) Cable cut for DLO. 8) Provide coordination study.						
51288	12A0081	Litespeed Electric, Inc. 135 West 29th Street, Suite 301 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Lenox Hill Hospital 210 East 64th Street New York NY	Approved	\$650.00
51289	12A0082	A.T.J. Electrical Co., Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	PS-87Q 67-54 80th Street Queens NY	Approved	\$650.00
51290	12A0083	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	USTA ITC NATS Project 123-40 Roosevelt Avenue Flushing NY	Approved	\$650.00
	12A0084	APS Electric Inc. 83-32 Parsons Blvd. Jamaica NY 11432	Requested approval for the electric service equipment proposed to be installed	456 Grand Street Brooklyn NY	On Hold	\$650.00
1) Show AIC at PLP panel and meter banks. 2) Show main bonding jumper in service equipment. 3) Indicate series rating for circuit breakers and meter banks.						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51409	12A0085	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	267 6th Street Brooklyn NY	Approved	\$650.00
1) Fire pump feeders not fire rated, & verify. 1-set of 4-300 MCM to fire pump motor. 2) Show AIC at meter banks. Job finalized 9/25/12.						
51606	12A0086	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	544 Union Avenue Brooklyn NY	Approved	\$650.00
1) Show splice detail to 2-200 amp disconnect switches. 2) Correct service size and conductor sizes for 2-200 amp disconnect. Job finalized 3/28/13. 2/27/14 Swapped 1 & 2 Revision 5.						
	12A0087	D & D Electric Contracting Corp. 720 Fifth Avenue, 10th Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	237 West 54th Street New York NY	On Hold	\$650.00
1) Provide documentation showing that the transformer can be installed against the walls. 2) Service room to have mechanical ventilation. 3) Primary of transformer bonded and grounded. 4) Bus undersized on load side of 3000 amp switch. 5) Explain 2-sets of 4/0 terminated to 30 amp switch. 6) Where is fire pump service switch located? 7) Separately derived systems not bonded and grounded.						
51567	12A0088	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Oakwood Beach Pollution Plant 751 Mill Road Staten Island NY	Approved	\$650.00
1) Show clearances in front of switchgear. 2) Provide elevation drawings for service bus. 3) What type of medium voltage cable is being installed. 4) Show clearance in back of 5KV switch 52-FA to be 5' or ask for special permission. 5) Show splice chamber on the outside. Job finalized 2/8/13.						
	12A0089	Kleinberg Electric Inc. 437 West 16th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	375 Front Street Staten Island NY	Pending	\$650.00
Generator cut sheet not provided. Is it listed?						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51291	12A0090	Athens Electric, Inc. 1980 63rd Street Brooklyn NY 11204	Requested approval for the electric service equipment proposed to be installed	72 Spring Street New York NY	Approved	\$650.00
51292	12A0091	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	907 5th Avenue New York NY	Approved	\$650.00
51293	12A0092	Samson Electric Corp. 825 8th Avenue, 2nd Floor New York NY 10019	Requested approval for the electric service equipment proposed to be installed	200 Madison Avenue New York NY	Approved	\$650.00
51294	12A0093	Ramdeen s Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	Berean Apartments 110 Rochester Avenue Brooklyn NY	Approved	\$650.00
4/14/14 Swapped Revision 1.						
51295	12A0094	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	155 East 29th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51296	12A0095	Interstate Electric LLC 304 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	96-02 57th Avenue Queens NY	Approved	\$650.00
51297	12A0096	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza New York NY	Approved	\$650.00
51343	12A0097	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 435 Hudson Street New York NY	Approved	\$650.00
Verify 2-1/4"x4" bus feeding existing 3000 amp service switch. Job finalized 8/3/12.						
51298	12A0098	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	160 Varick Street New York NY	Approved	\$650.00
4/1916 Swapped Drawing 1-Revision 1.						
51299	12A0099	I.P. Electric Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Supermarket at Hotel De Point 20-07 127th Street College Point NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51300	12A0100	Alkem Electrical Corp. 557 Lefferts Avenue Brooklyn NY 11225	Requested approval for the electric service equipment proposed to be installed	Hotel De Point 20-07 127th Street College Point NY	Approved	\$650.00
51301	12A0101	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	29 Broadway New York NY	Approved	\$650.00
51302	12A0102	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Times Building 229 West 43rd Street New York NY	Approved	\$650.00
51303	12A0103	Joseph Weinstein Electric Corp. 94-24 88th Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Staples Store 699 6th Avenue New York NY	Approved	\$650.00
51304	12A0104	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	261 West 125th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51305	12A0105	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Holiday Inn 150 Delancy Street New York NY	Approved	\$650.00
51306	12A0106	US Electric Corp. 13-07 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	800 St. Anns Avenue, Bldg. D Bronx NY	Approved	\$650.00
51307	12A0107	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	515 9th Avenue New York NY	Approved	\$650.00
7/31/15 Swapped Drawings 1 and 2-Revision 3s. 10/30/15 Swapped Drawings 1 and 2, Revision 4s. Nor more as built for the submittal.						
	12A0108	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	375 Pearl Street New York NY	On Hold	\$650.00
1) Show all clearances in generator rooms. 2) Bus to 2000 amp switch in panel BC 04 MGDP undersized. 3) Provide size of through bus in panel BC 04 GDP AO1 and bus to 3000 amp switch undersized. 4) Show feeder sizes off of panel m1 04 04 GDP B01. 5) Show feeder sizes to panels. 6) Show bonding and grounding. 7) Provide demarcation lines for work limit and reference other submission no. 8) Include single line indicating work. 9) BC 04-GDP-AO1, correct trips and sizes on board. 10) Indicate cable and cond. Size next to feeders(many labels are misplaced)						
51344	12A0109	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Goldwater N. Skilled Nursing Fac. 1752 Park Avenue New York NY	Approved	\$650.00
Verify that free standing switchboards do not have removable rear doors. 4/16/14 Rejected 1 - 3 Drawing shows change and other Rev 4 drawings -1 and -2 don't indicate any changes. 6/18/14 Swapped drawings 1,2 and 3 Rev 5s.						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51308	12A0110	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	123 Parkside Avenue Brooklyn NY	Approved	\$650.00
3/25/14 Swapped-2 Drawing Rev 1.						
51309	12A0111	AKF 1501 Broadway New York NY 10036	Requested approval for the electric service equipment proposed to be installed	280 Park Avenue New York NY	Approved	\$650.00
51310	12A0112	Mac Electrical Contractors, Inc. 2807 Flatbush Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	25 Broad Street New York NY	Approved	\$650.00
51366	12A0113	Ampere Electric Corp. 200-06 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	18 Extra Pl. aka 22 E. 1st St. New York NY	Approved	\$650.00
Tap conductors are undersized need 2 sets of 600 MCM. Job finalized 8/17/12.						
51311	12A0114	Beacon Electric Corp. 266 Jericho Turnpike Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Starbucks 350 West 42nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51312	12A0115	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Harlem Hospital 512 Lenox Avenue New York NY	Approved	\$650.00
51313	12A0116	Knight Electrical Services Corp. 599 Eleventh Avenue New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Metropolitan Museum of Art 1000 Fifth Avenue New York NY	Approved	\$650.00
4/21/14 Swapped AP-Rev 3 and E Rev 2. 3/30/15 Drawing swapped AP, Revision 3 and E, Revision 3.						
51314	12A0117	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	886 Westchester Avenue New York NY	Approved	\$650.00
	12A0118	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Sims 30th Street Pier Brooklyn NY	Denied	\$650.00
<p>1) The cut sheets for the generator not submitted, showing that the generator is listed and how the disconnect switch connects to the generator. 2) ATS #3 is overfused. 3) Types of the ATS not shown. 4) The bus sizes in the emergency switchboard are not shown. 5) Coordination study not provided. 6) AIC rating of the fire pump controllers not provided, and documentation was not provided showing that the fire pump controller are service rated. 7) Fire pump feeders are not fire rated. 8) Equipment grounding conductor undersized. 9) Fire pump emergency feeder not connected to line side of generator main switch. 10) Bus undersized to 3000 amp switch #3. 11) Elevation drawings not provided. 12) Where are the fences installed? 13) Transformer connection to distribution bus not shown. 14) Clearances of equipment to Bollards not shown. 15) Back of equipment blocked by Bollards. 16) Show types of conduit installed. 17) Main tie main to be 4 pole.</p>						
51315	12A0119	Fresh Meadow Electrical Contractors, LLC 65-01 Fresh Meadow Lane Fresh Meadows NY 11365	Requested approval for the electric service equipment proposed to be installed	Brooklyn Bridge Park 334 Furman Street, Pier 5 Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51400	12A0120	Ohms Electrical Corp. 65-10 Central Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	228 Avenue S Brooklyn NY	Approved	\$650.00
1) Drawings not submitted in Advisory Board format. 2) AIC not provided. 3) Notes not provided on drawing. 4) Fuse types not provided. 5) How far is the tap? Job finalized 9/27/12						
51367	12A0121	Verified Electl & Technical Services, Inc. 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	420 West 45th Street New York NY	Approved	\$0.00
1) Equipment grounding conductor undersized for service entrance conductors. 2) Confirm that ground is connected to collector bar and not ground rod. Job finalized 8/17/12.						
	12A0122	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	CCNY-Steinman Hall 261 Convent Avenue New York NY	Rejected	\$650.00
1) Show clearances on sides of switchgear, and clearance between corners of new equipment and switchboard pads. 2) Equipment grounding conductor on load side of fire pump switch and transformer undersized. 3) Size of fire pump ATS not shown. 4) Provide fuse size for fire pump emergency feeder. 5) Show how the jockey pump is connected in ATS? 11/27/12.-New-The 2 hrs fire rated RHHN cable shown on drawing no longer listed by NRTL as of 9/12/12.						
51316	12A0123	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	41-21 24th Street Queens NY	Approved	\$650.00
51347	12A0124	Tribeca Electrical Corp. 86-08 130th Street Richmond Hills NY 11418	Requested approval for the electric service equipment proposed to be installed	Albany Houses 193 Albany Avenue Brooklyn NY	Approved	\$650.00
1) Who will be altering the distribution panel provide listing documentation? 2) Cut sheet and bus sizing of new panel interior not provided. 3) Show coordination between new panel and fuses. Job finalized 8/9/12.						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0125	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	291 Union Street Brooklyn NY	On Hold	\$650.00
1) Type of fuses in meter banks not shown. 2) Type of circuit breakers in panel re not shown. 3) The circuit breakers in the main panel are not adequate for available short circuit current. 4) Coordination curves not provided.						
51368	12A0126	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	206 East 86th Street New York NY	Approved	\$650.00
Tap to 400 trans S undersized, change fuse or increase conductor Job finalized 8/17/12.						
51369	12A0127	Metro Electrical Contractors, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	1466 Broadway New York NY	Approved	\$650.00
1) Bond neutral to enclosure in emergency fire alarm switch. 2) Generator neutral to be grounded. 3) Panel DP-EM, confirm the panel does not feed life safety system. Job finalized 8/28/12. 7/21/15 Swapped drawings A-Rev 2, B-Rev 4, C and D-Rev. 5s.						
51317	12A0128	Anthony G. Ferry, Inc. 217A Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	500 West 23rd Street New York NY	Approved	\$650.00
51318	12A0129	A.S.R. Electrical Contracting Inc. 876 Jamaica Avenue Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	Menorah Home & Hospital 1516 Oriental Boulevard Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51370	12A0130	Mechanical Electrical Corp. 876 Jamaica Avenue Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	509 West 129th Street New York NY	Approved	\$650.00
Can disconnect switch be turned into room? Job finalized 8/21/12.						
51319	12A0131	Campbell and Dawes Ltd. Electl Contrs 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	NY Public Library 188 Madison Avenue New York NY	Approved	\$650.00
	12A0132	J. United Electrical 651 Willowbrook Road Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	589 Fifth Avenue New York NY	Denied	\$650.00
The newly installed barriers under the switchgear will prevent the proper ventilation required for the equipment.						
51320	12A0133	Spirelli Electric, Inc. 1901 Amethyst Street Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Armani Express 1 DeKalb Avenue Brooklyn NY	Approved	\$650.00
51321	12A0134	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Miller's Ale House 61-35 Junction Blvd. Rego Park NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51322	12A0135	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	165 West 91st Street New York NY	Approved	\$650.00
<p>1) Verify that emergency feeders are not run through the service room. 2) Provide neutral disconnect link in service switch #1. 3) Show AIC at APL-Tel panel. Job finalized 8/21/12. 7/22/15 Swapped drawing "C", Revision 1.</p>						
51371	12A0136	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	404 Park Avenue South New York NY	Approved	\$650.00
<p>1) Confirm that EM BP 13-1 does not feed life safety equipment. 2) Bond neutral to enclosure in 100 amp emergency switch for fire alarm. 3) What is fire alarm switch for in the ATS room. 4) Confirm that ATS SC1 & SC2 are life safety related. Job finalized 10/4/12. 11/25/13 swapped Rev 3.</p>						
51418	12A0137	Platinum Electrical Contracting, Inc. 478 Wild Avenue Staten NY 10314	Requested approval for the electric service equipment proposed to be installed	51 Astor Place New York NY	Approved	\$650.00
<p>1) Neutral in 400 amp emergency switch to be bonded to enclosure. 2) Provide not that all 4 pole ATS' are to be installed. 3) ES-EO-SS board does it supply emergency loads. Job finalized on 1/24/13. 4/10/14 Swapped F Rev 3. 11/17/15 Swapped Drawings E-Rev-0. F-Rev 4, N-Rev and O-Rev 4.</p>						
51560	12A0138	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Whitney Museum of American Art 93 Gansevoort Street New York NY	Approved	\$650.00
<p>1) Only bubble the area of the drawing that is NCW. 2) Neutral disconnect link to be installed on line side of bonding and grounding. 3) Verify the sizing of the service entrance conductors. 4) Bus size to 2500 amp switch not shown. 5) Fire pump feeder size not shown or fire rated. 6) Verify the sizing of the feeder to trough.</p>						
	12A0139	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	93 Worth Street New York NY	On Hold	\$650.00

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51323	12A0140	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission replace an existing defective 5 KV non Con Edison utility loop feeder on Governors Island where the switches and fusing are existing.	Governors Island 10 South Street New York NY	Approved	\$0.00
With the stipulation that the installation meet the current electrical code.						
51324	12A0141	CRM Electric Corporation 465 West 261st Street Bronx NY 10471	Requesting permission to utilize the NYC 2007 Electrical Code to wire a building permit was issued in July 2008, temporary wiring permit filed on 10/13/2010 and permanent wiring was filed in 1/2012 where it would be an extreme hardship to rewire the installation	1778-1800 Southern Blvd. Bronx NY	Approved	\$0.00
51325	12A0142	AKF 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to install unspliced elevator feeders in the elevator shaftway where the elevators are being converted from DC to AC	250 West 57th Street New York NY	Approved	\$0.00
Code: 620.37.						
	12A0143	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission to utilize the 2002 National Electrical Code with NYC Amendments for a project where the new building permit was approved in 2009 with no electrical applications filed until 2010.	CUNY/ASRC 85 St. Nicholas Terrace New York NY	Denied	\$0.00
	12A0144	Top Shelf Electric Corporation 463 Wild Avenue Staten Island NY 10314	Requesting permission to feed 4 separate lots with two service points where the service equipment for two buildings will be installed on the outside of commercial buildings where there is no space to install the equipment indoors.	382, 4384, 4386, 4388 Victory Blvd Staten Island NY	On Hold	\$0.00
1) Provide legal documentation showing that the buildings have one management and one owner. 2) Provide pictures of the installation.						

ADVISORY BOARD CALENDAR

July 18, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51326	12A0145	Teknion, LLC 350 Fellowship Road, Suite 100 Mount Laurel NY 08054	Requested approval of equipment for use in New York City of your Boulevard III Office Panel System		Approved	\$200.00
51327	12A0146	Teknion, LLC 350 Fellowship Rd, Suite 100 Mount Laurel NY 08054	Requested approval of equipment for use in New York City of your Teknion Expansion Caseloads and Tables Office System.		Approved	\$200.00
51330	12A0147	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to leave as installed a conduit containing Argon gas for a Fenwall dry fire protection system installed in the electrical dedicated equipment space.	Croton Water Treatment Plant 3701 Jerome Avenue Bronx NY	Approved	\$0.00
Code: 110.26(F)(1)(A).						