

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45419CO4	04A0017CO4	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from January 14, 2004 meeting.				
45442CO3	04A0024CO3	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from February 18, 2004 meeting. Correct 1-Line o drawing ELP-005 for 'MS-E' Ref. Atlas drawing. Show fire pump feeder concrete encased. 8/24/04-Approval granted.				
45452CO2	04A0034CO2	Requested approval for the electric service equipment proposed to be installed	Hold	\$0.00
Carry over from February 18, 2004 meeting. Submit 1-Line drawing in Advisory Board format.				
45585CO3	04A0142CO3	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from April 14, 2004 meeting				
45586CO3	04A0143CO3	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from April 14, 2004 meeting. 6/13/17 - 1) Not advisory Board Format 2) 2 Copies required. 9/26/17 - 1) Add the job address to the title block. 2) Verify 2hr fire rated room & room is mechanically ventilated. 10/6/17 Swapped drawing #MNY00328, Revision 5.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45627CO	04A0181CO	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$0.00
Carry over from May 19, 2004 meeting. Provide 24" clearance behind service switchboard pull sections.				
45630CO	04A0207CO	Requested approval for the electric service equipment proposed to be installed	ok, but	\$0.00
Carry over from May 19, 2004 meeting. Not reviewed. Will be reviewed next meeting on 8/18/04 meeting.				
45668CO2	04A0195CO2	Requested approval for the electric service equipment proposed to be installed	Hold	\$0.00
Carry over from May 19, 2004 meeting. No show.				
45757CO	-	Requesting permission to install cable TV termination boxes in 3 electrical closets.	Approved	\$0.00
Carry over from June 16, 2004 meeting.				
45761	04A0284	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45762	04A0285	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				
45763	04A0286	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				
45764	04A0287	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				
45765	04A0288	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				
45766	04A0289	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45767	04A0290	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.				
45768	04A0291	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.				
45769	04A0292	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.				
45770	04A0294	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.				
45771	04A0295	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will first ones reviewed at next meeting on 8/18/04.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45772	04A0296	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Clarify fire pump information, FLA is it a fire pump? 2) Show bonding of generator. 3) Show size of line side feeder off of existing 200 amp s.s. 4) What is system voltage.				
45773	04A0297	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45774	04A0298	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
Provide coordination curves between 1600A service switch and MSB panel.				
45775	04A0299	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45776	04A0300	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45777	04A0301	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45778	04A0302	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45779	04A0303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45780	04A0304	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Increase load side bus of 6000 amp service switch. 2) Change 3 sets of 500 MCM to 3 sets of 600 MCM feeding MEXX distribution board. 3) Clarify that service busway is properly braced.				
45781	04A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45782	04A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Service entranc copper detail bus undersized. 6/2/05 item finalized.				
45783	04A0307	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45784	04A0308	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
Service entrance conductors are undersized.				
45785	04A0309	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Increase C.T. bus to line side of service switch as per NYC amendments 800 amps sq". 2) Add supplemental ground.				
45786	04A0318	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
Portable generator to be case grounded only no neutral/ground bond.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45787	04A0321	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
No drawings.				
45788	04A0322	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
) Provide 4-pole ATS's for 4-wire loads. 2) Provide short circuit and coordination study. 3) Provide 1-Line diagram in Advisory Board format.				
45789	04A0323	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide cut-out for F.A. system (208V). 2) Provide 4-pole Ats's for 4-wire load. 3) Provide short circuit & coordination study. 4) Provide 1-Line in Advisory Board format.				
45790	04A0324	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Remove secondary circuit breaker. 2) Provide 4-Pole ATS's on 4-pole loads. 3) Provide 1-Line diagram in Advisory Board format. 4) Provide short circuit and coordination study.				
45791	04A0283	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Show all bus bar sizes. Only main bus & ground shown. 2) Note on bus current density should be corrected. Must meet Article 408. 3) Justify coordination of 3000A fuse & 2000A CB in MDB-YM. Indicate short circuit current rating and available s.c. current. 4) Block rear access to service switchboards with less than 36" clearance.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45792	04A0319	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Show details of 4/0 tap from new 800A switch. 2) Provide details of new 800A switch.				
45793	04A0316	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45794	04A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45795	04A0311	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04-Corrected 9/13/04				
45796	04A0310	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.				

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45797	04A0317	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45798	04A0315	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45799	04A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45800	04A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Install ground on 1200 amp service switch and add supplemental ground on both service switch. 2) Change 600 amp fuse in switchboard HDP to LPN or A2D. 3) Change fuses on 1-600 2-400 from TR to A2D. 4) Remove bus bar nots from drawing.				
45801	04A0320	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45802	04A0325	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45803	04A0326	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45804	04A0327	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45805	04A0328	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45806	04A0329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45807	04A0330	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45808	04A0331	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45809	04A0332	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45810	04A0333	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45811	04A0334	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45812	04A0335	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45813	04A0336	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45814	04A0337	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
45815	04A0338	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Ground generator chasis to building steel. 2) Encase fire pump feed. 3) Provide full load amps of fire pump and provide fire pump information.				
45816	04A0339	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45817	04A0340	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Provide size of service entrance bus. 2) Provide manufactures drawings of physical.				
45818	04A0341	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1)Provide manufactures physical drawings. 2) Provide bus size in CT.				
45819	-----	Requesting permission not to group together service equipment in two 2 family buildings with no common areas.	Approved	\$0.00
45820	-----	Requesting permission not to group together service equipment in a 2 family building with no common area.	Approved	\$0.00
45821	-----	Requesting permission to install two 208 volt air conditioners on one 20 amp circuit breaker in seventy units, each A/C draws 6.9 amps.	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45822	-----	Requesting permission to leave as installed unprotected aluminum conduits that penetrate through a concrete slab into the bottom of 1000 KVA switchboard.	Denied	\$0.00
Section 344.10(A) of the New York City Electrical Code and Underwriter Laboratory standard DYWV prohibit aluminum conduit to be installed in concrete or in contact with soil unless supplementary corrosion protection is applied.				
45823	-----	Requesting permission to install new lighting conduits that will support new 277 volt fixtures that will be supported from existing emergency circuit conduit in hazardous and non hazardous locations.	Hold	\$0.00
1)Must comply 300.11(B) clips must be listed for use of hanging one conduit from another. 2) Fixtures must be braced within 12" of fixtures to avoid sway.				
45824	-----	Requesting permission due to lack of space inside of an existing service room to install a new service switch in an adjacent boiler room.	Approved	\$0.00
45825	-----	Requesting permission to install a fire pump service switch outside the service room and to run its feeder 40 feet in one of the four following methods.	Approved	\$0.00
45826	-----	Requesting permission to install CCTV cabling and conduit in a elevator shaft to provide power to a camera mounted inside of the elevator cab.	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45827	-----	Requesting permission to build a 2 hour fire rated room for a automatic transfer switch inside of an existing service room.	Approved	\$0.00
45828	-----	Requesting permission to install a seventh service switch where one of the existing switches is for a fire pump.	Approved	\$0.00
45829	----- --	Requesting permission to install a seventh switch on a 1000 KVA service where one of he switches is for a fire pump.	Approved	\$0.00
45830	-----	Requesting permission to install a seventh service switch on a 1000 KVA service where one of the switches is for a fire pump.	Approved	\$0.00
45831	----- ---	Requesting permission to retrofit existing fuse panels to circuit breakers.	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Type of Request	Status	Fee
45832	----- -	Requesting permission to utilize 3 sets of 500 MCM and one 1/0 neutral to feed a 1200 amp switchboard.	Approved	\$0.00
45833	----- ---	Requesting permission to leave as installed disconnect switches for air conditioners that are located out of sight in a mechanical room with signage.	Approved	\$0.00
With the stipulation that motor lockouts are provided with signage				
45834	04A0293	Requested approval for use in New York City of your Manufactured Wiring System. Model/Serie Numbers: Metro Furniture "Topo".	Hold	\$200.00
The ceiling infeed and power harness and infeed cables are put on hold pending submittal of additional information on both mechanical and electrical termination and instructions.				
45835	04A0342	Requested approval for use in New York City of your ACS Flex2 and Flex 4 Systems-Modular Wiring Systems	Approved	\$200.00
For use in wiring luminaires in an accessible ceiling in accordance with Article 604 of the New York City Electrical Code.				

