

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45419CO4	04A0017CO4	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Random House 235 West 55th Street New York NY	Approved	\$0.00
Carry over from January 14, 2004 meeting.						
45442CO3	04A0024CO3	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 18, 2004 meeting. Correct 1-Line drawing ELP-005 for 'MS-E' Ref. Atlas drawing. Show fire pump feeder concrete encased. 8/24/04-Approval granted.						
45452CO2	04A0034CO2	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Hold	\$0.00
Carry over from February 18, 2004 meeting. Submit 1-Line drawing in Advisory Board format.						
45585CO3	04A0142CO3	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept. of Environmental 593 East 132nd Street Bronx	Approved	\$0.00
Carry over from April 14, 2004 meeting						
45586CO3	04A0143CO3	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Dept of Environmental 432 East 110th Street New York NY	Approved	\$0.00
Carry over from April 14, 2004 meeting.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45627CO	04A0181CO	The Sound Beyond Electrical Corp. 134 West 29th Street-11th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bklyn District Sanitation 161 Varick Street. Garages 1 and 4 Brooklyn NY	Ok, but	\$0.00
Carry over from May 19, 2004 meeting. Provide 24" clearance behind service switchboard pull sections.						
45630CO	04A0207CO	Hugh O Kane Electric Co., LLC 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	630 Flushing Avenue Brooklyn Ny	ok, but	\$0.00
Carry over from May 19, 2004 meeting. Not reviewed. Will be reviewed next meeting on 8/18/04 meeting.						
45668CO2	04A0195CO2	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Bloomberg 731 Lexington Avenue New York NY	Hold	\$0.00
Carry over from May 19, 2004 meeting. No show.						
45757CO	-	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requesting permission to install cable TV termination boxes in 3 electrical closets.	63 Wall Street New York NY	Approved	\$0.00
Carry over from June 16, 2004 meeting.						
45761	04A0284	UL Electrical Corp. 115-02 Liberty Avenue, 2nd Floor Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	225 Broadway New York NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45762	04A0285	Forum Engineering, P.C 139 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	195 Bowery New York NY 10038	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						
45763	04A0286	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Con Ed 4 Irving Place New York NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						
45764	04A0287	Roz-A-Lite Electrical Contracting Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	220 West 26th Street New York NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						
45765	04A0288	Arc Electrical & Mechanical Contrs, Corp 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Hunter College 71 East 94th Street New York NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						
45766	04A0289	Copper City Electric Corp. 330 East 38th Street-Suite 5G New York NY 10016	Requested approval for the electric service equipment proposed to be installed	242-246 East 25th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45767	04A0290	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	800 3rd Avenue New York NY	Approved	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.						
45768	04A0291	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	ABG Hotel 125 West 45th Street New York NY	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.						
45769	04A0292	ICOR Associates, LLC 21 Commerce Drive Cranford NJ 07016	Requested approval for the electric service equipment proposed to be installed	Parkmed Eastern Women's Ctr 800 2nd Avenue New York NY	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.						
45770	04A0294	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	UBS Building 1285 6th Avenue New York NY	Hold	\$650.00
Not reviewed. Will be first ones reviewed at next meeting on 8/18/04.						
45771	04A0295	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Price Waterhouse Coopers 300 Madison Avenue, 9th Floor New York NY	Hold	\$650.00
Not reviewed. Will first ones reviewed at next meeting on 8/18/04.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45772	04A0296	T.C. Sideris, P.E., P.C. 217-22 Northern Boulevard Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	Loew's Paradise Theater 2401-2419 Grand Concourse Bronx NY	Ok, but	\$650.00
1) Clarify fire pump information, FLA is it a fire pump? 2) Show bonding of generator. 3) Show size of line side feeder off of existing 200 amp s.s. 4) What is system voltage.						
45773	04A0297	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	387 West Broadway New York NY	Approved	\$650.00
45774	04A0298	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Columbia University 1255 Amsterdam Avenue New York NY	Ok, but	\$650.00
Provide coordination curves between 1600A service switch and MSB panel.						
45775	04A0299	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Theodore Roosevelt H.S. 500 East Fordham Road Bronx NY	Approved	\$650.00
45776	04A0300	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	William Taft H.S. 240 East 172nd Street Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45777	04A0301	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Center Mall 90-15 Queens Blvd. Queens NY	Approved	\$650.00
45778	04A0302	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Stop & Shop Retail Parking 89-89 Union Turnpike Forest Hills NY	Approved	\$650.00
45779	04A0303	I.S.M. Electrical Contractor 512 73rd Street Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Civil Term Supreme Court 141 Livingston Street Brooklyn NY	Approved	\$650.00
45780	04A0304	Al s Best Electric Co. Inc. 915 Broadway, Suite #607 New York NY 10003	Requested approval for the electric service equipment proposed to be installed	19 Union Square New York NY	Ok, but	\$650.00
1) Increase load side bus of 6000 amp service switch. 2) Change 3 sets of 500 MCM to 3 sets of 600 MCM feeding MEXX distribution board. 3) Clarify that service busway is properly braced.						
45781	04A0305	Judd Electric Inc. 1097 Second Avenue-Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	35 East 85th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45782	04A0306	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	77 Park Avenue New York NY	Approved	\$650.00
Service entrance copper detail bus undersized. 6/2/05 item finalized.						
45783	04A0307	Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	500 West 37th Street New York NY	Approved	\$650.00
45784	04A0308	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	1849-1851 Sedgwick Avenue Bronx NY	Ok, but	\$650.00
Service entrance conductors are undersized.						
45785	04A0309	Contact Plus Electrical Corp. 247 Van Brunt Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	2257 East 16th Street Brooklyn NY	Ok, but	\$650.00
1) Increase C.T. bus to line side of service switch as per NYC amendments 800 amps sq". 2) Add supplemental ground.						
45786	04A0318	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	American Stock Exchange 86 Trinity Place New York NY	Ok, but	\$650.00
Portable generator to be case grounded only no neutral/ground bond.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45787	04A0321	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Price Waterhouse Coopers 300 Madison Avenue, 9th Floor New York NY	Hold	\$650.00
No drawings.						
45788	04A0322	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 235 East 42nd Street New York NY	Approved	\$650.00
) Provide 4-pole ATS's for 4-wire loads. 2) Provide short circuit and coordination study. 3) Provide 1-Line diagram in Advisory Board format.						
45789	04A0323	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 685 3rd Avenue New York NY	Approved	\$650.00
1) Provide cut-out for F.A. system (208V). 2) Provide 4-pole Ats's for 4-wire load. 3) Provide short circuit & coordination study. 4) Provide 1-Line in Advisory Board format.						
45790	04A0324	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 219 East 42nd Street New York NY	Approved	\$650.00
1) Remove secondary circuit breaker. 2) Provide 4-Pole ATS's on 4-pole loads. 3) Provide 1-Line diagram in Advisory Board format. 4) Provide short circuit and coordination study.						
45791	04A0283	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Atlantic/Court 211 Atlantic Avenue Brooklyn NY	Hold	\$650.00
1) Show all bus bar sizes. Only main bus & ground shown. 2) Note on bus current density should be corrected. Must meet Article 408. 3) Justify coordination of 3000A fuse & 2000A CB in MDB-YM. Indicate short circuit current rating and available s.c. current. 4) Block rear access to service switchboards with less than 36" clearance.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45792	04A0319	Electric Light & Power, Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	820 West End Avenue New York NY	Hold	\$650.00
1) Show details of 4/0 tap from new 800A switch. 2) Provide details of new 800A switch.						
45793	04A0316	Raptor Electrical Construction Corp. 205-07 Hillside Avenue, Suite 27 Hollis NY 11423	Requested approval for the electric service equipment proposed to be installed	636 11th Avenue New York NY	Approved	\$650.00
45794	04A0312	Power Optech, LLC 48-51 36th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street-1st Floor New York NY	Approved	\$650.00
45795	04A0311	Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Verizon Generator 355 Forest Avenue-1st Floor Staten Island NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04-Corrected 9/13/04						
45796	04A0310	Dooley Electric Company, Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Max Capital 230 Park Avenue, Suite 2527 New York NY	Hold	\$650.00
Not reviewed. Will be first ones viewed at next meeting on 8/18/04.						

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45797	04A0317	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	500 Eighth Avenue New York NY	Approved	\$650.00
45798	04A0315	Roz-A-Lite Electric 163 20th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	333 Rector Place New York NY	Approved	\$650.00
45799	04A0314	Enterprise Electrical Contractors Inc. 41 Terrace Place Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Hillman Houses 530 Grand Street New York NY	Approved	\$650.00
45800	04A0313	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	240 Central Park South New York NY	Approved	\$650.00
1) Install ground on 1200 amp service switch and add supplemental ground on both service switch. 2) Change 600 amp fuse in switchboard HDP to LPN or A2D. 3) Change fuses on 1-600 2-400 from TR to A2D. 4) Remove bus bar nots from drawing.						
45801	04A0320	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	731 Flushing Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45802	04A0325	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	85 10th Avenue New York NY	Approved	\$650.00
45803	04A0326	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	589 5th Avenue New York NY	Approved	\$650.00
45804	04A0327	Fred Geller Electrical Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	200 East 42nd Street New York NY	Approved	\$650.00
45805	04A0328	E. Fitzgerald Electric Co., Inc. 98-16 Rockaway Beach Blvd. Rockaway Park NY 11693	Requested approval for the electric service equipment proposed to be installed	82-11 37th Avenue Queens NY	Approved	\$650.00
45806	04A0329	Venus Electrical Contractors, Inc. 34-14 Crescent Street Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	South Bronx High School 701 St. Anns Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45807	04A0330	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	260-280 Herkimer Street Brooklyn NY	Approved	\$650.00
45808	04A0331	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	83-45 Broadway New York NY	Approved	\$650.00
45809	04A0332	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	335 Madison Avenue New York NY	Approved	\$650.00
45810	04A0333	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	598 Madison Avenue New York NY	Approved	\$650.00
45811	04A0334	Chester Schiff, P.E. 45 West 34th Street, Suite 1102 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	151 West 17th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45812	04A0335	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Technicolor 110 Leroy Street-9th Floor/Bsmt New York NY	Approved	\$650.00
45813	04A0336	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	49-05 20th Avenue Astoria NY	Approved	\$650.00
45814	04A0337	Positive Electro Mech. Corp. d/b/a 1327 60th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	142 West 49th Street New York NY	Approved	\$650.00
45815	04A0338	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	94-06 104th Street Ozone Park NY	Ok, but	\$650.00
1) Ground generator chasis to building steel. 2) Encase fire pump feed. 3) Provide full load amps of fire pump and provide fire pump information.						
45816	04A0339	Action Light & Power, Inc. 383 Willoughby Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	15 West 28th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45817	04A0340	A.K. Electrical Contracting Inc. 261 46th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Holmes Towers 1780 First Avenue New York NY	Hold	\$650.00
1) Provide size of service entrance bus. 2) Provide manufactures drawings of physical.						
45818	04A0341	A.K. Electrical Contracting Inc. 261 46th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Holmes Towers 405 East 92nd Street New York NY	Hold	\$650.00
1)Provide manufactures physical drawings. 2) Provide bus size in CT.						
45819	-----	K & R Electric Co., Inc. 638 Sharrotts Road Staten Island Ny 10309	Requesting permission not to group together service equipment in two 2 family buildings with no common areas.	203 Westcott Blvd. Staten Island NY	Approved	\$0.00
45820	-----	K & R Electric Co., Inc. 638 Sharrotts Road Staten Island Ny 10309	Requesting permission not to group together service equipment in a 2 family building with no common area.	1096 Rossville Avenue Staten Island NY	Approved	\$0.00
45821	-----	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requesting permission to install two 208 volt air conditioners on one 20 amp circuit breaker in seventy units, each A/C draws 6.9 amps.	300 West 20th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45822	-----	Atria 2000 Associates, LLC 158-13 72nd Avenue Flushing NY 11365	Requesting permission to leave as installed unprotected aluminum conduits that penetrate through a concrete slab into the bottom of 1000 KVA switchboard.	159-10 71st Avenue Flushing NY	Denied	\$0.00
Section 344.10(A) of the New York City Electrical Code and Underwriter Laboratory standard DYWV prohibit aluminum conduit to be installed in concrete or in contact with soil unless supplementary corrosion protection is applied.						
45823	-----	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install new lighting conduits that will support new 277 volt fixtures that will be supported from existing emergency circuit conduit in hazardous and non hazardous locations.	Newtown Creek W.P.C.P. 301 and 403 Greenpoint Avenue Brooklyn NY	Hold	\$0.00
1)Must comply 300.11(B) clips must be listed for use of hanging one conduit from another. 2) Fixtures must be braced within 12" of fixtures to avoid sway.						
45824	-----	Ambrosino DePinto & Schmieder 275 Seventh Avenue-2nd Floor New York NY 10001	Requesting permission due to lack of space inside of an existing service room to install a new service switch in an adjacent boiler room.	17 Eastern Parkway Brooklyn NY	Approved	\$0.00
45825	-----	Quantum Electric Corporation 30-30 Northern Blvd. Long Island City NY 11101	Requesting permission to install a fire pump service switch outside the service room and to run its feeder 40 feet in one of the four following methods.	Birch Wathern Lenox School 210 East 77th Street New York NY	Approved	\$0.00
45826	-----	New York City Housing Authority 23-02 49th Avenue Long Island City NY 11101	Requesting permission to install CCTV cabling and conduit in a elevator shaft to provide power to a camera mounted inside of the elevator cab.	190 Marcy Ave and 75 Wilson Ave Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45827	-----	Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requesting permission to build a 2 hour fire rated room for a automatic transfer switch inside of an existing service room.	St. Thomas More Church 81-70 Utopia Parkway Queens NY	Approved	\$0.00
45828	-----	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requesting permission to install a seventh service switch where one of the existing switches is for a fire pump.	800 3rd Avenue New York NY	Approved	\$0.00
45829	----- --	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requesting permission to install a seventh switch on a 1000 KVA service where one of he switches is for a fire pump.	200 East 42nd Street New York NY	Approved	\$0.00
45830	-----	E. Fitzgerald Electric Co., Inc. 98-16 Rockaway Beach Blvd. Rockaway Park NY 11693	Requesting permission to install a seventh service switch on a 1000 KVA service where one of the switches is for a fire pump.	82-11 37th Avenue Queens NY	Approved	\$0.00
45831	----- ---	Parkchester South Condominium 2000 East Tremont Avenue Bronx NY 10462	Requesting permission to retrofit existing fuse panels to circuit breakers.	Parchester Condominum Bronx NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

July 21, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45832	----- --	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requesting permission to utilize 3 sets of 500 MCM and one 1/0 neutral to feed a 1200 amp switchboard.	Duane Hall @ Fordham Univ. 441 East Fordham Road Bronx NY	Approved	\$0.00
45833	----- ---	Ostroff Electric Inc. 102-14 159th Road Howard Beach NY 11414	Requesting permission to leave as installed disconnect switches for air conditioners that are located out of sight in a mechanical room with signage.	550 Park Avenue New York NY	Approved	\$0.00
With the stipulation that motor lockouts are provided with signage						
45834	04A0293	Steelcase Inc. 7220 Edgewater Drive Oakland CA 94621	Requested approval for use in New York City of your Manufactured Wiring System. Model/Serie Numbers: Metro Furniture "Topo".		Hold	\$200.00
The ceiling infeed and power harness and infeed cables are put on hold pending submittal of additional information on both mechanical and electrical termination and instructions.						
45835	04A0342	Tyco Engineered Products & Services 260 Duchaine Boulevard New Bedford MA 02745	Requested approval for use in New York City of your ACS Flex2 and Flex 4 Systems-Modular Wiring Systems		Approved	\$200.00
For use in wiring luminaires in an accessible ceiling in accordance with Article 604 of the New York City Electrical Code.						