

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 80-05-M
Report of Material and Equipment Acceptance Division**

Manufacturer- BKG Bunse – Aufzuge, P.O. Box 1229, Paderbohn, Germany D33042.

Trade Name- BKG Bunse- Aufzuge.

Product- Dumbwaiter landing door electro-mechanical interlock assemblies.

Pertinent Code Section(s)- 27-990.

Prescribed Test(s)- RS 18-1 (ANSI A17.1), UL 104.

Laboratory- Canadian Standard Association

Test Report- File No. LR106161-1, dated September 13, 1995.

Description- Dumbwaiter landing interlock assembly model number 13.3.002891 with contact BZ1730-21B/A201/AZ02 and model 13.2.00368-1 with contact BZ1730-21B/AZ02-1981, is designed to prevent the operation of driving machine by the normal operating device unless the hoistway door is locked in the closed position and to prevent the opening of the door unless the dumbwaiter door is within the landing floor and is either stopped or being stopped.

Recommendation – That the above described electro-mechanical dumbwaiter door interlocking device be accepted, when installed and adjusted as per manufacturer's instruction, subject to the approval of elevator inspection department at the installation site. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance May 12 2005

Examined By S. Derk Hudson