

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48730CO	08A0254CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	45th Street Hotel 66 West 45th Street New York NY	Approved	\$0.00
Carry over from May 14, 2008 meeting. Fire pump emergency disconnect sprinkler not remote from generator distribution. Job finalized 9/17/08.						
48789CO	08A0343CO	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Pepsi Cola Bottling Co. of N.Y. 650 Brush Avenue Bronx NY	Approved	\$0.00
Carry over from June 18, 2008 meeting.						
48802CO	08A0296CO	I.K.E. Electrical Corporation 601 West 26th Street 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	216-218 18th Street New York NY	Ok, but	\$0.00
Carry over from June 18, 2008 meeting. Verify 400 amp bus duct fusing for 3200 amp bus duct.						
48827CO	08A0305CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Credit Suisse 1 Madison Avenue New York NY	Approved	\$0.00
Carry over from June 18, 2008 meeting.						
48861CO	08A0365CO	Guth DeConzo Consulting Engineers, P.C. 242 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint Generator Reconnect 111 8th Avenue New York NY	Hold	\$0.00
Carry over from July 16, 2008 meeting. 1) Neutrals in generator disconnect switches must connect to building steel as long as the building steel is picked up in the ground ring of the normal service. 2) 3000 amp switches reversed. 3) 1-Line does not match interlocking drawing. 4) Is generator feeding life safety loads?						

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48870CO	08A0374CO	Atkinson Koven Feinberg Engineers 1501 Broadway, Suite 700 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Internap Expansion 111 Eighth Avenue New York NY	Approved	\$0.00
Carry over from July 16, 2008 meeting.						
48899CO	08A0392CO	Conservation Technology, Ltd. 2783 Shermer Road Northbrook IL 60002	Requested approval for use in New York City of your Portable Metal Halide Track Lighting System for Troffer Area (Accessible) Model/Series Numbers: CTL8116R204B4SP.		Denied	\$0.00
1) UL listed for wall mouting only. Ref . E248667 v1, Sec. 3 pg 24ILL.. 2) Manufacturer's instruction shows install in alcove/dropped ceiling does not comply with NEC/NYC code Sec.400.8 "use not permitted".						
48900CO		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to replace one for one all existing electrical equipment for a 1000 KVA service room with new and leave as installed 4-sets of 500 MCM that will feed frame ratings of 3600 amps where the peak electrical demand is 228 KW, 792 amps.	Grace Dodge Vocational H.S. 2474 Crotona Avenue Bronx NY	Approved	\$0.00
Carry over from July 16, 2008 meeting.						
48901	08A0393	T/S Associates Mechanical Consultants 2 West 32nd Street, 5th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	254 Park Avenue South New York NY	Approved	\$650.00
48902	08A0394	Gallant Fox Electrical Corp. 162-20 77th Road, Suite 2C Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	Ritz Carlton 50 Central Park South New York NY	Approved	\$650.00
1) Change switchboard bus to 3000A 3-6x1/4" cu. 2) Can additional door be installed behind existing switchboard? Job finalized 10/1/08.						

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48903	08A0395	Gallant Fox Electrical Corp. 162-20 77th Road, Suite 2C Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1965 Broadway New York NY	Approved	\$650.00
48904	08A0396	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	393 West Broadway New York NY	Hold	\$650.00
1) Pending field evaluation. 2) Provide proper work clearances. 3) Replace link fuses.						
48905	08A0397	Prince Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	180 Ludlow Street New York NY	Approved	\$650.00
48906	08A0398	CHT Electric Corp. 535 5th Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Leo's Bagels 2 Hanover Square New York NY	Approved	\$650.00
48907	08A0399	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	24 Hour Fitness 600 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48908	08A0400	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requested approval for the electric service equipment proposed to be installed	444 Madison Avenue New York NY	Approved	\$650.00
Verify neutral conductors and bond in existing fire pump service switches. Job finalized 10/1/08.						
48909	08A0401	Premier Electric Inc. 19 West 36th Street, 12th Floor New York NY	Requested approval for the electric service equipment proposed to be installed	New Fire Pump 1370 Avenue of the Americas New York NY	Approved	\$650.00
Egress to open out if possible. Job finalized 10/28/08.						
48910	08A0402	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Macy's 1317 Broadway New York NY	Approved	\$650.00
1) Verify that service room is mechanically ventilated. 2) New switch neutral shall not be bonded to enclosure. Job finalized March 20, 2009.						
48911	08A0403	Stat Electric, Inc. 118-21 Queens Blvd.-Suite 311 Queens NY 11375	Requested approval for the electric service equipment proposed to be installed	5110 19th Avenue Brooklyn NY	Approved	\$650.00
48912	08A0404	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	90-09 Northern Boulevard Queens NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48913	08A0405	A & M Electrical Service, Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	26 Broadway New York NY	Hold	\$650.00
1) Verify that service room is mechanically vented. 2) Confirm access to Con-ED detail after installation. 3) Existing 4000A fuse is not suitable. Correct if drafting error. Remove fuse if drawing correctly shows condition.						
48914	08A0406	Richard Neu, Licensed Electrician 4347 Hylan Blvd. Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	90 Williams Street New York NY	Approved	\$650.00
1) Bond neutral in 30 amp FACO.(SSW #4). 2) Show tap detail and conductor feeder size. 3) Short circuit current at new CB panel. Job finalized 8/25/08.						
48915	08A0407	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	AT & T 811 10th Avenue New York NY	Hold	\$650.00
1) supplemental ground in 4000 and service switch to be building steel only. 2) Ground fault indication needed on 480 volt generator. 3) Generator cut sheets not provided. 4) Provide GF protection on 2500 amp feeders. 5) Seq. of operation for portable generator? 6) Manufacturer cuts for paralleling switchgear. 7) Floor plan for generator room.						
48916	08A0408	Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	2323 Eastchester Road Bronx NY	Approved	\$650.00
48917	08A0409	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	200 West 72nd Street New York NY	Approved	\$650.00
1) Provide reduced neutral calculations. 2) Service entrance conductors feeding 800 amp service switch are undersized. Job finalized 9/23/08.						

# ADVISORY BOARD CALENDAR

August 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48918	08A0410	Park Square Electric Corp. 202 28th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	40 Bond Street New York NY	Approved	\$650.00
48919	08A0411	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	53 North 3rd Street Brooklyn NY	Approved	\$650.00
48920	08A0412	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	330 Hudson Street New York NY	Approved	\$650.00
Job finalized 9/9/08.						
48921	08A0413	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	English Kills Phase 1 Aeration 1106 Grand Street Brooklyn NY	Hold	\$650.00
1) Tap rule for generator? 2) Bond and grounding in Con Ed box should be in service switch. 3) GFP on 1600/1200a C.B. 4) Bus on load of service bkr undersized. 5) Service conductors undersized. 6) Show coordination between main and branches. 7) Verify connection between CT component and main breaker. Floor plan shows bus, 1-Line shows cable. 8) Provide 2nd means of egress.						
48922	08A0414	Abilene Electric Inc. 2402 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	210 West 70th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

August 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48923	08A0415	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Metro PCS 421 7th Avenue New York NY	Approved	\$650.00
48924	08A0416	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	345 East 81st Street New York NY	Approved	\$650.00
1) Provide grounding electrode conductor and supplemental ground lugs. 2) Bond service switch #1. 3) Provide service entrance conductor for SS #1. Job finalized 8/25/08.						
48925	08A0417	Bestco General Maintenance Inc. 922 East 233rd Street Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	Staples 90-30 Metropolitan Avenue Forest Hills NY	Hold	\$650.00
Provide short circuit calculations and curves.						
48926	08A0418	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Sotheby's International Realty 38 East 61st Street New York NY	Approved	\$650.00
1) Provide short circuit calculations and curves. 2) Phone equipment to be removed from service room. Job finalized 8/25/08.						
48927	08A0419	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Christopher Columbus H.S. 925 Astor Avenue Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48928	08A0420	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Retail Building 1551 Broadway New York NY	Approved	\$650.00
Provide disconnect and fusing for TVSS. Job finalized 7/1/09.						
48929	08A0421	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	On The Avenue Hotel 2178 Broadway New York NY	Approved	\$650.00
48930	08A0422	B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	130 Cedar Street New York NY	Approved	\$650.00
Generator neutral to be connected to building steel and main service neutral to pick up building steel in grounding ring. Job finalized 8/19/08.						
48931	08A0423	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	200 West 57th Street New York NY	Approved	\$650.00
Fuse types not provided for bus duct switches. Job finalized 9/23/08.						
48932	08A0424	Cedar Electrical Contractors, Inc. 325 East 41st Street, Suite 1006 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	The Trinity School 101 West 91st Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48933	08A0425	Jolt Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	101 West 87th Street New York NY	Approved	\$650.00
48934	08A0426	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	211 East 70th Street New York NY	Approved	\$650.00
48935	08A0427	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Omnicom 195 Broadway New York NY	Ok, but	\$650.00
Equipment grounding conductors are undersized on service entrance and feeder conductors.						
48936	08A0428	RNH Electric Co., inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	725 Evergreen Street Brooklyn NY	Approved	\$650.00
48937	08A0429	K & G Electric Co., Inc. 747 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	333 East 43rd Street New York NY	Approved	\$650.00
Show selectivity for circuit breaker panels. Job finalized 8/25/08.						

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48938	08A0430	Konsker Electric Corp. 32-15 36th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	521 Fifth Avenue New York NY	Approved	\$650.00
48939	08A0431	E S B Electric Corp. 500 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Affinia Hotel 371 7th Avenue New York NY	Approved	\$650.00
48940	08A0432	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	535 West End Avenue New York NY	Approved	\$650.00
48941	08A0433	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Riverside South Bldg J2 240 Riverside Blvd. New York NY	Approved	\$650.00
48942	08A0434	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Roosevelt Island Bridge  Queens NY	Approved	\$650.00
Page 3-4 states that there is no selective coordination. Job finalized 12/12/08.						

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48943		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to leave as installed a second point of service to 1 block and lot that will supply power outdoors for water main irrigation control hot box where all equipment is installed outdoors.	201 Edward Curry Avenue Staten Island NY	Approved	\$0.00
48944		Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requesting permission to run underground service lateral conductors in rigid non metallic conduit.	218 Beach 17th Street Far Rockaway NY	Approved	\$0.00
48945		Martin Dorkin, Licensed Electrical Contractor 547 Coney Island Avenue Brooklyn NY 11218	Requesting permission to run underground concrete encased service entrance conductors in rigid non metal conduits.	31-33 Farrington Street Queens NY	Approved	\$0.00
48946		Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting permission to install service equipment facing each other with a front clearances of 5 and 6 feet on a 1000 KVA service	444 Madison Avenue New York NY	Approved	\$0.00
48947		Laser Lite Electrical, Inc. 40 Gatton Street Staten Island NY 10309	Requesting permission to apply section of the 2008 NEC to a place of assembly where the occupancy is above 75 people where the branch circuits are wired in AC cable that does not contain an insulated grounding conductor.	Henney's Steak House 2187 Richmond Avenue Staten Island NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**August 13, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48948		Rothstein & Hoffman Electric Service, Inc. 257 Centre Street New York NY 10013	Requesting permission to allow conductors tapped off the load side of a 4000 amp service switch to exceed 10 feet without terminating to a single overcurrent protection device, and signage will be provided on the 17' length switchgear to not increase fuse sizes.	Four Point Sheraton Hotel 66 Charlton Street New York NY	Approved	\$0.00
With the stipulation that all spare switches are removed and the signage shall state "no future switches can be installed in this panel."						
48949		A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requesting permission due to lack of space inside of the buildings, to install service equipment outdoors under the steps where the height is less than 6 1/2 feet on 19 2 family buildings.	Heron Lane Bronx NY	Approved	\$0.00
48950		Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting permission to utilize Section 690.64(B)(2) of the 2008 NEC by allowing photovoltaic equipment fused at 80 amps to be connected on load side of a 400 amp disconnect switch which is the second fusing off of a 1600 amp 277/480 volt 1000 KVA service.	Keyspan Energy Delivery 200 Gulf Avenue Staten Island NY	Approved	\$0.00