

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47469CO	06A0489CO	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	New York Stock Exchange 11 Wall Street New York NY	Approved	\$0.00
Carry over from October 25, 2006 meeting.						
47688CO	06A0508CO	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	City University of New York Convent Avenue @ 138th Street New York NY	Hold	\$0.00
Carry over from February 14, 2007 meeting. 1) Provide available short circuit current at Switchboard-C & Switchboard-A. 2) What is being fed by Switchboard A and C?						
48005CO	07A0313CO	Proven Electrical Contracting Inc. 247 Driggs Avenue Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Con Edison Inc. of New York 4 Irving Place New York NY	Hold	\$0.00
Carry over from July 18, 2007 meeting. Hold engineer to appear at September 12, 2007 Advisory Board meeting.						
48013CO	07A0320CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Chapin School 100 East End Avenue New York NY	Approved	\$0.00
Carry over from July 18, 2007 meeting.						
48028CO	07A0360CO	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Goldman Sachs-Site 26 Battery Park City New York NY	Approved	\$0.00
Carry over from July 18, 2007 meeting.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48030CO	07A0312CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Monroe H.S. Bronx 1551 East 176th Street Bronx NY	Approved	\$0.00
Carry over from July 18, 2007 meeting. 1) Provide fuse sizes in 200 amp disconnect switch. 2) Bond secondaries of transformers. 3) Verify if service room is ventilated. 4) 2500 amp switch bus undersized. 5) Show #6 conductors for faco. 6) Indicate what type of ATS are being used. Job finalized April 24, 2009.						
48075	07A0364	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Clear Channel Communications 32 Avenue of the Americas New York NY	Approved	\$650.00
48076	07A0366	Reliable Electrical Contractors Corp. 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	1810 3rd Avenue New York NY	Approved	\$650.00
1) Show tap detail in troughs and conduct or size feeding trough. 2) Conductor size feeding trough for service switches #1 and #4 not on drawing. Job finalized June 23, 2008.						
48077	07A0369	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NBC 41 West 50th Street New York NY	Approved	\$650.00
1) Provide 4-pole ATS. 2) 4000 amp service switch reversed on drawing. 3) Provide code clearances around EDP. 4) Provide details of generator main circuit breaker and load bank circuit breaker show enclosure floor plan with circuit location and clearance dimensions. 5) Remove ATS from service room. Job finalized 12/12/08.						
48078	07A0379	Absolute Electrical Contracting Inc. One Cross Island Plaza, Suite 109 Rosedale NY 11422	Requested approval for the electric service equipment proposed to be installed	516 West 19th Street New York NY	Approved	\$650.00
1) Verify if the 400 amp service switch is a spare. 2) No neutral link provided in 1200 amp service switch. 3) Supplemental ground not provided. Job finalized 8/20/07.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48079	07A0381	Approved Electric Corp. 3578 White Plains Rd, Suite 107 Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	Hostos Community College 500 Grand Concourse Bronx NY	Approved	\$650.00
1) Correct room layout drawing showing the 400 amp switch. 2) Provide lengths of the taps. Job finalized 8/20/07.						
48080	07A0383	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Rikers Island 19-19 Hazen Street Rikers Island NY	Approved	\$650.00
1) Show where the emergency side of the ATS for the fire pump terminates. Must be rated. 2) Neutral in generator to be connected to grounding electrode. Job finalized 8/20/07.						
48081	07A0376	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Northrup Grumman 480 East 176th Street Bronx NY	Approved	\$650.00
48082	07A0411	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	P.S. 207/149 41 West 117th Street New York NY	Approved	\$650.00
48083	07A0374	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Northrup Grumman 3856 Bronx Boulevard Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48084	07A0372	Approved Electrical Contractors, Inc. 6318 New Utrecht Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Silvercrest Nursing Home 144-45 87th Avenue Briarwood NY	Hold	\$650.00
1) Existing ATS for fire alarm to be 3 pole type (switched neutral). 2) Reduce generator circuit breaker trip to 800A or provide 1000A MTS. 3) Provide description of operation of co-gen system 2 scenarios: on Con Ed power on emergency power. 4) Clarify grounding.						
48085	07A0371	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Limited Brands 1740 Broadway New York NY	Approved	\$650.00
1) Provide detail of bus duct tap. 2) Close off rear access to new tap box. 3) Generator neutral to be grounded. Job finalized 5/6/08.						
48086	07A0393	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Bank of America-One Bryant Pk 1111 Avenue of the Americas New York NY	Approved	\$650.00
48087	07A0400	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	103-00 Foster Avenue Brooklyn NY	Approved	\$650.00
Provide neutral links and show bonding and grounding of service switches. Job finalized 9/19/07.						
48088	07A0397	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Queens District 14 Salt Shed 5110 Almeda Avenue Far Rockaway NY	Hold	\$650.00
1) Ground transformer rods to be 8 or 10 feet long or building steel. 2) Verify the of conduit being installed. 3) Provide note on drawing indicating that bus is 12 inches off of floor. 4) Provide ground fault protection 2500 amp service switch. 5) Supplemental ground not provided. 6) Provide site pan drawing showing 15 KV equipment transformer. 7) Show 2nd level after 2500A service circuit breaker. 8) Need 2nd means of egress.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48089	07A0398	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard Perry Avenue Brooklyn NY	Approved	\$650.00
1) Verify the size of conductors feeding the transformer. 2) Verify the type of conduits being installed. 3) Verify that fire pump feeder is fire rated. 4) Provide note on drawing indicating that bus is 12 inches off of the floor. 5) Show plan view with primary substation. Job finalized 8/19/08.						
48090	07A0399	K & R Electric Co., Inc. 4347 Hylan Blvd Staten Island Ny 10309	Requested approval for the electric service equipment proposed to be installed	180 Schermerhorn Street Brooklyn NY	Approved	\$650.00
1) Provided note on drawing indicating that switchboard bus is 12 inches off of the floor. 2) Verify that fire pump feeder is fire rated and what type of conduit is being installed. 3) Taps for life safety loads to be located ahead of service switches. Job finalized 9/19/07.						
48091	07A0386	Fresh Meadow Commun&ElectlContgCorp 65-42 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Fresh Foods 19 West 44th Street New York NY	Approved	\$650.00
48092	07A0387	DiFazio Electric NY, Inc. 42-24 Douglaston Parkway Douglaston NY 11363	Requested approval for the electric service equipment proposed to be installed	NYU Downtown Ambulatory Care Ct 111 Broadway, 2nd Floor New York NY	Approved	\$650.00
Remove neutral bonds in transformer. Job finalized 11/9/07.						
48093	07A0401	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Evander Child HS(X) 800 Gunhill Road Bronx NY	Ok, but	\$650.00
Provide second set of drawings.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48094	07A0403	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Northrop Gumman 80 West 40th Street New York NY	Approved	\$650.00
Clarify number of service switches drawing shows 7. Job finalized 10/24/07.						
48095	07A0405	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Middle School 283K 284 Baltic Street Brooklyn NY	Approved	\$650.00
48096	07A0407	Belway Electric NYC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Alliance Bernstein 1345 Avenue of the Americas New York NY	Hold	\$650.00
1) Switchboard "A" distribution switch lower fuse ratings to 2000 amp. 2) Provide manufacturer's cut sheet of bus duct and tap boxes. 3) Provide bus sizes of paralleling switchgear and ground fault protection required on standby. 4) Correct voltage note on room layout drawing. 5) With 3-P ATS's generator neutrals to be ungrounded. May cause issues with ground fault protection. 6) Clarify utility feeds to fire pumps(top of drawing). 7) Provide bus duct tap details. 8) Indicate clearance dimensions on floor plan.						
48097	07A0415	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	88 Washington Place New York NY	Approved	\$650.00
48098	07A0385	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	Rikers Island 18-01 Hazen Street Rikers Island NY	Hold	\$650.00
1) Fire pump service switch not remote from service. 2) 1 Line does not match room layout (4000A service switch and distribution). 3) Reduce fusing in 4000 amp s.s. or increase feeder. 4) Provide bonding and grounding of 4000 amp service switch. 5) Correct jockey pump information. 6) Provide ground fault indication at EG1 and EG2 for life safety loads. 7) Secondary of 15 KVA transformer not grounded. 8) Generator neutrals must terminate on grounding electrode. 9) Generators 4000 amp must be reduced to 3500 amps. 10) Provide sequence of operation for 3-source transfer system..						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48099	07A0368	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia Univ.-School of Journalism 29-50 Broadway New York NY	Approved	\$650.00
48100	07A0416	GreenbergFarrow 265 Davidson Avenue, Suite 400 Somerset NJ 08873	Requesting concept approval due to nuisance tripping, to remove an undersized redundant overcurrent device on a 5KV primary feeder that is customer owned.	Home Depot 2501 Forrest Avenue Staten Island NY	Approved	\$650.00
With the stipulation that when this job is submitted to the Board for final approval the drawings shall include the primary side of the installation that was not submitted on Calendar # 47251. Documentation shall be provided from Con Edison Stating who owns and maintains the primary side and the redundant fusing can be replaced with a disconnect switch.						
48101	07A0365	Reliable Electrical Contractors Corp. 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	520 West 27th Street New York NY	Approved	\$650.00
1) Provide wire size and number of sets on line and load side of service switches #1, 2 and load side o service switches #3, load side of 400 amp disconnect switch. 2) Provide fuse types in 800 amp service switch #3. 3) Life safety ATS in service room, where is the second source? Job finalized 6/23/08.						
48102	07A0367	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint/Nextel 80 West 40th Street New York NY	Ok, but	\$650.00
1) Line side sizes of 400 amp service switch not on drawing. 2) Show tap detail in trough not shown. 3) Clarify where new lugs where installed.						
48103	07A0370	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Sprint/Nextel 270 Nostrand Avenue Brooklyn NY	Hold	\$650.00
Drawing of existing equipment not complete.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48104	07A0378	Rockmor Electric Enterprises, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Apple Store 401 West 14th Street New York NY	Approved	\$650.00
<p>1) Service entrance conductors to 4000 amp service switch undersized. 2) Conductors on load side of 4000 amp service switch undersized. 3) Bus sizes of old equipment not on drawing. 4) Provide manufacturer's cut sheets of equipment. 5) Advisory Board rules require new work to be bubbled.</p>						
48105	07A0380	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Extell Development 305/311 East 46th Street New York NY	Hold	\$650.00
<p>1) Service entrance conductors to 4000 amp service switch undersized. 2) Conductors on load side of 4000 amp service switch undersized. 3) Bus sizes of old equipment not on drawing. 4) Provide manufacturer's cut sheets of equipment. 5) Advisory Board rules require new work to be bubbled.</p>						
48106	07A0382	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Three Legged Dog 56 Greenwich Street New York NY	Approved	\$650.00
<p>Tap for fire pump service switch can't be made in the same cubicle as the 1200 amp service switch. Job finalized 8/20/07.</p>						
48107	07A0384	Egg Electric Inc. 24 West 25th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Milstein Family Heart Ctr- 165 Fort Washington Avenue New York NY	Ok, but	\$650.00
<p>1) Fire pump feeder tapped inside of 4000amp service switch. 2) Fire pump fuse size not provided. 3) Provide note on drawing indicating that bus is 12 inches off of the floor. 4) Correct 5 KV to 15 KV.</p>						
48108	07A0412	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	2040 White Plains Road Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48109	07A0409	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Beacon Park 29 West 138th Street New York NY	Approved	\$650.00
48110	07A0408	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	201 Pearl Street New York NY	Approved	\$650.00
48111	07A0410	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	345 Hudson Street New York NY	Approved	\$650.00
48112	07A0377	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Northrup Grumman 131 Walnut Street Bronx NY	Approved	\$650.00
48113	07A0375	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Nextel 3030 Emmons Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48114	07A0373	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Plaza Hotel Retail Fifth Avenue @ 59th Street New York NY	Approved	\$650.00
48115	07A0390	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Albert Einstein College of Med. 1510 Water Place Bronx NY	Approved	\$650.00
Provide note on drawing indicating that bus is 12 inches of f of the floor., Job finalized 9/19/07.						
48116	07A0392	BLH Electrical Contractors, Inc. 3361C East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	245 East 54th Street New York NY	Hold	\$650.00
1) Show 3rd fusing of the 800 amp switch. 2) Tap of a tap not allowed on load side of 600 amp to troughs and load side of 400 amp service switch to CTs.						
48117	07A0394	Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Greater Allen Cathedral 110-42 Merrick Boulevard Queens NY	Hold	\$650.00
1) Provide note on drawing indicating that the switchboard bus is 12 inches off of the floor. 2) One set of 500 MCM fused at 1200 amps. 3) Verify that the fire pump branch circuit is fire rated. 4) Indicate who is installing the service entrance conductors. 5) Show load side of 800 amp CT connections.						
48118	07A0395	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Flushing Meadow Park Queens NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48119	07A0396	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	52 East 4th Street New York NY	Approved	\$650.00
Change 600 amp fuses in SB3 to 500 amps. Job finalized 9/19/07.						
48120	07A0388	Jordan Danlels Electrical Contrs, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Brookfield Property One Liberty Plaza New York NY	Approved	\$650.00
48121	07A0389	Jusler Electrical Corp. 2616 Skillman Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Columbia Univ. Imaging Ctr. 12 West 168th Street, Cellar and 1st F New York NY	Approved	\$650.00
48122	07A0402	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	265 West 37th Street New York NY	Approved	\$650.00
Relocate or verify clearance in front of existing sub meters and 200 amp disconnect switches next to new 1200 disconnect switch. Job finalized 3/20/09.						
48123	07A0404	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	L.A. Fitness 145 E. Service Road Staten Island NY	Approved	\$650.00
1) Verify voltage of job. 2) What is feeding new equipment Con-Ed or existing equipment? Job finalized 8/28/07.						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48124	07A0406	ATJ Electrical Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	El Museo del Barrio 1230 Fifth Avenue New York NY	Hold	\$650.00
Provide selectivity.						
48125	07A0414	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested concept approval for	IKEA 1 Beard Street Brooklyn NY	Approved	\$650.00
48126	07A0413	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Gateway Ctr at Bx Terminal Mkt 671 River Avenue Bronx NY	Approved	\$650.00
48127	07A0391	Petrocell Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The New Yankee Stadium 1 Yankee Stadium Bronx NY	Hold	\$650.00
1) Remove main circuit breaker from emergency switchboard. 2) Provide short circuit and coordination study. 3 Generator room to comply with 110.34 and drawing to show all clearances ad doors next to switchgear.						
48128	07A0417	Mass Electric Construction Company 150-50 14th Road Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Coney Island Water Treatment Brooklyn NY	Approved	\$650.00
1)						

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48129	07A0418	Jack Sotnikow Consultants Inc. 241 West 30th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1 East 1st Street New York NY	Approved	\$650.00
48130	\	Cannon Design 360 Madison Avenue New York NY 10017	Requesting permission to install concrete encased underground service laterals in Schedule 40 non metallic conduits	PS-IS #798 Public School 696 Jamaica Avenue Brooklyn NY	Approved	\$0.00
48131	\	A & R Electl Maint. Inc. 69-61 Juniper Blvd South Middle Village NY 11379	Requested permission to install underground service entrance conductors in Schedule 80 non metallic conduit for 132 two family buildings located in a corrosive area Far Rockaway, Queens	Blvd., Bch 73rd St., Schooner St., C Queens NY	Approved	\$0.00
48132	\ \	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install underground service entrance conductors in concrete encased fiberglass reinforced epoxy non metallic conduits	1269 Lexington Avenue New York NY	Approved	\$0.00
48133	\ \ \	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requesting permission to install as per Con-Edison requirements 15 KV underground primary and 265/480 volt secondary feeders in non metallic fiberglass reinforced epoxy conduits that will run into and out of a 4 compartment blockhouse and provide power to 3 buildings.	Gateway Ctr at Bx Terminal Mkt 671 River Avenue Bronx NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48134	\ \ \ \ \	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requesting permission to install as per Con-Edison requirements 27 KV underground primary and 265/480 volt secondary feeders in non metallic fiberglass reinforced epoxy conduits that will run into and out of a 4 compartment blockhouse and provide power to 3 buildings.	IKEA 1 Beard Street Brooklyn NY	Approved	\$0.00
48135	\ \ \ \ \	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requesting permission due to the contractor finding a underground steel beam to bury rebar reinforced concrete encased rigid galvanized conduits 23 inches below the road surface instead of 24 inches.	Bureau of Wastewater Treatment 63 Flushing Avenue Brooklyn NY	Approved	\$0.00
48136	\ \ \ \ \ \ \ \ \ \ \	Fishman Electric & Son Corp. 107-26 Springfield Boulevard Queens Village NY 11429	Requesting permission to leave as installed 6 medical offices that are wired with AC cable that does not contain an insulated grounding conductor in a building that was renovated to add 14 offices without knowing who the tenants will be.	24-26 Eastchester Road Bronx NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48137	///////	Cosentini Associates Two Pennsylvania Plaza New York NY 10121	Requesting permission on Cal. #48028 to waive selective coordination between two 1200 amp KRPC fuse due to the following: 1) The air cooled chiller is strictly for back-up and shall only run when the main chiller plant on 13th floor is not available. 2) The available short circuit current at panel DP-44-B is approximately 34kA. 3) Panel DP-44-B serves the air cooled chiller via an ATS. This ATS is optional and not a code required transfer switch. If for any reason, the feeders serving the air cooled chiller are shorted and the 1200A fuses at SS-B1 blow. The EPS plant would start up upon loss of power and provide emergency power to DP-44-B via the ATS.	Goldman Sachs Battery Park City-Site 26 New York NY	Approved	\$0.00
48138	///////	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requesting permission to waive full selectivity from the 1200 amp Siemens RLF circuit breaker to a 800 amp THKM circuit breaker due to the fault current at the 800 amp circuit breaker being 19-67 KA and a fault current of 18 KA is required	New York Stock Exchange 11 Wall Street New York NY	Approved	\$0.00
48139	///////	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission due to limited space inside of the electrical room where circuit breaker panels had to be installed and hardship to replace to waive full selectivity between 1600 amp KLLU fuses and 800 amp CMD6 circuit breakers in distribution panels DP-1 and DP-2.	Chapin School 100 East End Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

August 15, 2007

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48140	07A0419	Nocom Inc. 105 Willolea Road Carp On Canada KOA 0	Requested approval for use in New York City of your Backbox Assembly. Model/Series Numbers: SMI-Backbox Cat. No. WSCS-1 IKEA, SMI-Duplex Plate Cat. No. ST302, SMI-Trim Plate Cat. No. TRIM-1-N-White, Duplex Recept. Cat. No. CR20W.		Denied	\$200.00
1) CSA report is required (not UL). 2) Product construction must be consistent with CSA report. 3) Mounting holes are not code compliant. 4) There is no volume marking provided. 5) KO has "double D" circumference and does not permit the connector to seat properly. 6) Connector must be supplied or specified installation instructions.						
48141	07A0420	Panduit Corporation 16530 163rd Street Lockport IL 60441	Requested approval for use in New York City of your Metal Raceway System. Model/Series Numbers: PMR5 and PMR7.		Approved	\$200.00