

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0000CO	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	45 Main Street Brooklyn NY	On Hold	\$0.00
1) Confirm access to pullbox behind disconnect switch #1. 2) Panel A,C,D & G calc not required but pane "B" is undersized.						
51349	12A0108CO	Hugh O Kane Electric Company, Inc. 90 White Street New York NY	Requested approval for the electric service equipment proposed to be installed	375 Pearl Street New York NY	Approved	\$0.00
51350	12A0148	LFG Landmark Facilities Group, Inc. 611 Broadway, Suite 721 New York NY 10012	Requested approval for the electric service equipment proposed to be installed	70 West 40th Street New York NY	Approved	\$650.00
51351	12A0149	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Brookfield Landfill Arthur Kill Avenue Staten Island NY	Approved	\$650.00
51352	12A0150	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Yeshiva University 2495 Amsterdam Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51420	12A0151	Atore Campisi & Sons Lic. Electl Contrs, 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Queens Blvd. Ext Care Fac, 61-11 Queens Blvd. Woodside NY	Approved	\$650.00
Fire pump to be connected to line side of generator disconnect switch. Job finalized 10/22/12.						
51353	12A0152	Asko Electl Constn & Maint., Inc. 21-24 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	15 West 44th Street New York NY	Approved	\$650.00
	12A0153	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Randall's Island Tennis Ctr. One Randall's Island Road New York NY	Denied	\$650.00
1) Transformer disconnect switch to be ground fault protected, bonded, grounded, and fused. 2) Fused disconnect switch required to connect portable generator too 3) Supplemental ground not shown. 4) F.P. & F.A. feed to be taken ahead of service switch. 5) Transformer top lengths not shown. 6) Service room not ventilated. 7) Fire pump and fire alarm system to have separate ATS switches.						
51375	12A0154	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	50 North 5th Street Brooklyn NY	Approved	\$650.00
Equipment grounding conductors undersized. Job finalized 8/30/12.						
	12A0155	Contact Electric Corp. 1064 60th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1362 50th Street Brooklyn NY	On Hold	\$650.00
Provide details of what is new and what is existing.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51354	12A0156	JSP Electrical Contracting Corp. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	AMC Loews Kips Bay Theatre 570 Second Avenue New York NY	Approved	\$650.00
51355	12A0157	Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 214-X 1970 West Farms Road Bronx NY	Approved	\$650.00
51410	12A0158	Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	600 Lexington Avenue New York NY	Approved	\$650.00
1) Supplemental electrode not shown on drawing for new 1600A service switch Article .250.52 (D) 16. 2) GFP not provided for new 1600A 480/277V service switch Article 230.95. Job finalized 9/24/12.						
51356	12A0159	Stanco Systems Electrical Contracting Inc. 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	220 East 42nd Street New York NY	Approved	\$650.00
51407	12A0160	H & L Electric, Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	NY Hilton Hotel 1335 Avenue of the Americas New York NY	Approved	\$650.00
1) Supplement ground not shown on drawing for service 'C' Article 250.53. 2) All switchboards to have tamper resistant bolts on rear cover with signage "Do not remove cover". 3) Switchboards receiving power from co-gen to have signage indicating that bus can be live if the main switch is in the off position. Job finalized 9/25/12.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51405	12A0161	Website Electric Corp. 155 New Dorp Plaza Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	On the Avenue Hotel 78 Broadway, aka 228 West 77th Str New York NY	Approved	\$650.00
1) Supplemental electrode not shown on drawing Article 250.53(D). 2) 400 amp rated CT fused at 600 amp. Job finalized 9/25/12.						
	12A0162	A & M Electrical Service Inc. 76 Bathgate Street Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	210 Joralemon Street Brooklyn NY	Pending	\$650.00
1) Switchboards to have rear doors. 2) Verify size of F.P.. fuse.						
51406	12A0163	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	405 Park Avenue New York NY	Approved	\$650.00
Tap conductor to 400 amp disc switch undersized. Job finalized 9/25/12.						
51376	12A0164	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Red Bull Music Academy 218 West 18th Street New York NY	Approved	\$650.00
Provide size of vertical bus. Job finalized 8/30/12.						
51461	12A0165	M.C. Electrical NY Inc. 843 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Cosmopolitan Club 122 East 66th Street New York NY	Approved	\$650.00
1) #10 service entrance conductors fused @ 100 amps. 2) Provide short circuit calculation at panel DP1. Job finalized 11/20/12. 5/6/14 Swapped all drawings. Contractor name change and addition of panel/and feeder. 1/12/15 Swapped AB-50-01, Revision 5 and FP-50-01, Revision 4.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0166	Al-Letric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	One Fulton Square 39-16 Prince Street Flushing NY	On Hold	\$650.00
1) 2000 amp service switch overfused. 2) Conductors tapped from bus duct undersized. 3) Bus to 2000 amp service switch undersized. 4) Fire pump feeder undersized. 5) 5 foot clearance required in front of service switches.						
	12A0167	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	101 West 87th Street New York NY	On Hold	\$650.00
1) 1200 amp switch to have neutral link. 2) Doors to swing out w/panic hardware. 3) Fire pump service tap shares enclosure with main service switch. 4) Relocate one door remotely from each others.						
51462	12A0168	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Soho Hotel 523 Greenwich Street New York NY	Approved	\$650.00
1) Fire pump service entrance and feeder undersized. 2) Neutrals in service switches to be bonded. 3)Block right side of service. 4) Incorrect calc for panel "Bar". Job finalized 11/21/12.						
51463	12A0169	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	508 West 24th Street New York NY	Approved	\$650.00
1) Bus in panel HPD undersized. 2) Neutral not bonded in 60 and 400 amp service switch. 3) Verify TVSS has fuses. Job finalized 11/21/12. 11/28/14 Swapped Revision 2.						
	12A0170	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Sims, South Bklyn Marine Terminal 472-490 2nd Avenue Brooklyn NY	On Hold	\$650.00
1) Verify if generator loads are for required life safety. 2) Emergency system and normal system not separated by 2 hour fire rated wall.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51401	12A0171	Deltex Electrical Contracting, Inc. 1027 McDonald Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	151 West 30th Street New York NY	Approved	\$650.00
1) Rear of switchboard to be blocked off. 2) Verify back of board does not need access. Job finalized 9/27/12.						
51357	12A0172	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	149-09 183rd Street Jamaica NY	Approved	\$650.00
51373	12A0173	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	34 Leonard Street New York NY	Approved	\$650.00
Existing feeder overfused unless it is a tap. If so, how long is the tap? Job finalized 8/27/12,						
	12A0174	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	680 Madison Avenue New York NY	Rejected	\$650.00
Rearrange EM EQ to line up with door(access of equipment). 12/18/14 Job finalized. 12/1/15 Rejected. 1) Only one set of drawings was submitted. 2) Cover sheet with explanation of changes.						
51542	12A0175	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	160 West 62nd Street New York NY	Approved	\$650.00
Feeders from transformer to disconnect switch ovefused. Job finalized 1/15/13.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51408	12A0176	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Queens West Parcel 3 46-10 Center Boulevard Long Island City NY	Approved	\$650.00
1) Neutrals in 30 amp service switches not bonded to enclosures. 2) How do 10 sets of 350 MCM terminate in 1200 amp switch. Job finalized 9/25/12. 7/15/14 Swapped 1,2, and 3, Revision 4. 9/24/14 Swapped 1,2, and 3, Revision 5's. 5/4/15 Swapped 1,2 and 3, Revision 6s.						
51411	12A0177	Reliant Electrical Contracting Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	St. Louis Hall 319 West 94th Street New York NY	Approved	\$650.00
1) Service switch #1 overfused. 2) Neutrals not bonded to enclosure in 30 amp service switch. Job finalized 9/24/12.						
51358	12A0178	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	135 West 30th Street New York NY	Approved	\$650.00
51359	12A0179	USA Electrical Services 77-08 21st Avenue East Elmhurst NY 11370	Requested approval for the electric service equipment proposed to be installed	36-08 33rd Street Astoria NY	Approved	\$650.00
3/25/14 Swapped Revision 1.						
51417	12A0180	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	583 Broadway New York NY	Approved	\$650.00
Tap conductors are undersized. Job finalized 10/5/12.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51360	12A0181	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	145-146 Central Park West New York NY	Approved	\$650.00
M.I. Transition conductors overfused. Job finalized 8/29/12.						
51374	12A0182	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	270 Park Avenue New York NY	Approved	\$650.00
	12A0183	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	245 Park Avenue New York NY	On Hold	\$650.00
<p>1) Verify that switchboard BBBB has rear doors. 2) Vertical bus size in paralleling switch gear 3rd and 4th section not shown. 3) Fusing on normal side on drawing AB40-06 of 6 not shown on drawings-01. & 02. 4) Physical of load bank board not provided or bus sizes. 5) ATS' SDP-6B and SPP-6D overfused on emergency side, and line side fuses not shown. 6) Vertical bus in UPS-UIS-A, VIS-B, DS-FF switchboard. 7) Verify that bus duct connections in the switchboard are accessible after installation. 8) Gen 3 output breaker to be ground fault protected. 9) Coordination study not provided. 10) Verify if rear doors can be opened ninety degrees on paralleling gear.</p>						
	12A0184	Richard Neu, Licensed Electrician 400 Saint Marks Place Staten Island NY 10301	Requesting permission to leave as installed #1 copper conductors supported at 120 feet where it will be a hardship to correct.	258 Riverside Drive New York NY	Denied	\$350.00
51361	12A0185	Purcell Electrical Contractors, LTD 138-30 241st Street Rosedale NY 11422	Requesting permission to install outdoor overhead service entrance conductors in PVC raceways for six buildings that are located in a corrosive area Far Rockaway, Queens	21, 6217, 6215, 6211 and 6207 Almc Far Rockaway NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	12A0186	Consentini Associates Consulting Engs Two Pennsylvania Plaza New York NY 10121	Requesting permission to replace old existing automatic transfer switches for the emergency system with new where the switches and feeders are located in the service room	1515 Broadway New York NY	Denied	\$0.00
1) The ATS switches to be field evaluated by a NRTL after retro fitting. 2) The existing ATS switches to be enclosed in a 2 hour fire rated room.						
51362	12A0187	Quest Electric Corp. 2362 Westchester Avenue Bronx NY 10462	Requesting permission to retro-fit existing fuse back boxes with UL recognized Eaton circuit breaker interiors for 871 back boxes that are embedded in plaster walls with existing conduits entering the top and bottom of the back boxes	Tracey Towers 20-40 Moshulu Parkway Bronx NY	Approved	\$0.00
	12A0188	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY 10038	Requesting permission to utilize Section 705.12(D)(2) of the proposed 2014 NEC for a solar photo voltaic installation	Kohl's 2239 Forest Avenue Staten Island NY	Denied	\$0.00
1) Single line drawing not provided. 2) Permission to utilize the 2014 National Electrical Code is denied. 3) Your special permission request is not clear on what you intend to install.						
51363	12A0189	Twig Consulting Engineers, PC 7 Penn Plaza, Suite 702 New York NY 10001	Requesting permission to leave one means of egress to the service room where there is one unobstructed egress	122 East 75th Street New York NY	Approved	\$0.00
51238CO	12A0190	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Rockefeller University 1230 York Avenue New York NY	Approved	\$0.00
Carry over from May 2, 2012 meeting.						

ADVISORY BOARD CALENDAR

August 15, 2012

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51174CO	12A0191	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	42-37 Main Street Queens NY	Approved	\$0.00
Carry over from April 18, 2012 meeting. 1) Equipment grounding conductors undersized. 2) Explain service entrance conductors to fire pump, 2-sets of 4-4/0? Job finalized 11/29/12.						