

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46793CO2	05A0530CO2	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Memorial Sloan Kettering  New York NY	Approved	\$0.00
Carry over from June 14, 2006 meeting. This approval is for the additional paralleling gear added to existing switchboard. Addition to drawing 44923.						
46951CO	06A0064CO	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Eger Healthcare 140 Meisner Avenue Staten Island NY	Hold	\$0.00
Carry over from February 15, 2006 meeting. 1) Replace fuses with Class R type. 2) Bonding and grounding not shown. 3) Show selectivity between 400A fuses and circuit breaker. 4) Provide 2 sets of drawings.						
47074CO	06A0212CO	Crossland Electrical Systems, Inc. 846 East 52nd Street Brooklyn NY 11203	Requested approval for the electric service equipment proposed to be installed	599 Kingston Avenue Brooklyn NY	Approved	\$0.00
Carry over from April 12, 2006 meeting. Comply with tap rules. Job finalized 10/23/06						
47172CO2	06A0279CO2	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY 11217	Requested approval for the electric service equipment proposed to be installed	415 East 37th Street New York NY	Approval	\$0.00
Carry over from July 12, 2006 meeting.						
47215CO2	06A0229CO2	Elliot Energy Systems, Inc. 2901 S.E. Monroe Street Stuart FL 34997	Requested approval for use in New York City of your TA 100 Microturbines, Model/Series Numbers: TA100-CHP, - Monogen.		Denied	\$0.00
Carry over from June 14, 2006 meeting. The equipment must be listed by a nationally recognized testing laboratory.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47238CO	06A0291CO	Shally Electrical Contractor, Inc. 15 Ingraham Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	2801 Emmons Avenue Brooklyn NY	Approved	\$0.00
Carry over from June 14, 2006 meeting.						
47278CO	06A0336CO	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Whole Foods 229 Chrystie Street New York NY	Approved	\$0.00
Carry over from July 12, 2006 meeting. Show neutral disconnect link. Job finalized 10/16/06.						
47284CO	06A0364CO	Welsbach Electric Corp. 111-01 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	NYC DEP--Manhattan Pump Station 13th Street and Avenue D New York NY	Approved	\$0.00
Carry over from July 12, 2006 meeting.						
47286CO	06A0339CO	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Arverne by the Sea Bldg. #1A Beach 81st Street Arverne NY	Denied	\$0.00
1) The neutrals in the service switches are not bonded to the enclosures. 2) No grounding conductor or grounding electrode conductor provided. 3) Short circuit calculations were not provided, 800 amp fuses to circuit breakers. 4) The conductors contained in the conduits are not properly identified. 5) The fire pump information was not provided and not complete, full load amperage and type of raceway not provided, feed to fire pump to be fire rated.						
47302CO	06A0340CO	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Bradhurst Parc 102 Bradhurst Avenue New York NY	Approved	\$0.00
Carry over from July 12, 2006 meeting.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47307CO	.	Black and Kurtz Consulting Engineers, LLI 475 Fifth Avenue New York NY 10017	Requesting concept approval to install the switchgear for the co-generation and the emergency systems within the same fire rated room.	North Shore L.I. Jewish Hospital 265-25 76th Avenue New Hyde Park NY	Approved	\$0.00
Carry over from July 12, 2006 meeting. Note: With the recommendation that the switchgears are installed in a manner that will provide the most clearance between them.						
47308CO	...	Department of Environmental Protection 59-17 Junction Boulevard Flushing NY 11373	Requesting permission on existing Department of Environmental Protection pump sites that will be upgraded to meet all electrical code requirements, to install components rated for Class I, Group D, Division 2 in an ordinary electrical box with non-rated components.	NY Dept of Environmental Protection  New York NY	Approval	\$0.00
Carry over July 12, 2006 meeting.						
47317CO	06A0365CO	Lo Sardo General Contractors Inc. 35 Crescent Street Brooklyn NY 11208	Requested approval in New York City of your Electrical Materials and Equipment for Transportable Classroom Unity (TCU).		Approved	\$0.00
Carry over from July 12, 2006 meeting.						
47328	06A0382	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	237 Park Avenue New York NY	Approved	\$650.00
47329	06A0400	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Briar Hill Apartments 600 West 246th Street Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47330	06A0402	Call Electric Co. 35-21 Ninth Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	1 Dag Hammarskjold Plaza 885 Second Avenue New York NY	Approved	\$650.00
47331	06A0404	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	325 5th Avenue New York NY	Approved	\$650.00
47332	06A0406	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	425 Fifth Avenue New York NY	Approved	\$650.00
47333	06A0409	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	301 East 55th Street New York NY	Approved	\$650.00
47334	06A0410	Tri-Power Engineering, LLC 488 Schooley's Mountain Hackettstown NJ 07480	Requested approval for the electric service equipment proposed to be installed	1 West 81 Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

August 16, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47335	06A0412	MSM Electric, Inc. 417 Brighton Beach Avenue, 2nd Floor Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	133 East 58th Street New York NY	Approved	\$650.00
Indicate fire pump switch painted red and labeled "Do Not Disconnect". Job finalized 10/12/07.						
47336	06A0414	Innovative Electric of New York, Inc. 2056 Cross Bronx Expressway Bronx NY 10472	Requested approval for the electric service equipment proposed to be installed	890 Prospect Avenue Bronx NY	Approved	\$650.00
47337	06A0416	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the Americas New York NY	Approved	\$650.00
47338	06A0419	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Public Health Labs 455 First Avenue New York NY	Hold	\$650.00
1) Only 1 drawing of service room layout submitted. 2) Only 1 drawing of generator room layout submitted. 3) Code required clearance between new 4000 switchboard and existing Section 5. 4) Mac Power's physical of equipment not submitted. 5) Verify if 3 or 4 pole ATS are used. 6) Verify bonding and grounding of generator. 7) FDR to new generator distribution switchboard undersized. 8) Ground fault trip not permitted for emergency main circuit breaker. 9) Provide coordination study with CB trip settings and curves.						
47339	06A0421	Team Electric, Inc. 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bradley Residence 285 Central Park West, Apt. 9S New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47340	06A0423	Levinson & Santoro Electric Corp. 20-16 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	PS 70X 1691 Weeks Avenue Bronx NY	Approved	\$650.00
1) Verify if Con Ed is feeding end box. 2) Bond neutral in F.A.C.O. box. 3) Door to service room to open out. 4) Provide 2nd means of egress. Job finalized 9/21/06.						
47341	06A0424	Forest Electric Corp. 111 8th Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
47342	06A0388	Zev Electric Corporation 54 Pearl Street Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	53 Bridge Street Brooklyn NY	Approved	\$650.00
Jockey pump tap cannot be made in controller enclosure. Job finalized 10/26/06.						
47343	06A0390	Axcel Electric Company 636 11th Avenue, 10th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	85 4th Avenue New York NY	Approved	\$650.00
47344	06A0393	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Verizon-Cell Site 550 Brush Avenue Bronx NY	Approved	\$650.00
Indicate both sets are tapped in wire trough. Job finalized 8/28/06.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47345	06A0395	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	111 Central Park North New York NY	Approved	\$650.00
1) Fire pump fuse oversized. 2) Cannot tap jockey pump feed inside controller enclosure. Job finalized 8/28/06.						
47346	06A0397	B & G Electrical Contractors 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	139 Wooster Street New York NY	Approved	\$650.00
47347	06A0398	United Electrical Contracting Corp. 69 Ludlow Street, Ground Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	88 Crosby Street New York NY	Approved	\$650.00
47348	06A0372	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Modells II Bronx 1500 Bassett Avenue Bronx NY	Denied	\$650.00
Locate fire pump switch closest to CT compt. This a duplicate filed in error by the contractor. Void Cal. #47348 as per Cal. #46580. Advisory Board rule changed in 2006 to not allow this installation which was allowed in 2005.						
47349	06A0371	New Grand Electric, Inc. 71-73 Allen Street #302 New York NY 10002	Requested approval for the electric service equipment proposed to be installed	197 Bridge Street Brooklyn NY	Ok, but	\$650.00
1) Jockey pump tap cannot be in controller enclosure. 2) 2 doors should be at opposite ends of room.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47350	06A0380	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Park Slope Armory 1402 8th Avenue Brooklyn NY	Approved	\$650.00
47351	06A0379	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	JHS 45 2351 1st Avenue New York, NY	Approved	\$650.00
47352	06A0383	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Time and Life Building 1271 Sixth Avenue New York NY	Approved	\$650.00
47353	06A0385	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1470 Amsterdam Avenue New York NY	Approved	\$650.00
47354	06A0407	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	The Plaza Hotel Fifth Avenue at Central Park South New York NY	Hold	\$650.00
1) Indicate bus sizing on existing service. 2) Transformer secondary conductors not sized properly. 3) Show FLA for fire pump. 4) Transformer service switch on service #3: feeder undersized. 5) Floor plan not consistent with one-line. 6) Show locations of transformers. 7) Indicate routing of busway in service room.						

# ADVISORY BOARD CALENDAR

August 16, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47355	06A0418	INS Electrical Services Inc. 86 Bower Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Bed Bath & Beyond 2700 Veteran Road West Staten Island NY	Hold	\$650.00
47356	06A0399	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	NYU Dept. of Journalism 20 Cooper Square New York NY	Approved	\$650.00
47357	06A0401	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Ft. Schuyler House-Nextel Site 3077 Cross Bronx Expressway Bronx NY	Approved	\$650.00
47358	06A0403	Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	JHS #157 63-55 102nd Street Rego Park NY	Approved	\$650.00
Service room door with panic hardware to open out. Job finalized 8/28/06.						
47359	06A0405	Colony Electric Company, Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	316 Third Avenue New York NY	Approved	\$650.00
1) The 10 4 inch conduits must be galvanized and protected from mechanical injury. 2) Verify access to cable pull Section MDP-2. 3) Verify ventilation in service room. Job finalized 8/28/06.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47360	06A0408	KC Electrical Contracting Inc. 240-19 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	160 Riverside Boulevard New York NY	Approved	\$650.00
47361	06A0411	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	One Hanson Place Brooklyn NY	Approved	\$650.00
47362	06A0413	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	237 West 35th Street New York NY	Approved	\$650.00
47363	06A0415	MF Electrical Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	550 Brush Avenue Bronx NY	Approved	\$650.00
47364	06A0417	Double K Electric Corp. 247-03 Jamaica Avenue Bellerose NY 11426	Requested approval for the electric service equipment proposed to be installed	Queens Blvd. 99-01 Queens Blvd. Rego Park NY	Approved	\$650.00
1) Remove neutral bonds on disconnect switches. 2) 600 amp Rite Aid switch is reversed. 3) Tap of a tap not permitted on load side of 600 amp service switch 4) 500 MCM conductors fused at 600 amps. 9/8/06 Job finalized.						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47365	06A0420	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	421-33 East 13th Street New York NY	Approved	\$650.00
1) Service room doors have to comply with 110.26 (C) (2). 2) Verify length of reduced bus duct. 3) Fuse type are not provided. Job finalized 8/20/07.						
47366	06A0422	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	IS 59Q 132-55 Ridgedale Street pringfield Garden NY	Hold	\$650.00
1) Load side bus off of 2500 and service switch undersized. 2) Show short circuit calculations between 400 amp service switch and panel DP-EM circuit breakers. 3) Verify that Con-ED is feeding end box.						
47367	06A0387	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	156 5th Avenue New York NY	Approved	\$650.00
47368	06A0389	Axcel Electric Company 636 11th Avenue, 10th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Chelsea Pier 60 West 20th Street New York NY	Approved	\$650.00
1) Verify that the load is not supplying a fire alarm system. 2) Provide ground on load side of transformer. Job finalized 4/24/07.						
47369	06A0391	Axcel Electric Company 636 11th Avenue, 10th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	125 Park Avenue New York NY	Approved	\$650.00
1) Provide short circuit calculations for fuses to circuit breakers. 2) Relocate meter to provide access to behind board. Job finalized 4/25/07						

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47370	06A0392	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Mt. St. Michael's HS 4300 Murdock Avenue Bronx NY	Approved	\$650.00
1) Increase feeder to 200 amp switch. 2) Verify if ATS has a solid neutral. Job finalized 8/28/06.						
47371	06A0394	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	The Sapir Organization 261 Madison Avenue New York NY	Approved	\$650.00
1) Load side feeders off of 1600 SSB are undersized. 2) Verify size of feeders off of SSA switch. 3) Verify location of switches SSA and SSB. 4) Verify location of transformer to secondary switch. Job finalized 8/28/06.						
47372	06A0396	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	175 Water Street New York NY	Approved	\$650.00
Verify which switch is feeding the bus duct. Job finalized 8/28/06.						
47373	06A0384	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	1 River Terrace New York NY	Approved	\$650.00
1) Indicate switch and fuse size of switch feeding " WT Retail" trough. (MS-B) 2) Indicate fire pump FDR is rated (MS-B). 3) Jockey pump tap cannot be made in controller enclosure. (MS-A). Job finalized 9/06.						
47374	06A0374	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	NYU 120 E. 12th Street New York NY	Ok, but	\$650.00
1) Verify if emergency service room door can comply with 110.26 C2. 2) Show selectivity between 600 A2K fuses and 1200 amp circuit breaker. 3) Bus sizes of take off's not shown.						

# ADVISORY BOARD CALENDAR

August 16, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47375	06A0386	J.G. Electrical Installations, Inc. 66-05 60th Place Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	315 Park Avenue South New York NY	Approved	\$650.00
47376	06A0378	Falco Electrical Services Inc. 2220 Voorhies Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	150 East 35th Street New York NY	Ok, but	\$650.00
Provide 2nd door.						
47377	06A0377	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS 195 253-50 149th Avenue Rosedale NY	Approved	\$650.00
Selectivity between 1200 amp over current. Job finalized 9/11/06.						
47378	06A0376	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	51 North 8th Street Brooklyn NY	Approved	\$650.00
Relocate 2nd door remote from 1st. Job finalized 10/25/06.						
47379	06A0381	Pomalee Electric Co. Inc. 450 Seventh Avenue, Suite 1501 New York NY 10123	Requested approval for the electric service equipment proposed to be installed	153 E. 53rd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47380	06A0375	Linear Electric Inc. 630 Ninth Avenue, Suite 1001 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	August Wilson Theatre 245 West 52nd Street New York NY	Approved	\$650.00
60 amp elevator disconnect switch not shown in service room. Job finalized 3/26/07.						
47381	06A0373	Lothstein & Hoffman Electric Services, Inc 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	World Journal 141-07 20th Avenue Whitestone NY	Approved.	\$650.00
47382		KGK Electric Corp. 21-03 21st Avenue Astoria NY 11105	Requesting permission to replace like and kind without filing full Advisory Board drawings, feeders, generators and emergency switchboards on an 1000 KVA service	106-21 Beach Channel Drive Queens NY	Denied	\$350.00
Drawings must be submitted to the Advisory Board for approval.						
47383		Schwimmer Electric Service Corp. 244 5th Avenue, Suite 29154, 2nd Fl. New York NY 10001	Requesting permission to install an overhead standpipe service in non metallic Schedule 80 conduit on a single family house located in a corrosive area Far Rockaway, Queens	341 Beach 40th Street Far Rockaway NY	Approved	\$0.00
47384	"	Marriott Electric Corp. 182-25 150 Avenue Springfield Gardens NY 11413	Requesting permission to install overhead standpipe services in non metallic Schedule 80 conduit on 11 three family buildings located in a corrosive area, Far Rockaway, Queens.	0, 2914, 2918 Farber Terrace and 11 Far Rockaway NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47385	"	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to leave as installed service equipment mounted on the outside of a combination commercial/residential building.	38-24 55th Street Woodside NY	Approved	\$0.00
47386	""	DiRusso Electrical Contracting Inc. 63-23 Metropolitan Avenue Middle Village NY 11379	Requesting permission to leave one means of egress to the service room due to the construction of the building. Re: Drawing Cal. # 47071.	234 Skillman Avenue Brooklyn NY	Approved	\$0.00
47387	""""	Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting concept approval to replace an 1000 KVA generator where the front clearance from the generator to the switchboard is less than 5 feet	One Centre Street New York NY	Denied	\$0.00
47388	""""	Robin Electrical Co., Inc. 437 East 165th Street Bronx NY 10456	Requesting permission to leave as installed in a place of public assembly A/C cable as a wiring method.	880 River Avenue Bronx NY	Approved	\$350.00
With the stipulation that all of the circuits must be ground fault protected.						
47389	06A0425	Tyco Thermal Controls 11 Exeter Pass Colts Neck NJ 07722	Requested approval for use in New York City of your QuickNet Floor Warming System w/QuickStat thermostat and floor temperature sensor. Model/Series Numbers: QuickNet 010-1 to QuickNet-100-2		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**August 16, 2006**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47390	06A0426	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Vivo Interior Office Furnishing system modular electrical components. FT. 110 Frames. Model/Series Numbers: FT141 Power Entry; FT150 thru 156 Harness and receptacle accessories.		Approved	\$200.00
47391	=	New York City Housing Authority 90 Church Street, 6th Floor New York NY 10007	Requesting permission to replace like and kind three 333 KVA and three 250 KVA transformers that provide power to the housing authority complex.	Adams Houses Development 710 Tinton Avenue Bronx NY	Denied	\$0.00