August 17, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46389CO Carry over fro	05A0228CO om May 25, 2005 m	Fried Electric Co., Inc. 250 West 77th Street, Suite 430 New York NY 10024 eeting. 1) Change conductors to 1/0. 2) I	Requested approval for the electric service equipment proposed to be installed dentify fire pump control painted red.	250 W. 77th Street New York NY	Approved	\$0.00
46471CO	05A0298CO	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Abak Line of Modular Systems Office Furnishings. Model/Series Numbers: Frame: AK110, HHWWX; Power Entry Box AK130.WW; AK131. WW Power Harness Kit; AK132 Access Zone Power Harness.		Approved	\$0.00

Carry over from June 15, 2005 meeting.

46474CO	46474CO 05A0307CO	Falco Electrical Services, Inc. 2220 Voorhies Avenue	Requested approval for the electric service equipment proposed to be installed	260 Madison Avenue	Approved	\$0.00
		Brooklyn NY 11235		New York NY		
Carry over fro	om July 20, 2005 me	eting.				
46481CO	05A0315CO	Edwards & Zuck, PC	Requested approval for the electric service	Tishman	Approved	\$0.00
	315 Park Avenue South	equipment proposed to be installed	30 Rockefeller Plaza	11		
		New York NY 10010		New York NY		
Carry over fro	om July 20, 2005 me	ç	1	1		
46482CO	05A0314CO	JB Electric Corp.	Requested approval for the electric service	Verizon	Hold	\$0.00
		3702 Rombouts Avenue	equipment proposed to be installed	1095 Sixth Avenue		
		Bronx NY 10466		New York NY		
Carry over fro neutral bus.	om July 20, 2005 me	eting. 1) Service conductors not properly	protected per code (trough to another floor). 2) Provide	common neutral /ground for both services	vice per generato	r

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46485CO	05A0311CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Atlas Park 80th Street & Cooper Avenue Glendale NY	Approved	\$0.00
Carry over fro	om July 20, 2005 me	eeting.				
46492CO	05A0346CO	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Fortress Investments 345 Avenue of the Americas "Bldg C New York NY	Approved	\$0.00
Carry over fro	om July 20, 2005 me	eeting.				1
46494CO	05A0348CO	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Bank of America 1633 Broadway New York NY	Approved	\$0.00
Carry over fro	om July 20, 2005 me	eeting.				
46509CO	05A0305CO	OHR Chodosh Electl Contg, Inc. 979 East 35th Street Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	Yeshiva Noviminsk 1690 60th Street Brooklyn NY	Approved	\$0.00
Carry over fro	om July 20, 2005 me	eeting.				1
	05A0300CO	Quest Electric Corp.	Requested approval for the electric service equipment proposed to be installed	Claremont Apartments	Approved	\$0.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46528CO	05A0354CO	Zev Electric Corp. 54 Pearl Street Brooklyn NY 11201	Requested approval for the electric service equipment proposed to be installed	Josh Guttman 68 Jay Street Brooklyn NY	Approved	\$0.00
Carry over fro	om July 20, 2005 me	eeting. Show how line and load is separate	d.		L	1
46545	05A0358	R & L Systems, Inc. 37-20 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	240 East 123rd Streeet New York NY	Approved	\$650.00
46546	05A0359	Qncc Electrical Contracting Corp. 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Kings County Hospital 451 Clarkson Avenue Brooklyn NY	Approved	\$650.0
46547	05A0360	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	UBS 85 Avenue of the Americas, Floor 15 New York NY	Hold	\$650.0
			ngs not consistent with drawing E.8. Provide coordina er. 4) Provide short circuit and coordination study.	ted 1-line diagram. Provide 1-line diagr	am in Adviso	ry
46548	05A0363	K.E.D. Electrical Contracting, Inc. 535 Wild Avenue	Requested approval for the electric service equipment proposed to be installed	40 Gansevoort Street	Approved	\$650.0

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46549	05A0364	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Newtown Creek W.P.C.P. 31F Greenpoint Avenue Brooklyn NY	Hold	\$650.00
1) Clarify if 4	80V switchgear is 3	W or 4W. 2) Comply with Article 408 an	hendment for bus sizing. Connections to 4000A break	ers undersized. 3) Provide SC and coordi	nation study.	I
46550	05A0366	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Hermany Farms 2338 Hermany Avenue Bronx NY	Approved	\$650.00
46551	05A0372	B & G Electrical Contractors 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	The Shops at Atlas Park 80-40 Cooper Avenue Queens NY	Approved	\$650.00
1) Reconcile not 3rd point.	U	and winding configuration on elevation and	single line. 2) Identify Calendar number of 5KV s	w and XFMR. 3) Fire alarm connection	should be serv	ice tap
46552	05A0373	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	New York Athletic Club 180 Central Park West New York NY	Approved	\$650.00

Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
05A0375	Dooley Electric Co., Inc. 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New York Hospital of Queens 56-45 Main Street Flushing NY	Approved	\$650.00
05A0376	Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	Tilden High School 5800 Tilden Avenue Brooklyn NY	Approved	\$650.00
05A0377	Atlantic Electrical Contracting Inc. 206 East 9th Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	1160 Park Avenue New York NY	Approved	\$650.00
05A0378	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	George W. Wingate H.S. 600 Kingston Avenue Brooklyn NY	Approved	\$650.0
05A0379	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Pier 12 NY Cruise Terminal Brooklyn NY	Approved	\$650.00
	05A0376 05A0377 05A0378	05A0375 45-54 37th Street Long Island City NY 11101 05A0376 Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn NY 11234 05A0377 Atlantic Electrical Contracting Inc. 206 East 9th Street New York NY 10003 05A0378 Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451 05A0379 Primiano Electric Co.	05/10575 45-54 37th Street Long Island City equipment proposed to be installed 05A0376 Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn Requested approval for the electric service equipment proposed to be installed 05A0376 Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn Requested approval for the electric service equipment proposed to be installed 05A0377 Atlantic Electrical Contracting Inc. 206 East 9th Street New York Requested approval for the electric service equipment proposed to be installed 05A0378 Tru-Val Electric Corp. 2550 Park Avenue Bronx Requested approval for the electric service equipment proposed to be installed 05A0379 Primiano Electric Co. Requested approval for the electric service equipment proposed to be installed	05A0370 45-54 37th Street Long Island City equipment proposed to be installed 56-45 Main Street Flushing NY 05A0376 Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn Requested approval for the electric service equipment proposed to be installed Tilden High School 5800 Tilden Avenue Brooklyn 05A0377 Atlantic Electrical Contracting Inc. 206 East 9th Street New York Requested approval for the electric service equipment proposed to be installed 1160 Park Avenue New York 05A0378 Tru-Val Electric Corp. 2550 Park Avenue Bronx Requested approval for the electric service equipment proposed to be installed George W. Wingate H.S. 600 Kingston Avenue Brooklyn 05A0379 Primiano Electric Co. Requested approval for the electric service equipment proposed to be installed Pier 12 NY Cruise Terminal	0510070 45:54 37th Street Long Island City equipment proposed to be installed 56-45 Main Street Flushing Imported 05A0376 Morales Electrical Contracting, Inc. 4601 Avenue N Brooklyn Requested approval for the electric service equipment proposed to be installed Tilden High School 5800 Tilden Avenue Brooklyn Approved 05A0377 Atlantic Electrical Contracting Inc. 206 East 9th Street New York Requested approval for the electric service equipment proposed to be installed 1160 Park Avenue New York Approved 05A0378 Tru-Val Electric Corp. 2550 Park Avenue Bronx Requested approval for the electric service equipment proposed to be installed George W. Wingate H.S. 600 Kingston Avenue Brooklyn Approved 05A0379 Tru-Val Electric Corp. 205A0379 Requested approval for the electric service equipment proposed to be installed George W. Wingate H.S. 600 Kingston Avenue Brooklyn Approved

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46559	05A0380	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Urban Glass House 330 Spring Street New York NY	Approved	\$650.00
46560	05A0381	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	The O'Neil Building 655 6th Avenue New York NY	Approved	\$650.00
46561	05A0382	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Millennium Tower Residence 30 West Street New York NY	Approved	\$650.00
46562	05A0406	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Art & Design High School 1075 2nd Avenue New York NY	Approved	\$650.00
						1
46563	05A0405	L.E.A. Electric Corp. 270 W. 39th St., 2nd Fl., Ste #5.	Requested approval for the electric service equipment proposed to be installed	476 Broadway New York NY	Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46564	05A0407	Accurate Electrical Contractors Corp. 180 Rose Avenue Staten Island NY 10306	Requested approval for the electric service equipment proposed to be installed	Nagle Ave. Limited Partnership 228 Nagle Avenue New York NY	Approved	\$650.00
46565	05A0408	Premier Electric 38 Granite Avenue Staten Island NY 10303	Requested approval for the electric service equipment proposed to be installed	Francis Lewis High School 58-20 Utopia Parkway Queens NY	Approved	\$650.00
46566	05A0409	A.T.J. Electrical Co., Inc. 33-61 55th Street	Requested approval for the electric service equipment proposed to be installed	The Museum of the City 1220 Fifth Avenue	Approved	\$650.00
		Woodside NY 11377		New York NY		
46567	05A0411	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	Mission of Immaculate Virgin Outdoor Basketball Court Staten Island NY	Approved	\$650.00
46568	05A0412	WMGroup Engineers, P.C. 370 Seventh Avenue, Suite 1710	Requested approval for the electric service equipment proposed to be installed	NYU, The Palladium Bldg. 140 E. 14th Street	Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46569	05A0413	Rigid Electric, Inc. 336 37th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NYU East Building Chiller 239 Greene Street New York NY	Approved	\$650.0
46570	05A0414	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	7311 Lexington Avenue New York NY	Approved	\$650.0
46571	05A0416	Rothstein & Hoffman Electric Service, Inc. 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	240 Centre Street New York NY	Hold	\$650.
	of ATS 3 or 4 pole 75HP fire pump.) Show generator frame. 4) Show conductors off of gene		ding. 6) Verify	2000
46572	05A0423	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Bathgate H.S. 1595 Bathgate Avenue Bronx NY	Approved	\$650.
46573	05A0424	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Restaurant Depot 4340 57th Avenue Maspeth NY	Hold	\$650.
) Neutral in	800 amp fire pump		Verify the 400 amp service ahead of the 30 amp disconn		out.	

Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
05A0421	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	HSBC 452 Fifth Avenue New York NY	Approved	\$650.00
				1	
05A0361	Sideris Engineers P.C. 217-22 Northern Boulevard Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	482-504 Driggs Avenue Brooklyn NY	Approved	\$650.00
with LPN type. J	bb finalized 8/23/05.				1
05A0362	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	866 Third Avenue New York NY	Approved	\$650.00
05A0365	sociated Electrical Contractors of NY Cor 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	136 East 76th Street New York NY	Approved	\$650.0
05A0367	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue	Approved	\$650.00
	05A0421 05A0361 with LPN type. Jo 05A0362 05A0365	05A0421 Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside NY 11361 with LPN type. Job finalized 8/23/05. Image: Street Corp. 101-32 101st Street 05A0362 Five Star Electric Corp. 101-32 101st Street Image: Street Corp. 101-32 101st Street 05A0365 isociated Electrical Contractors of NY Cor 27 East 233rd Street Image: Street Corp. 10470	05A0421 Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York Requested approval for the electric service equipment proposed to be installed 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside Requested approval for the electric service equipment proposed to be installed 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside Requested approval for the electric service equipment proposed to be installed 05A0362 Five Star Electric Corp. 101-32 101st Street Ozone Park Requested approval for the electric service equipment proposed to be installed 05A0365 isociated Electrical Contractors of NY Cor 27 East 233rd Street Bronx Requested approval for the electric service equipment proposed to be installed 05A0367 Forest Electric Corp. Requested approval for the electric service equipment proposed to be installed	05A0421 Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York Requested approval for the electric service equipment proposed to be installed HSBC 452 Fifth Avenue New York 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside Requested approval for the electric service equipment proposed to be installed 482-504 Driggs Avenue Brooklyn 05A0362 Five Star Electric Corp. 101-32 101st Street Ozone Park Requested approval for the electric service equipment proposed to be installed 866 Third Avenue New York 05A0365 isociated Electrical Contractors of NY Cor 27 East 233rd Street Bronx Requested approval for the electric service equipment proposed to be installed 136 East 76th Street New York 05A0365 isociated Electric Corp. 27 East 233rd Street Bronx Requested approval for the electric service equipment proposed to be installed 136 East 76th Street New York 05A0367 Forest Electric Corp. Requested approval for the electric service equipment proposed to be installed 136 East 76th Street New York	International Contractors, Inc. Requested approval for the electric service equipment proposed to be installed HSBC 452 Fifth Avenue New York Approved 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside NY 11361 Requested approval for the electric service equipment proposed to be installed 482-504 Driggs Avenue Brooklyn NY Approved 05A0361 Sideris Engineers P.C. 217-22 Northern Boulevard Bayside NY 11361 Requested approval for the electric service equipment proposed to be installed 482-504 Driggs Avenue Brooklyn NY Approved 05A0362 Five Star Electric Corp. Requested approval for the electric service equipment proposed to be installed 866 Third Avenue New York NY Approved 05A0365 isociated Electrical Contractors of NY Cor 27 East 233rd Street Requested approval for the electric service equipment proposed to be installed 136 East 76th Street NY Approved 05A0365 isociated Electrical Contractors of NY Cor 27 East 233rd Street Requested approval for the electric service equipment proposed to be installed 136 East 76th Street NY Approved 05A0367 Forest Electric Corp. Requested approval for the electric service 136 East 76th Street NY Approved

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46579	05A0368	Egg Electric Inc. 26 West 17th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Hines 499 Park Avenue New York NY	Approved	\$650.00
46580	05A0369	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Modell's-Bronx 1500 Bassett Avenue Bronx NY	Approved	\$650.00
46581	05A0370	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Hilton Garden Inn/Days Hotel 790 Eighth Avenue New York NY	Approved	\$650.00
46582	05A0371	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Hilton Hotel 234 West 42nd Street New York NY	Approved	\$650.00
46583	05A0383	Five Star Electric Corp. 101-32 101st Street	Requested approval for the electric service equipment proposed to be installed	68 Bradhurst Avenue New York NY	Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46584	05A0384	Action Light & Power, Inc. 383 Willoughby Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	440 9th Avenue New York NY	Approved	\$650.00
46585	05A0385	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	1514 Sedgwick Avenue Bronx NY	Approved	\$650.00
46586	05A0386	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	130 West 19th Street New York NY	Approved	\$650.00
46587	05A0387	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	33 West End Avenue New York NY	Approved	\$650.00
					L.	
			Requested approval for the electric service		Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46589	05A0389	Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	219 East 44th Street New York NY	Approved	\$650.00
46590	05A0390	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	164 West 75th Street New York NY	Approved	\$650.00
46591	05A0391	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	390 Park Avenue New York NY	Approved	\$650.00
46592	05A0392	R. Gunzer Inc. 36-08 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	76 Madison Avenue New York NY	Approved	\$650.00
			1			

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46594	05A0394	B & G Electrical Contractors of NY, Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	245 Cherry Street New York NY	Approved	\$650.00
46595	05A0395	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	18 East 41st Street New York NY	Approved	\$650.00
						I
46596	05A0396	F.W. Clarke Electrical Contractors 2925 O'Neill Place Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	J.H.S. 50K 183 South 3rd Street Brooklyn ny	Approved	\$650.00
						I
46597	05A0397	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	IAC/Interactive Corp. 527 West 18th Street New York NY	Approved	\$650.00
46598	05A0398	S.J. Electric, Inc. 601 Union Street	Requested approval for the electric service equipment proposed to be installed	300 West 135th Street	Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46599	05A0399	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	300 East 55th Street New York NY	Approved	\$650.00
46600	05A0400	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mount Sinai Medical Center 5 East 98th Street New York NY	Approved	\$650.00
Transformer	undersized. Job fina	lized 8/23/05	<u> </u>			I
46601	05A0401	Donald White Electrical Inc. 1324 Bergen Street Brooklyn NY 11213	Requested approval for the electric service equipment proposed to be installed	1097 Lexington Avenue New York NY	Approved	\$650.00
46602	05A0402	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza New York NY	Hold	\$650.00
Provide 1 Lin	e of GE factory drav	wing.				I
46603	05A0403	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jacobi Medical Center 1400 Pelham Parkway South Bronx NY	Approved	\$650.00

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46604	05A0404	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	32-00 Skillman Avenue Long Island City NY	Approved	\$650.00
46605	05A0410	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	145 Brooklyn Avenue Brooklyn NY	Hold	\$650.00
Show existing	g loads from generat	tor and fusing.	1		I	
46606	05A0417	Walter T. Gorman P.E., P.C. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	CBS Building 513 57th Street New York NY	Approved	\$650.00
46607	05A0418	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Crown Castle Site 310 Greenwich Street New York NY	Approved	\$650.00
	05A0419	J.A. Lee Electric, Inc. 23-30 50th Avenue	Requested approval for the electric service equipment proposed to be installed	Crown Castle Site 371 7th Avenue	Approved	\$650.00

Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
05A0420	Mazza Electric Corp. 494 Eighth Avenue New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Adams & Co. Real Estate 30 West 24th Street New York NY	Approved	\$650.00
05A0415	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	136-35 37th Avenue Flushing NY	Approved	\$650.00
05A0422	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	155 Canal Street New York NY	Hold	\$650.00
	I	1			
05A0428	Folks Electrical, Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	Greenwich Street aka 19 Rector Stre New York NY	Approved	\$650.00
-	Hazrat Ramatalli, Licensed Electl Contr 111-17 Liberty Avenu Oueens NY 11419	Requesting permission to leave as installed outdoor meter equipment with a front clearance of less than 3 feet.	102-12 95 Avenue Queens NY	Approved	\$350.00
	05A0420 05A0415 05A0422	05A0420 Mazza Electric Corp. 494 Eighth Avenue New York NY 10001 05A0415 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464 05A0428 Folks Electrical, Inc. 670 Broadway New York NY 10012	05A0420 Mazza Electric Corp. 494 Eighth Avenue New York Requested approval for the electric service equipment proposed to be installed 05A0415 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 05A0422 D.J. Electrical Contractors, Inc. 670 Broadway New York Requested approval for the electric service equipment proposed to be installed 05A0428 Folks Electrical, Inc. 670 Broadway New York Requested approval for the electric service equipment proposed to be installed 05A0428 Folks Electrical, Inc. 670 Broadway New York Requesting permission to leave as installed outdoor meter equipment with a front clearance of less than 3	05A0420 Mazza Electric Corp. 494 Eighth Avenue New York Requested approval for the electric service equipment proposed to be installed Adams & Co. Real Estate 30 West 24th Street New York 05A0415 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 136-35 37th Avenue Flushing 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 136-35 37th Avenue Flushing 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 155 Canal Street New York 05A0428 Folks Electrical, Inc. 670 Broadway New York Requested approval for the electric service equipment proposed to be installed Greenwich Street aka 19 Rector Strc New York 05A0428 Folks Electrical, Inc. 670 Broadway New York Requesting permission to leave as installed outdoor meter equipment with a front clearance of less than 3 102-12 95 Avenue	OSA0420 Mazza Electric Corp. 494 Eighth Avenue New York Requested approval for the electric service equipment proposed to be installed Adams & Co. Real Estate 30 West 24th Street New York Approved 05A0415 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 136-35 37th Avenue Flushing Approved 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 136-35 37th Avenue Flushing Approved 05A0422 D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx Requested approval for the electric service equipment proposed to be installed 155 Canal Street New York Hold 05A0428 Folks Electrical, Inc. 670 Broadway New York Requested approval for the electric service equipment proposed to be installed Greenwich Street aka 19 Rector Street New York Approved - Hazrat Ramatalli, Licensed Electl Contr 111-17 Liberty Avenu Requesting permission to leave as installed outdoor meter equipment with a front clearance of less than 3 102-12 95 Avenue Approved

August 17, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46614		Sidney Electrical Contracting Inc. 1950 Coney Island Avenue Brooklyn NY 11223	Requesting permission to utilize an existing conduit located in the elevator shaftway that will supply power to the elevator motor due to AC conversion.	1012 Cortlandt Street New York NY	Approved	\$0.00
46615		P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requesting permission to allow a 29 inch clearance instead of 36 inches on the side of a 1000 KVA service switchboard.	Fortress Investment 5 Avenue of the Americas, Building New York NY	Approved	\$0.00
46616		Ferrara Electrical Corp. 115-07 Atlantic Avenue Richmond Hill NY 11418	Requesting permission to leave as installed existing fuse panels that were retro fitted with the interiors and covers of Cutler-Hammer circuit breaker panels.	39-35 155th Ave,and89-40 151st Ave Queens NY	Approved	\$350.00
46617		Testa Electric Co. Inc. 1435-65th Street Brooklyn NY 11219	Requesting permission to leave as installed service equipment for a cell site on the outside of a commercial building that is not grouped together with the existing service equipment.	5091 Amboy Road Staten Island NY	Approved	\$350.00
46618		Tarasis Electric Corp. 36-08 Ninth Street Long Island City NY	Requesting permission to temporarily fuse the new 3000 amp service switch at 1800 amps until the time when the additional loads will be added (and the property line box will be replaced/upgraded at that time). A large permanently affixed sign will be mounted on the switch indicating not to install a fuse larger than 1800 amps.	I.S. 2 333 Midland Avenue Staten Island NY	Approved	\$0.00

with the stipulation that this service is upgraded as sonn as possible.

Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	D.P. Facilities Incorporated 61 West 23rd Street New York NY 10010	Requesting permission to waive the requirement for selective fuse coordination for the first and second level over current protective devices that will feed two redundant 500 KVA UPS systems.	HSBC Bank 452 5th Avenue New York NY	Approved	\$0.00
	Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island NY 10306	Requesting permission to install service equipment on the outside of a building that will feed 4 apartments, 2 stores and a PLP meter in 2 buildings that do not have any common areas.	500 and 502 Bay Street Staten Island NY	Approved	\$0.00
05A0425	Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106	Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120.		Hold	\$200.00
DX2-120 on hold.	Must provide testing agency's certificate of	of listing.		I	I
05A0426	Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106	Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12.		Hold	\$200.00
er with UL listing no	ot consistent with applications.				
05A0427	Southwire Company 1 Southwire Drive Carrollton GA 30119	Requested approval for use in New York City of your Electrical Cable-Type MC.		Approved	\$200.00
	05A0425 0X2-120 on hold. 05A0426	D.P. Facilities Incorporated 61 West 23rd Street New York NY 10010 Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island NY 05A0425 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 05A0426 Lehigh Electric Products Company 05A0426 Lehigh Electric Products Company 05A0426 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Allentown PA 18106 Southwire Company 05A0427 Southwire Company	D.P. Facilities Incorporated 61 West 23rd Street New York Requesting permission to waive the requirement for selective fuse coordination for the first and second level over current protective devices that will feed two redundant 500 KVA UPS systems. Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island Requesting permission to install service equipment on the outside of a building that will feed 4 apartments, 2 stores and a PLP meter in 2 buildings that do not have any common areas. 05A0425 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120. 05A0426 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120. 05A0426 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12. r with UL listing not consistent with applications. Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12.	D.P. Facilities Incorporated 61 West 23rd Street New York Requesting permission to wave the requirement for selective fuse coordination for the first and second level over current protective devices that will feed two redundant 500 KVA UPS systems. HSBC Bank 452 5th Avenue New York Delaware Electrical Contracting Inc. - Requesting permission to install service equipment on the outside of a building that will feed 4 apartments, 2 stores and a PLP meter in 2 buildings that do not have any common areas. 500 and 502 Bay Street Staten Island 05A0425 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106 Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120. 05A0426 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106 Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12. rt with UL listing not consistent with applications. Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12.	D.P. Facilities Incorporated 6 West 23rd Street New York Requesting permission to waive the requirement for selective fuse coordination for the first and second level over current protective devices that will feed two redundant 500 KVA UPS systems. HSBC Bank 452 Sth Avenue New York Approved Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island Requesting permission to install service equipment on the outside of a building that will feed 4 approved approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120. 500 and 502 Bay Street Staten Island Approved 05A0425 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120. Hold 05A0426 Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12. Hold 05A0427 Southwire Company Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12. Hold

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46624	05A0429	Southwire Company 1 Southwire Drive	Requested approval for use in New York City of your Southwire HCF MC.		Approved	\$200.00
		Carrollton GA 30119				