

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50301CO	10A0331CO	Wesler-Cohen Associates Consulting Engs 740 Broadway Amityville NY 11701	Requested approval for the electric service equipment proposed to be installed	Staten Island Stapleton Marine 9 FDNY Staten Island NY	Denied	\$0.00
Carry over from September 15, 2010 meeting. The submittal is not in Advisory Board format, and the manufacturer's physical drawings were not submitted						
50602CO	11A0106CO	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	30 West 31st Street New York NY	Approved	\$0.00
Carry over from April 13, 2011 meeting. 1) Verify 4 sets of MI cable feeding limited service fire pump. 2) F.A. system undersized EGC's. 3) Vertical bus in service switchboard undersized. Job finalized 11/10/11.						
50714CO	11A0207CO	Brandl Electric Inc. 1926 Mott Avenue Far Rockaway NY 11191	Requested approval for the electric service equipment proposed to be installed	Jetro/Restaurant Depot 100 Oak Point Road Bronx NY	OK, but	\$0.00
Carry over from March 25, 2011 meeting. 1) TVSS not shown on 1-Line, where is TVSS located? 2) Fire pump feed cannot be tapped from cubicle that contains overcurrent protective devices.						
50746CO	11A0229CO	Enterprise Electrical Systems, Inc. 40 Emerson Court Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	165 West 91st Street New York N	Approved	\$0.00
Carry over from June 15, 2011 meeting.						
50749CO	11A0232CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Barclays Center Arena 620 Atlantic Avenue Brooklyn NY	Approved	\$0.00
Carry over from June 15, 2011 meeting. Length of transformer tap to new 400 amp panel not shown. Job finalized 9/1/11.						

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50804	11A0274	Twins Electric Corporation 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	400 West 119th Street New York NY	Approved	\$650.00
Through bus undersized.v 9/13/13 job finalized..						
50805	11A0275	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	CBRE 1 West 39th Street New York NY	Approved	\$650.00
50806	11A0276	Kramer Electric, LLC 336 West 37th Street, Suite 510 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	The Puck Building 295 Lafayette Street New York NY	Hold	\$650.00
1) Neutral disconnect link installed on line side of bonding and grounding. No supplemental ground lug provided. 2) Is DBI new or existing, bus size not provided. 3) Show second fusing off of existing service switches. 4) Service switch 3A not identified on 1-Line, is it rear accessible? 5) Dimension clearance at corner of new SEB. 6) Submit manufacturer cuts.						
50807	11A0277	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard-Bldg. 30 & 92 63 Flushing Avenue Brooklyn NY	Approved	\$650.00
1) Verify that existing service room is mechanically ventilated. 2) Fire pump switch, and circuit undersized. 3) Provide signage in building 92 indicating where the service is located. Job finalized 9/22/11.						
50808	11A0278	Spirelli Electric, Inc. 1901 Amethyst Street Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	City Point 1 DeKalb Avenue Brooklyn NY	Approved	\$650.00
Verify that service room is mechanically ventilated. Job finalized 9/22/11.						

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50809	11A0279	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	451 Broadway New York NY	Approved	\$650.00
50810	11A0280	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	120 Broadway New York NY	Approved	\$650.00
50811	11A0281	Delta Phase Electric Corporation 978 Kent Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	211 West 61st Street New York NY	Approved	\$650.00
50812	11A0282	Lizardos Mechanical & Electrical Eng. 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Lenox Hill Hospital 100 East 77th Street New York NY	Approved	\$650.00
50813	11A0283	Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	26th Ward Water Pollution Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50814	11A0284	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Costco 2975 Richmond Avenue Staten Island NY	Approved	\$650.00
1-Line does not match room layout. Job finalized 10/21/11.						
50815	11A0285	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	2130 Adam Clayton Powell Jr. New York NY	Approved	\$650.00
50816	11A0286	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	1717 Broadway New York NY	Approved	\$650.00
1) Equipment grounding conductors in MC cables are undersized. 2) More than 6 switches supplied from transformer, how long are transformer secondary conductors. 3) PVC jacketed MC cable to be behind 1 hour fire rated construction in the 2008 NEC. 3A) Provide secondary overcurrent protection on step-up 750 KVA transformer . 4) How long are transformer secondary conductors. 5) Show "DP-EM" on drawings. 6) Show F.A. switch on generator room floor plan. Job finalized 1/15/13. 4/7/15 Swapped Drawing 1,2,3, Revision 2s.						
50817	11A0287	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	770 11th Avenue New York NY	Approved	\$650.00
1) Service switch over fused. 2) Provide calculations for reduced neutral size. Job finalized 10/25/11.						
50818	11A0288	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	St. Anns Terrace 775 Eagle Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50819	11A0289	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	St. Anns Terrace 820 St. Anns Avenue, Site E Bronx NY	Approved	\$650.00
50820	11A0290	P2 Electric, Inc. 416 Graham Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	240 Park Avenue South New York NY	Approved	\$650.00
50821	11A0291	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Beth Israel Medical Center 10 Nathan D. Pearlman Place New York NY	Approved	\$650.00
Verify that rear cover of service switch is not removable. Job finalized 9/19/11.						
50822	11A0292	Jeminis Electrical Contractors, Inc. 22-42 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Lefrak 97-77 Queens Boulevard Queens NY	Denied	\$650.00
The tap to feed the fire pump cannot be made in the same enclosure that contains overcurrent protective devices.						
50823	11A0293	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	765-775 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50824	11A0294	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Courtland Community 929 Courtland Avenue Bronx NY	Approved	\$650.00
50825	11A0295	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	345 East 69th Street New York NY	Approved	\$650.00
50826	11A0296	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	International Gem Tower 55 West 46th Street New York NY	Ok, but	\$650.00
1) Generator distribution rooms to have 2 means of egress 110.26(c)(2). 2) Generator to have ground fault indication. 3) Fire pump circuit conductors normal and emergency to be fire rated. 4) Equipment grounding conductors undersized.						
50827	11A0297	Fritzmartin Electric, Inc. 76 Degraw Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	345 West 14th Street New York NY	Approved	\$650.00
1) Service entrance conductors to 2000 amp C.T, not identified. 2) Are circuit breaker panels for future use? AIC not provided. Job finalized 1/14/13. 10/30/14 Swapped Revision 2. 5/4/15 Swapped Revision 3.						
50828	11A0298	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	420 West 45th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50829	11A0299	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	The Windermere Hotel 666 West End Avenue New York NY	Approved	\$650.00
1) Equipment grounding conductor undersized. 2) Provide neutral link in service switch and supplemental ground. 3) Provide cut sheet of service entrance box from manufacturer. 4) Provide physical of new distribution panel. Job finalized 11/29/11.						
50830	11A0300	CSA Group 17 Battery Place, Suite 100 New York NY 10004	Requested Concept Approval:	CBS Broadcast Center 513 West 56th Street New York NY	Hold	\$0.00
Designer to appear to explain job.						
50831	11A0301	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Buckingham Hotel 101 West 57th Street New York NY	Hold	\$650.00
1) 5' clearance needed in front of new service equipment. 2) Is new equipment rear accessible? Can rear covers be removed? 3) Fire pump feed taken from cubicle that contains overcurrent protective devices. 4) Where is special service fire pump located? 5) 1200 amp through bus undersized. 6) Generator frame not grounded.						
50832	11A0302	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Main Street Radiology 136-25 37th Avenue, 2nd Floor Flushing NY	Approved	\$650.00
50833	11A0303	Fas Electrical Contractors Inc. 78-10 67th Drive Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	Lane Towers 107-40 Queens Blvd. Queens NY	Approved	\$650.00
1) How long is the tap to panel HDP-CHP. 2) Transformer T-1 not grounded. 3) How long are transformer T-1 secondary conductors to new distribution board. 4) Provide signage on new distribution board warning of live blades. Job finalized 9/22/11.						

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50834	11A0304	Foster Electrical Service Inc. 1325 Foster Avenue Brooklyn NY 11230	Requested approval for the electric service equipment proposed to be installed	ACS 1274 Bedford Avenue Brooklyn NY	Approved	\$650.00
50835	11A0305	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Bruckner Blvd & East 138th St. Bronx NY	Approved	\$650.00
Service switch #5 not bonded and grounded, no neutral link provided. Job finalized 9/22/11.						
50836	11A0306	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	P.S./I.S. 281 425 East 35th Street New York NY	Approved	\$650.00
1) Fire pump conductors to be 2 hour fire rated. 2) Feeders overfused. 3) Where is FA emergency switch located. Job finalized 10/11/12. 12/10/13 Swapped Rev 2 address correction Brooklyn to Manhattan. 8/18/15 Swapped Drawing C, Revision 2. 4/18/16 Swapped drawing C-Revision 3.						
50837	11A0307	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	601 West 26th Street New York NY	Rejected	\$650.00
Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 7/15/14 Rejected Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 12/1/14 1) Provide fused disconnect switch for portable generator 700-5(G) and bond and ground it. 2) 4 sets of 4/0 fuse at 1600 amps. 3) 4 pole ATS feeder 3 pole ATS.						
50838	11A0308	Electrical Design Management, LLC 939 Eighth Avenue, Suite 301 New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Jamaica 2 129-11 Jamaica Avenue Richmond Hill NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50839	11A0309	C & A Electrical Corp. 107-41A Merrick Blvd. Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	250 Mercer Street New York NY	Approved	\$650.00
50840	11A0310	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Times Building 229 West 43rd Street New York NY	Approved	\$650.00
Show size of vertical bus in new board. Job finalized 10/24/11.						
50841	11A0311	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	365 Bridge Street Brooklyn NY	Approved	\$650.00
Jumpers in disconnect switch undersized. Job finalized 10/25/11.						
50842	11A0312	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Battery Park Site 24 200/200 North End Avenue New York NY	Approved	\$650.00
Will grounding collector bus be accessible with barrier installed. Job finalized 10/24/11.						
50843	11A0313	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	250 East 54th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50844	11A0314	Broadway Electric, LLC 1261 Broadway, Suite 609 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	620 West 42nd Street New York NY	Approved	\$650.00
50845	11A0315	Jeminis Electrical Contractors, Inc. 22-42 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Hebrew Home for the Aged 5903 Palisades Avenue Bronx NY	Hold	\$650.00
Fire pump tap cannot be taken from a cubicle that contains overcurrent protective devices.						
50846	11A0316	Seong Jin Electric Inc. 37-12 58th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Gertz Plaza 162-10 Jamaica Avenue Queens NY	Approved	\$650.00
50847	11A0317	Maximum Electric Corp. 65-19 Metropolitan Avenue Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	10 Gracie Square New York NY	Approved	\$650.00
50848	11A0318	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Institute for Community Living 684 Livonia Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50849	11A0319	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	500 West 42nd Street New York NY	Approved	\$650.00
50850	11A0320	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	L & L Holding Co. 200 Fifth Avenue New York NY	Denied	\$0.00
Wrong calendar number for the above job address. The correct calendar # is 50856.						
50851		Mazza Electric Corp. 494 Eighth Avenue New York NY 10001	Requesting permission to replace a defective 400 amp service switch with new on a 1000KVA service	1619 Broadway-Basement New York NY	Approved	\$0.00
50852		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requesting permission due to lack of space inside of the existing service room to install a new service switch in a remote electrical distribution room where signage will be provided indicating where the other service is located	235 West 71st Street New York NY	Approved	\$0.00
50853		Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting permission to extend approximately 40 feet of service entrance conductors in fire rated MI cable in a ventilated trough where it is not feasible to trench the existing slab	West Side YMCA 5 West 63rd Street New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

August 17, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50854		Jays Electrical Contracting Co. 1440 Utica Avenue Brooklyn NY 11203	Requesting permission to replace an existing defective 800 amp service switch with new where the front clearance is 28 to 30 inches and there is no other location to install the new switch.	240 West 14th Street New York NY	Hold	\$0.00
Pending field evaluation.						
50855		P.A. Collins P.E. 15 West 26th Street, 5th Floor New York NY 10010	Requesting permission to install rigid non metallic conduit and PVC coated rigid metallic conduit exposed indoors in a corrosive area inside of the New York aquarium salt water holding tanks.	New York Aquarium Surf Avenue at West 10th Street Brooklyn NY	Approved	\$0.00
50856	11A0320	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	L & L Holding Co. 200 Fifth Avenue New York NY	Approved	\$0.00
Equipment grounding conductor undersized for 2000 amp fuse. Job finalized 9/19/11.						
50857	11A0321	Workrite Ergonomics 1450 Technology Lane Petaluma CA 94954	Requested approval for equipment for use in New York City of your Fino Undercabinet Lights.		Approved	\$200.00