

ADVISORY BOARD CALENDAR

August 31, 2020

Approval #	Submission #	Type of Request	Status	Fee
BK00361A	BK00361	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/14/2020 1. Comply with 445.13 - The generator W1 conductor is undersized. 2. Provide size of fire pumps conductors - Emergency side - and confirm 2 hr. fire rated as per 695.6 3. Clarify if the multiple addresses included in the project have the same block and lot or not. 4. Update the cover sheet with the owner and P.E. dated signature. 8/19/2020 1. Comply with 445.13 - The generator W1 conductor is undersized. 2. Provide size of fire pumps conductors - Emergency side - and confirm 2 hr. fire rated as per 695.6. 9/24/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00526A	BK00526	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/26/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00579A1	BK00579	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/5/2020 1. Comply with 695.4(B)(1)(1) for the fire pump OCPD- Please note the FLC as per table 430.250 shall be used not the name plate FLC. 2. Confirm compliance with 695.6(B)(1)(1) - Confirm 2" of concrete encasement to Fire Pump conductors. 8/10/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00584A1	BK00584	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>9/3/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK00615A1	BK00615	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>9/3/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

ADVISORY BOARD CALENDAR

August 31, 2020

Approval #	Submission #	Type of Request	Status	Fee
BK00616A1	BK00616	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/3/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00522A1	BX00522	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/28/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00541A2	BX00541	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/27/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/9/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/24/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00232A	MN00232	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/11/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00384	MN00384	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00409A1	MN00409	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/31/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

August 31, 2020

Approval #	Submission #	Type of Request	Status	Fee
MN00519A1	MN00519	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/5/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00544A	MN00544	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/31/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00559A1	MN00559	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/16/2020 Job finalized; Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00587A1	MN00587	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00588A	MN00588	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/1/2020 1. Conductors off SSW # 2, 3 & 4 are undersized. 2. Provide trip setting of Generator breakers. 3/23/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00591A	MN00591	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/25/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

August 31, 2020

Approval #	Submission #	Type of Request	Status	Fee
MN00597A1	MN00597	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/31/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00598A	MN00598	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00604A1	MN00604	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/20/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00605A1	MN00605	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/11/2020 1.Please Comply with NYC electrical code section 230.64(B) in the room layout 2.Verify the BS-BB switchboard rating where two new fuses are tapping from 3.Verify the tap conductor size feeds the exiting switchboard BS-BB 4.Clarity the generator notes 5.Verify ATS poles at the fire alarm; 8/26/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/26/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/11/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00607A	MN00607	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/28/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

ADVISORY BOARD CALENDAR

August 31, 2020

Approval #	Submission #	Type of Request	Status	Fee
MN00613A3	MN00613	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/31/2020 1. Confirm that Jockey Pump tap conductor comply with 430.28 and EGC is undersized 2. EGC is undersized after 400A fire pump switch per T250.122 3. Provide Amperage rating of new service switchboard 4. Confirm that new area of work within asbestos report or ACP-5 documents 9/17/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/22/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/9/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
MN00673A	MN00673	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>11/4/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
SI00487A1	SI00487	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>9/10/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
SI00620A1	SI00620	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>10/14/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/27/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/29/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				