

# ADVISORY BOARD CALENDAR

August 31, 2021

Approval #	Submission #	Type of Request	Status	Fee
BK01002A1	BK01002	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/16/2021 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 <a href="https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf">https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf</a>:                      The §4000-01 Rule includes but not limited to the following:                      a. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing.                      b. Available fault current at the new ACDP panel not accepted..8/31/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK01055A1	BK01055	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>9/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK01058A1	BK01058	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/24/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
BK01104A2	BK01104	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/12/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/27/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
BK01110A1	BK01110	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>8/13/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
BK01111A1	BK01111	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/12/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK01136A1	BK01136	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/9/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK01143A1	BK01143	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/16/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00950A1	BX00950	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/15/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work				
BX01158A2	BX01158	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/30/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/15/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
MN00050A2	MN00050	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/1/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/12/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN00655A	MN00655	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/23/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00764A1	MN00764	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00790A1	MN00790	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00974A1	MN00974	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/27/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00981A1	MN00981	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/26/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00991A2	MN00991	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/2/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/13/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN01033A1	MN01033	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01043A1	MN01043	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/1/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01045A1	MN01045	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/6/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01047A	MN01047	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/8/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
	MN01069	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>8/4/2021 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01  <a href="https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf">https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf</a>:                      The §4000-01 Rule includes but not limited to the following:                      a. A statement confirming that all fuses and/or circuit breakers have been coordinated for selective short circuit overcurrent protection must be on the drawing.                      b. Confirm UI listing of all the equipment – add note on the plans.                      2. Remove demolition plans from the EPR submission.                      3. Confirm that the existing 750KVA transformer secondary neutral is bonded and grounded.                      4. Provide rating of the existing ATSS (amperage, voltage and AIC ratings) and number of poles. 5. Floor plans shall clearly be labeled to match one-line plan and show the equipment clearances as per 110.26 and/or 110.34 and new versus existing equipment. Floor plans that only includes second level or beyond of OCPD should be removed from submission. The required floor plans are as follow:                      i. Any new or existing service room with changes were made for this submission.                      ii. Any new electrical equipment that 1000KVA or above Floor plans.                      6. Confirm that the new area of work included within the submitted ACP21- add note on the plan includes the ACP21 Document number</p>				
MN01075A1	MN01075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/12/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01112A1	MN01112	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
9/7/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01122A1	MN01122	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/18/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
MN01123A1	MN01123	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/6/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01126A1	MN01126	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/13/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/12/2022 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN01160A1	MN01160	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00784A	QN00784	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/6/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00795A1	QN00795	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/27/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00877A	QN00877	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**August 31, 2021**

Approval #	Submission #	Type of Request	Status	Fee
QN00926A	QN00926	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
10/8/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01009A1	QN01009	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/9/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01020A1	QN01020	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/10/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01106A	QN01106	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/26/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN01144A1	QN01144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
8/17/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				