

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                 | Status   | Fee    |
|---|--------------|--|--|---|----------|--------|
| 46970CO2  | 06A0096CO2   | The Electric Connection Inc.<br>410 West 127th Street<br>New York NY 10027           | Requested approval for the electric service equipment proposed to be installed | New Yorker Hotel<br><br>New York NY                   | Approved | \$0.00 |
| Carry over from March 15, 2006 meeting.   |              |  |  |   |          |        |
| 47171CO2  | 06A0257CO2   | Broadway Electric, LLC<br>1261 Broadway, Suite 609<br>New York NY 10001              | Requested approval for the electric service equipment proposed to be installed | 6 West 48th Street<br><br>New York NY                 | Hold     | \$0.00 |
| Carry over from July 12, 2006 meeting. Relocate equipment to adjacent room.         |              |  |  |   |          |        |
| 47183CO2  | 06A0230CO2   | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416               | Requested approval for the electric service equipment proposed to be installed | 1992 Broadway<br><br>New York NY                      | Approved | \$0.00 |
| Carry over from May 24, 2006 meeting.   |              |  |  |   |          |        |
| 47338CO   | 06A0419CO    | Danco Electrical Contractors, Inc.<br>40-17 24th Street<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Public Health Labs<br>455 First Avenue<br>New York NY | Approved | \$0.00 |
| Carry over from August 16, 2006 meeting. Maximize clearance. Job finalized 7/21/09. |              |  |  |   |          |        |
| 47366CO   | 06A0422CO    | SMC Electrical Contracting Inc.<br>150-11 14th Avenue<br>Whitestone NY 11357         | Requested approval for the electric service equipment proposed to be installed | IS 59Q<br>132-55 Ridgedale Street<br>Springfield NY   | Approved | \$0.00 |
| Carry over from August 16, 2006 meeting.  |              |  |  |   |          |        |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                      | Status   | Fee      |
|---|--------------|--|--|--|----------|----------|
| 47392   | 06A0427      | Momern Electrical Contractors Inc.<br>927 Dumont Avenue<br>Brooklyn NY 11207       | Requested approval for the electric service equipment proposed to be installed | 464 West 44th Street<br>New York NY                        | Approved | \$650.00 |
| Provide fencing to separate service room "open basement". Job finalized 9/20/06.  |              |  |  |  |          |          |
| 47393   | 06A0445      | Folks Electrical, Inc.<br>670 Broadway<br>New York NY 10012                        | Requested approval for the electric service equipment proposed to be installed | 170 East 77th Street<br>New York NY                        | Approved | \$650.00 |
| Provide fencing to separate service room "open basement". Job finalized 9/20/06.  |              |  |  |  |          |          |
| 47394   | 06A0457      | B & G Electrical Contractors of NY, Inc.<br>38-22 55th Street<br>Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | The Hub Parking Garage<br>3000-3002 3rd Avenue<br>Bronx NY | Hold     | \$650.00 |
| 1) Bonding jumper and ground lugs shown incorrectly. Must be on line side of disconnect link. 2) Feeder to 800A service switch #1 undersized. 3) Provide short circuit ratings of 'LLP' & 'MDP'. 4) Provide short circuit calculations and coordination curves with breaker settings. |              |  |  |  |          |          |
| 47395   | 06A0456      | Judd Electric, Inc.<br>41-41 38th Street<br>Long Island City NY 11101              | Requested approval for the electric service equipment proposed to be installed | 1090 Amsterdam Avenue<br>New York NY                       | Approved | \$650.00 |
| Provide cuts on Siemens mcc's and panelboard. Job finalized 12/18/06.   |              |  |  |  |          |          |
| 47396   | 06A0453      | Olympic Electrical Wiring Corp.<br>133 50th Street<br>Brooklyn NY 11232            | Requested approval for the electric service equipment proposed to be installed | 415 Greenwich Street<br>New York NY                        | Approved | \$650.00 |
| Provide cuts on Siemens mcc's and panelboard. Job finalized 12/18/06.   |              |  |  |  |          |          |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location   | Status   | Fee      |
|---|--------------|--|--|---|----------|----------|
| 47397   | 06A0447      | Barth-Gross Electric Co., Inc.<br>110 West 26th Street<br>New York NY 10001        | Requested approval for the electric service equipment proposed to be installed | Verizon<br>110 Greenwich Street<br>New York NY                  | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 47398   | 06A0448      | P.E. Stone, Inc.<br>50 Watts Street<br>New York NY 10013                           | Requested approval for the electric service equipment proposed to be installed | 245 Park Avenue Co.<br>245 Park Avenue<br>New York NY           | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 47399   | 06A0430      | GRX Euro Electric Corp.<br>164-13 Cross Island Parkway<br>Whitestone NY 11357      | Requested approval for the electric service equipment proposed to be installed | 1200 Fifth Avenue<br>New York NY                                | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 47400   | 06A0452      | B & G Electrical Contractors of NY, Inc.<br>38-22 55th Street<br>Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | Memorial Sloan Kettering<br>300 East 66th Street<br>New York NY | Hold     | \$650.00 |
| 1) Provide bus bar sizing per NYEC . 2) Provide fire pump data. 3) Show fuse types. 4) 480V feeds to F.A. must be disconnect switch (F.C.O. not permitted). 5) Provide 36" clearance around Switchboard #3. 6) Show fire pump switch on floor plan. 7) Provide equipment section views. |              |  |  |   |          |          |
| 47401   | 06A0431      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416             | Requested approval for the electric service equipment proposed to be installed | Cornerstone Site #6<br>68 Bradhurst Avenue<br>New York NY       | Approved | \$650.00 |
|   |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                | Status   | Fee      |
|---|--------------|--|--|--------------------------------------|----------|----------|
| 47402   | 06A0432      | Livingston Electrical Associates, Inc.<br>162-20 77th Road<br>Flushing NY 11366      | Requested approval for the electric service equipment proposed to be installed | 450 West 17th Street<br>New York NY  | Approved | \$650.00 |
| 1) Provide reduced neutral and voltage drop calculations. Confirm neutral size service switch #3, service 'A'. 2) Door to open out. Job finalized 9/25/06.                          |              |  |  |                                      |          |          |
| 47403   | 06A0433      | H.P. Electrical Designs Inc.<br>321 West 44th Street, Suite 405<br>New York NY 10036 | Requested approval for the electric service equipment proposed to be installed | 310 East 53rd Street<br>New York NY  | Approved | \$650.00 |
| 47404   | 06A0434      | Woodland Electrical Contracting Inc.<br>4601 White Plains Road<br>Bronx NY 10470     | Requested approval for the electric service equipment proposed to be installed | 145 East 125th Street<br>New York NY | Approved | \$650.00 |
| 1) Distribution 'MDP-H' panel bus undersized 750A@ 1000A/Sq. in. 800A Fu. 2) Block access to rear of service switchboard. Job finalized 9/20/06. 9/10/13 Drawing swapped for Rev 3. |              |  |  |                                      |          |          |
| 47405   | 06A0435      | Vlashava Electrical Contracting Corp.<br>171 Bayard Street<br>Brooklyn NY 11222      | Requested approval for the electric service equipment proposed to be installed | 70 West 36th Street<br>New York NY   | Approved | \$650.00 |
| 47406   | 06A0436      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416               | Requested approval for the electric service equipment proposed to be installed | 340 East 23rd Street<br>New York NY  | Approved | \$650.00 |
| 'DP-R' panel bus undersized 750A@ 1000A/Sq in. 800A Fu. Job finalized 9/20/06.  |              |  |  |                                      |          |          |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #   | Submission # | Applicant Name and Address   | Type of Request  | Installation Location   | Status   | Fee      |
|--|--------------|--|--|---|----------|----------|
| 47407  | 06A0438      | S.J. Electric, Inc.<br>601 Union Street<br>Brooklyn NY 11215                               | Requested approval for the electric service equipment proposed to be installed | 229 Chrystie Place<br>New York NY                                   | Approved | \$650.00 |
|  |              |  |  |   |          |          |
| 47408  | 06A0428      | Platinum Electrical Contracting Inc.<br>360 Industrial Loop Road<br>Staten Island NY 10309 | Requested approval for the electric service equipment proposed to be installed | 401 West 14th Street<br>New York NY                                 | Approved | \$650.00 |
|  |              |  |  |   |          |          |
| 47409  | 06A0429      | J.J. Rosenberg Electrical Contractors, Inc.<br>27 Herkimer Place<br>Brooklyn NY 11216      | Requested approval for the electric service equipment proposed to be installed | 47 West 66th Street<br>New York NY                                  | Approved | \$650.00 |
|  |              |  |  |   |          |          |
| 47410  | 06A0446      | Amber Lite Electric Corp.<br>4830 Arthur Kill Road<br>Staten Island NY 10309               | Requested approval for the electric service equipment proposed to be installed | Hakimian Organization<br>30 West 18th Street<br>New York NY         | Approved | \$650.00 |
| with the recommendation for doors to open out.   |              |  |  |   |          |          |
| 47411  | 06A0458      | Kanta Electric Corp.<br>34-21 56th Street<br>Woodside NY 11377                             | Requested approval for the electric service equipment proposed to be installed | Fashion Industries Voc. H.S.<br>225 West 24th Street<br>New York NY | Approved | \$650.00 |
| 1) Provide 2nd means of egress. 2) Must provide code requirement clearances. Job finalized 11/20/06. |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|--|--------------|---|--|--|----------|----------|
| 47412  | 06A0455      | Mac Electrical Contractors, Inc.<br>2807 Flatbush Avenue<br>Brooklyn NY 11234 | Requested approval for the electric service equipment proposed to be installed | 2569 Ocean Avenue<br>Brooklyn NY                               | Approved | \$650.00 |
| Relocate the service room door that has the 24 inch clearance to the 234 inch wall. Job finalized 10/2/06. |              |   |  |  |          |          |
| 47413  | 06A0454      | Olympic Electrical Wiring Corp.,<br>133 50th Street<br>Brooklyn NY 11232      | Requested approval for the electric service equipment proposed to be installed | 75 Smith Street<br>Brooklyn NY                                 | Approved | \$650.00 |
| Clarify the number of sets of conductors feeding equipment numbers 11,12, 13 & 14. Job finalized 12/18/06. |              |   |  |  |          |          |
| 47414  | 06A0449      | Nead Electric, Inc.<br>500 5th Avenue, Suite B-15<br>New York NY 10110        | Requested approval for the electric service equipment proposed to be installed | Department of Sanitation<br>52-35 58th Street<br>Queens NY     | Ok, but  | \$650.00 |
| 1) Confirm that existing 3000 amp busway is copper. 2) Remove neutral link in new switchboard.             |              |   |  |  |          |          |
| 47415  | 06A0450      | Nead Electric, Inc.<br>500 5th Avenue, Suite B-15<br>New York NY 10110        | Requested approval for the electric service equipment proposed to be installed | Corsair Capital<br>717 Fifth Avenue, 24th Floor<br>New York NY | Approved | \$650.00 |
| 47416  | 06A0444      | Alpine Electrical Inc.<br>1448 65th Street<br>Brooklyn NY 11219               | Requested approval for the electric service equipment proposed to be installed | 6722 Fort Hamilton Parkway<br>Brooklyn NY                      | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar # | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee      |
|------------|--------------|---|--|---|----------|----------|
| 47417      | 06A0451      | Michael Mazzeo Electric Corp.<br>41-24 24th Street<br>Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | H & M<br>111 Fifth Avenue, Cellar<br>New York NY                  | Approved | \$650.00 |
| 47418      | 06A0437      | Action Light & Power, Inc.<br>383 Willoughby Avenue<br>Brooklyn NY 11205        | Requested approval for the electric service equipment proposed to be installed | Beth Chana School<br>712 Bedford Avenue<br>Brooklyn NY            | Approved | \$650.00 |
| 47419      | 06A0439      | Nori Electric, Inc.<br>527 West 29th Street<br>New York NY 10001                | Requested approval for the electric service equipment proposed to be installed | 1160 Park Avenue<br>New York NY                                   | Approved | \$650.00 |
| 47420      | 06A0440      | Spiro Electric, Inc.<br>201-07 Northern Blvd.<br>Bayside NY 11361               | Requested approval for the electric service equipment proposed to be installed | Agency for Childrens Services<br>90-25 161st Street<br>Jamaica NY | Approved | \$650.00 |
| 47421      | 06A0441      | S.J. Electric, Inc.<br>601 Union Street<br>Brooklyn NY 11215                    | Requested approval for the electric service equipment proposed to be installed | Queens Crossing<br>138-20 38th Avenue<br>Flushing NY              | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location                                  | Status   | Fee      |
|--|--------------|---|--|--|----------|----------|
| 47422  | 06A0442      | K.G.K. Electric Corp.<br>21-03 21st Avenue<br>Astoria NY 11105                        | Requested approval for the electric service equipment proposed to be installed   | 106-21 Beach Channel Drive<br>Rockaway NY              | Approved | \$650.00 |
|  |              |   |  |  |          |          |
| 47423  | 06A0443      | Atlas-Acon Electric Service Corp.<br>283 Hudson Street<br>New York NY 10013           | Requested approval for the electric service equipment proposed to be installed   | Rockefeller Ctr. a.k.a. 1250 6th Ave<br>New York NY    | Approved | \$650.00 |
| Provide short circuit and coordination study. Job finalized 9/20/06.                     |              |   |  |  |          |          |
| 47424  | 06A0459      | Arnold Finkelstein, Licensed Electrician<br>430 East 89th Street<br>New York NY 10028 | Requested approval for the electric service equipment proposed to be installed   | Sprint/Nextel<br>809 First Avenue<br>New York NY       | Approved | \$650.00 |
|  |              |   |  |  |          |          |
| 47425  | ~            | Jeco Electrical Service Corp.<br>1162 Intervale Avenue<br>Bronx NY 10459              | Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit for 5 three family buildings located in a corrosive area, Far Rockaway, Queens | 76, 280, 282, 284, 286 Watjean Cour<br>Far Rockaway NY | Approved | \$0.00   |
|  |              |   |  |  |          |          |
| 47426  | ~~           | Able Electl Service & Maintenance Inc.<br>161 Van Dyke Street<br>Brooklyn NY 11231    | Requesting permission to install overhead service entrance conductors in rigid non metallic conduit for a one family building located in a corrosive area, Far Rockaway, Queens          | 1236 Norton Drive<br>Far Rockaway NY                   | Approved | \$0.00   |
| With the stipulation that Schedule 80 non metallic conduit is used as the wiring method. |              |   |  |  |          |          |



# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request   | Installation Location  | Status   | Fee      |
|---|--------------|--|---|--|----------|----------|
| 47427   | ~~~~         | M-E Engineers<br>417 Fifth Avenue, 5th Floor<br>New York NY 10016                      | Requesting permission due to financial hardship to install a transformer to correct voltage drop on service entrance conductors that will run approximately 1600 feet to a building   | Central Park Police Precinct<br>@ 86th Street<br>New York NY | Denied   | \$0.00   |
| The transformer shall not be used to compensate for voltage drop.   |              |  |   |  |          |          |
| 47428   | ~~~~~        | Joseph R. Loring & Associates, Inc.<br>21 Penn Plaza, 14th Floor<br>New York NY 10001  | Requesting permission to leave as installed a replacement 1000 KVA generator that faces a new distribution board with a front clearance of 3 feet 4 1/4 inches in a building that does not have available space to relocate the generator or switchboard. | One Centre Street<br>New York NY                             | Approved | \$0.00   |
| With the stipulation that insulating material is applied to the side of the generators fuel tank that faces the switchgear. |              |  |   |  |          |          |
| 47429   | ~~~~~        | Consentini Associates Consulting Eng<br>Two Pennsylvania Plaza<br>New York NY 10121    | Requesting concept approval to install 2-4000 amp emergency circuit breakers in series.   | Goldman Sachs<br>Battery Park City Site 26<br>New York NY    | Approved | \$0.00   |
| 47430   | ~~~~~        | Levinson & Santoro Electric Corp.<br>20-16 130th Street<br>College Point NY 11356      | Requesting permission to leave one mean of egress into a service room. RE: Cal. #47340. Ok, but.  | P.S. 70X<br>1691 Weeks Avenue<br>Bronx NY                    | Approved | \$0.00   |
| Pending further information. Item finalized 9/21/06.  |              |  |   |  |          |          |
| 47431   | 06A0460      | A.L.P. Lighting Components, Inc.<br>1401 Blairs Bridge Road<br>Lithia Springs GA 30122 | Requested approval for use in New York City of your Fluorescent Strip Fixture with Riveted Ends, Pivot Style. Model/Series Numbers: SEP 220, 240, 272 AND 296.  |  | Denied   | \$200.00 |
| The electrical Advisory Board does not approve fixture components.  |              |  |   |  |          |          |

# ADVISORY BOARD CALENDAR

**September 13, 2006**

| Calendar #  | Submission # | Applicant Name and Address                                | Type of Request   | Installation Location | Status   | Fee      |
|---|--------------|---|---|-----------------------|----------|----------|
| 47432   | 06A0461      | Bretford Mfg.<br>11000 Seymor Avenue<br>Franklin IL 60131 | Requested approval for use in New York City of your Office Furniture. Model/Series Numbers: PUL 3060PT. PUL 3060PT-NY |                       | Approved | \$200.00 |
| With the stipulation that the manufacturer's installation instructions state that each table must be secured in a manner that will prevent damage to the wiring system upon movement of the tables. |              |   |   |                       |          |          |