

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|---|--|---|----------|--------|
| 45452CO3 | 04A0034CO3 | Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102 | Requested approval for the electric service equipment proposed to be installed | The Rockefeller University 1230 York Avenue New York NY | Approved | \$0.00 |
| Carry over from February 18, 2004 meeting. | | | | | | |
| 45668CO3 | 04A0195CO3 | Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365 | Requested approval for the electric service equipment proposed to be installed | Bloomberg 731 Lexington Avenue New York NY | Hold | \$0.00 |
| No Show | | | | | | |
| 45761CO2 | 04A0284CO2 | UL Electrical Corp. 115-05 Liberty Avenue, 2nd Floor Richmond Hill NY 11419 | Requested approval for the electric service equipment proposed to be installed | 225 Broadway New York NY | Approved | \$0.00 |
| Carry over from July 21, 2004 meeting. | | | | | | |
| 45849CO | 04A0356CO | Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373 | Requested approval for the electric service equipment proposed to be installed | 333 East 102nd Street New York NY | Approved | \$0.00 |
| Carry over from August 18, 2004 meeting. | | | | | | |
| 45875CO | 04A0382CO | Emergency Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236 | Requested approval for the electric service equipment proposed to be installed | Franklyn Plaza Apts 2081 2nd Avenue New York NY | Denied | \$0.00 |
| The service entrance conductors are undersized. | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|--|--|--|----------|----------|
| 45890 | 04A0393 | Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019 | Requested approval for the electric service equipment proposed to be installed | Pierpoint Morgan Library 29 East 36th Street New York NY | Approved | \$650.00 |
| 1) Bus undersized in sections 2 and 3. 2) 75 KVA f.p. XFMR should be 208A-408/277Y step-up. 3) Show fuse cut-out on 1-Line. 10/6/04 Finalized. | | | | | | |
| 45891-VOID | 04A0411-Void | Void | Requested approval for the electric service equipment proposed to be installed | | Denied | \$0.00 |
| | | | | | | |
| 45892 | 04A0399 | Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003 | Requested approval for the electric service equipment proposed to be installed | 650 Fifth Avenue New York NY | Approved | \$650.00 |
| Provide make and model of new 600A switches. 9/28/04-Finalized. | | | | | | |
| 45893 | 04A0390 | Falco Electrical Services, Inc. 2220 Voorhies Avenue Brooklyn NY 11235 | Requested approval for the electric service equipment proposed to be installed | 260 Madison Avenue New York NY | Hold | \$650.00 |
| 1) Provide detaile of bus tap. 2) Confirm 208A-480/277Y winding on XFMR. 3) Submit drawing in Advisory Board format. | | | | | | |
| 45894 | 04A0407 | Expert Electric, Inc. 18-71 41st Street Astoria NY 11105 | Requested approval for the electric service equipment proposed to be installed | 1 Centre Street New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|--|----------|----------|
| 45895 | 04A0395 | Sage Electrical Contracting, Inc. 651 Willowbrook Rd., Suite 201 Staten Island NY 10314 | Requested approval for the electric service equipment proposed to be installed | Hippodrome 1120 6th Avenue New York NY | Hold | \$650.00 |
| 1) 4000A feeder to 21st floor undersized. 2) 1200A feeder to 500KVA strap-up XFMR undersized. 3) Provide info on 500 KVA XFMR: winding configuration, make, model. 4) Clarify floor plan. | | | | | | |
| 45896 | 04A0394 | Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219 | Requested approval for the electric service equipment proposed to be installed | 580 5th Avenue New York NY | Hold | \$650.00 |
| 1) Provide GFP per 215.10 for 1200A, 480V switch. 2) Clarify grounding of XFMR neutral. 3) Clarify method of running PVC conduit. 4) Provide details of new tap section. 5) Clarify 24" front clearance of existing service switchboard. | | | | | | |
| 45897 | 04A0392 | Star Electric 494 Greenwich Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | DEP 96-05 Horace Harding Expressway Queens NY | Approved | \$650.00 |
| | | | | | | |
| 45898 | 04A0389 | Egg Electric Inc. 26 West 17th Street New York NY 10011 | Requested approval for the electric service equipment proposed to be installed | NYU Hospital 550 First Avenue-Bsmt New York NY | Approved | \$650.00 |
| 1) Clarify fuse make and type on new switchboard. 2) Modify concrete pads and curbing to eliminate trip hazard. 6/1/05 item finalized. | | | | | | |
| 45899 | 04A0388 | James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231 | Requested approval for the electric service equipment proposed to be installed | Empire State College 325 Hudson Street New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|---|---|----------|----------|
| 45900 | 04A0412 | United Electrical Contracting Corp, 69 Ludlow Street New York NY 10002 | Requested approval for the electric service equipment proposed to be installed | 129 Lafayette Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 45901 | 04A0416 | S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215 | Requested approval for the electric service equipment proposed to be installed | Queens Windsor 108-24 71st Street Queens NY | Approved | \$650.00 |
| 1) Primary protection and conductor undersized for 75 KVA XFMR. 2) Panel EPP voltage incorrect. 9/28/04-Finalized. | | | | | | |
| 45902 | 04A0417 | Sterling Electric Inc. 863 Sterling Place Brooklyn NY 11216 | Requested approval for the electric service equipment proposed to be installed | 721 Amsterdam Avenue New York NY | Approved | \$650.00 |
| | | | | | | |
| 45903 | 04A0415 | Sage Electrical Contracting, Inc. 651 Willowbrook Rd., Suite 201 Staten Island NY 10314 | Requested approval for the electric service equipment proposed to be installed | 622 Broadway New York NY | Approved | \$650.00 |
| | | | | | | |
| 45904 | 04A0414 | Pabst Electric Company Inc, 45-48 51st Street Woodside NY 11377 | Requested approval for the electric service equipment proposed to be installed | City Center HVAC Upgrade 130 West 56th Street New York NY | Hold | \$650.00 |
| 1) Show existing service room on floor plan. 2) Indicate signage for two service rooms. | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|--|---|----------|----------|
| 45905 | 04A0413 | Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219 | Requested approval for the electric service equipment proposed to be installed | PC Richards 53 West 23rd Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 45906 | 04A0418 | Consolidated Electric Construction Co, 201 East 42nd Street, 11th Floor New York NY 10017 | Requested approval for the electric service equipment proposed to be installed | 130 Fulton Street New York NY | Approved | \$650.00 |
| 1) Service conductors undersized. 2) Feed-thru cables in 'HDP' undersized. 3) Access around new switchboard 'MSB' inadequate. 9/28/04-Finalized. | | | | | | |
| 45907 | 04A0419 | H & L Electric Inc. 41-11 28th Street Long Island City NY | Requested approval for the electric service equipment proposed to be installed | 425 East 25th Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 45908 | 04A0406 | Polo Electric Corp. 497 Canal Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 505 Fifth Avenue New York NY | Approved | \$650.00 |
| Physicals of both switchboards don't match one line. 9/28/04-Finalized. | | | | | | |
| 45909 | 04A0405 | Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 249 Boyland Street Brooklyn NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|--------------|---|---|--|----------|----------|
| 45910 | 04A0404 | Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 1440 Broadway New York NY | Approved | \$650.00 |
| | | | | | | |
| 45911 | 04A0403 | Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110 | Requested approval for the electric service equipment proposed to be installed | Whole Food Market 4 Union Square South New York NY | Approved | \$650.00 |
| | | | | | | |
| 45912 | 04A0402 | Al-Lectric electrical Corp. 137 Chrystie Street New York NY 10002 | Requested approval for the electric service equipment proposed to be installed | 141 Duane Street New York NY | Approved | \$650.00 |
| Move service switch. If not installed, confirm measurements on drawing. 9/28/04-Finalized. | | | | | | |
| 45913 | 04A0401 | Livingston Electrical Assoc. Inc. 162-20 77th Road Flushing NY 11366 | Requested approval for the electric service equipment proposed to be installed | 210 Lafayette Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 45914 | 04A0400 | Dynamic Electric Service Inc. 14-17 110th Street College Point NY 11356 | Requested approval for the electric service equipment proposed to be installed | 1021 Park Avenue New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|---|--|----------|----------|
| 45915 | 04A0398 | High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 9 West 31 Street New York NY | Approved | \$650.00 |
| Confirm location of special fire pump. 9/28/04-Finalized. | | | | | | |
| 45916 | 04A0397 | High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | 780 8th Avenue New York NY | Approved | \$650.00 |
| | | | | | | |
| 45917 | 04A0396 | A & R Electrical Maintenance, Inc. 85-44 Grand Avenue Elmhurst NY 11373 | Requested approval for the electric service equipment proposed to be installed | 175 West 90th Street New York NY | Approved | \$650.00 |
| | | | | | | |
| 45918 | 04A0391 | Intrpid Electrical Contracting, Inc. 149 Waterbury Avenue Staten Island NY 10309 | Requested approval for the electric service equipment proposed to be installed | Alan Stevenson School 132 East 78th Street New York NY | Approved | \$650.00 |
| 1- line is mixed up. 9/28/04-Finalized. | | | | | | |
| 45919 | 04A0410 | Salvatore Campisi & Sons Elecl Contrs, Inc 453 Onderdonk Avenue Ridgewood Ny 11385 | Requested approval for the electric service equipment proposed to be installed | 111 West 19 Street New York NY | Approved | \$650.00 |
| | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|--------------|--|--|--|----------|----------|
| 45920 | 04A0409 | Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220 | Requested approval for the electric service equipment proposed to be installed | 410 West 24 Street New York NY | Hold | \$650.00 |
| 1) Need copper detail of Con- Ed box. 2) Service bus undersized. | | | | | | |
| 45921 | 04A0408 | Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220 | Requested approval for the electric service equipment proposed to be installed | 405 West 23 Street New York NY | Hold | \$650.00 |
| 1) Need copper detail of Con-Ed box. 2) Provide fuse types. 3) Show neutral bonds. 4) Service bus undersized. | | | | | | |
| 45922 | 04A0420 | Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101 | Requested approval for the electric service equipment proposed to be installed | Food Emporium 2008 Broadway New York NY | Approved | \$650.00 |
| 45923 | 04A0421 | Polo Electric 497 Canal Street New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | Prada 575 Broadway New York NY | Approved | \$650.00 |
| 1) Change 400AMP TR fuse to A2D or A2K . 2) Remove the letters HPD - SC-1 and change to none automatic circuit breaker. 3) change BL circuit breakers to HBL in HDP- SC-2. 10/6/04-Finalized. | | | | | | |
| 45924 | 04A0422 | Woodside Electric Corp. 1200 Oakpoint Avenue Bronx NY 10474 | Requested approval for the electric service equipment proposed to be installed | Renwick Gardens 332 East 29th Street New York Ny | Ok, but | \$650.00 |
| Confirm that switchboard is not rear accessible. | | | | | | |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|---|----------------|--|---|---|----------|----------|
| 45925 | 04A0423 | MI Electric Inc. 18-38 119th Street College Point Ny 11356 | Requested approval for the electric service equipment proposed to be installed | 136-21 Roosevelt Avenue Flushing Ny | Hold | \$650.00 |
| 1) Clarify feeder to fire pump. 2) Provide location of fire pump. 3) Tap to fire pump service switch shall not be made in service switch enclosure. 4) Show doors on service room layout. | | | | | | |
| 45926 | ---- | Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314 | Requesting permission to install a new second service on a property where a cabana and pool will be built approximately 250 feet away from the existing single family house. | Robert Golden Residence 33 Columbia Avenue Staten Island NY | Approved | \$0.00 |
| 45927 | ---- | M-E/Vogel Taylor Engineers, P.C. 417 Fifth Avenue, Suite 501 New York NY 10016 | Requesting permission on a previously denied submittal to leave as installed surface non metallic raceway in a law school building. | New York University Vanderbilt Hal 40 Washington Square South New York Ny | Approved | \$0.00 |
| 45928 | ----- - | UL Electrical Corp. 115-05 Liberty Avenue, 2nd Floor Richmond Hill NY 11419 | Requesting permission to leave as install a 800 amp automatic transfer switch that replaced a 400 amp ATS inside of an existing service room. No extra load was added to the ATS. | Beth Rivkah School 470 Lefferts Avenue Brooklyn Ny | Approved | \$0.00 |
| 45929 | ----- ----- | Consolidated Electric Construction Co. 205 East 42nd Street New York NY 10017 | Requesting permission on a one month temporary installation to install feeder and branch circuit wiring with hard usage or extra-hard usage multi conductor cords. The installation will comply with Article 527 for temporary installations. | Target "Pop-Up" Store 7 Times Square-Ground Floor New York NY | Approved | \$0.00 |

ADVISORY BOARD CALENDAR

September 15, 2004

| Calendar # | Submission # | Applicant Name and Address | Type of Request | Installation Location | Status | Fee |
|--|---------------|---|---|--|----------|--------|
| 45930 | ----- ---- | Unisys Electric Inc. 19 Irving Place Staten Island NY 10304 | Requesting permission to add a second means of egress in a switchboard room where the switchboard does not have the proper side clearances. | Brooklyn Navy Yard 63 Flushing Avenue, Bldg. 500 Brooklyn NY | Approved | \$0.00 |
| With the stipulation that it is one time one location. | | | | | | |
| 45931 | ----- ---- | Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036 | Requesting permission for education purposes only, to install Romex wiring in a single family house that will be built inside of a technical training school. | 139-10 15th Avenue Whitestone NY | Approved | \$0.00 |
| With the stipulation one time one location | | | | | | |