

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54175	15A0017CO2	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	400 Bay 41st Street Brooklyn NY	Approved	\$0.00
Carry over from July 13, 2016 meeting. 1) Fire pump emergency breaker undersized, EGC conductor undersized. 2) Show ATS #1 on drawing. 10/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0141CO	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	RXR Realty 75 Rockefeller Plaza New York NY	Rejected	\$0.00
Carry over from December 16, 2015 meeting. 1) Via-Link feeder for fire pump undersized, transition. 2) Provide fire pump cut sheets with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/2/16 Rejected. 1) Transition boxes and conductors not shown. 2) Show withstand rating of FP controller and fault current at fire pump controller.						
	16A0005	B & G Electrical Contractors of NY, Inc. 38--22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	155 Richmond Terrace Staten Island NY	Pending	\$650.00
1) Drawing 1, tapped conductor to APH-3TK and DPL-3TK undersized. 2) Drawing 2 feeder to DPH-1TB undersized. 3) Drawing 2, show wiring methods and feeder sizes for fire and jockey pumps. 4) Drawing 3, show length of transformer tap to "TR-MTA". 5) Provide generator room layout drawing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.						
With the stipulation:						
Fire Rated Enclosure's must comply with the following:						
<ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0027CO2	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	217 West 57th Street New York NY	On Hold	\$0.00
Carry over from June 8, 2016 meeting. 1) Drawing K-Load bank breaker not GF type. 2) Provide physical of olsun 2500 KVA substation R1/R2, are there rear doors? 3) Explain the use of neutral conductor on the double ended switchboard R1/R2, is there transformer differential being used to protect transformer? 4) DP-MEP-7 and DP-N-1, 1 Line does not match physical.						
54328	16A0447	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	1565 Forest Avenue Staten Island NY	Approved	\$650.00
Provide short circuit curves. 1/30/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0485	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue, 6th Floor New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 5th Avenue New York NY	Denied	\$650.00
OR 1) Drawing not in Advisory Board format. 2) Coordination study performed, signed, and sealed by a P.E. not provided. 3) 1 Line doesn't match physical. 4) overcurrent devices not shown on 1 line for panel D.P.						
	16A0537	Top Shelf Electric Corporation 4386 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	45 Park Place New York NY	Pending	\$650.00
<p>1.Drawing to be darker, very hard to follow feeders</p> <p>2.Show 3rd fusing for meter banks on 12th floor, provide manufacturers' cut sheets of meter banks and circuit breakers</p> <p>3.Show size of equipment grounding conductor in MC riser cable</p> <p>4.Generator frame to be bonded to building steel</p> <p>5.Manufactures cut sheets of equipment not provided, switch board, fire pumps, transformers</p> <p>6.Review not complete</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54112	16A0541CO	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	719 Seventh Avenue New York NY	Approved	\$0.00
Carry over from August 17, 2016 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0543CO2	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue, New York NY 10017	Requested approval for the electric service equipment proposed to be installed	25-70 Whitestone Expressway Queens NY	On Hold	\$0.00
1) Correct typo on 1 Line showing 2 4" conduits on 1 Line. 2) Verify size of conductor feeding transformers, 1 Line doesn't match coordination study 4/0-2/0.						
	16A0585	Centrifugal Electric, LLC 7 West 36th Street, 6th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	161 Maiden Lane New York NY	On Hold	\$650.00
<p>1) Indicate riser sizes up to last meter switch tap and tapping method. 2) Gen set indicated as non-separately derived system and indicates bonding of neutral. 3) T-3-1, T-3-2, secondary devices to have GFCI protection. 4) Address the comment on page 9 of coordination study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0591	James F. Volpe Electl Contrg Corp. 81Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Brooklyn Army Terminal 140A 58th Street Brooklyn NY	Pending	\$650.00
<p>1) Neutral conductor required for fire alarm service switch to bond and ground. 2) Equipment grounding conductor to fire alarm service switch undersized. 3) Fire alarm ATS to be 4 pole if using 4 wire system. 4) Provide coordination study for emergency system. 5) ATS not be installed in switchboard room. 6) Emergency switchboard labeled as service switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54087	16A0592	Pappas Fodera Electric 260 Beach 116th Street Rockaway NY 11694	Requested approval for the electric service equipment proposed to be installed	772 Edgewater Road Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/19/16 Swapped Drawing D-Revision.1.						
54186	16A0605	Energy Squared, LLC 1 Independence Way Princeton NJ 08540	Requested approval for the electric service equipment proposed to be installed	1984 Bruckner Boulevard Bronx NY	Approved	\$650.00
1) Cover letter to be signed, sealed and stamped by a P.E. 2) Where is the service located? 3) Service room to comply with 230.64(B). 4) SS-A--feeders to 1000 KVA fused. 5) Both service switchboards main bonding jumpers installed on load side of neutral link. 6) Switchboards to comply with 408.60(F). 7) Provide physical for MDP-B. 8) Transformer primary switch to be rated for transformer inrush current. 9) Provide siteplan and indicate traffic protection for equipment. 11/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54102	16A0611	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	1520 Sedgwick Avenue Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54110	16A0619	M.C. Electrical NY, Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	459 East 149th Street Bronx NY	Approved	\$635.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54111	16A0620CO	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	435 West 31st Street New York NY	Approved	\$0.00
Carry over from August 17, 2016 meeting. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54113	16A0627	QNCC Electric 84-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	400 Central Park West New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54094	16A0628	QNCC Electric 84-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	150-38 Union Turnpike Queens NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54219	16A0639	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	2926 West 28th Street Bronx NY	Approved	\$650.00
<p>1) What series is the MI cable ? 2) Show how 10 sets of MI transition to 4 sets of 600KCM. *Note: In the future please staple together genset and ATS documents separately no clamps.with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54225	16A0641	Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	2943 West 28th Street Brooklyn NY	Approved	\$650.00
<p>1) Panels SFDP, PDP-AB, TDP-B1, TDP-B2, PDP-C, TDP-C1/C2 and DP-cc if 3rd fusing indicate it on 'physical'. 2) Distribution board MDB-C not shown room layout and physical drawings. 3) What series is the MI cable? Note: In the future, please staple together genset and ATS documents seaparately no clamps. 4) Show how 8 sets of MI cable transition to conductors. 5) Provide genset cutsheets. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54177	16A0651	Beacon Electric Corp. 266 Jericho Turnpike Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	304 Park Avenue New York NY	Approved	\$650.00
OR Length of tap not shown. 10/26/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54181	16A0652	Z & Z Electric Inc. 2380-82 Hughes Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	32-00 Skillman Avenue Queens NY	Approved	\$650.00
OR Tap conductors to 800 amp disconnect switches undersized. 11/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54124	16A0655	Zin Electrical, Inc. 1267 Utica Avenue Brooklyn NY 11203	Requesting permission to reutilize existing riser conduits where a new staircase is being installed and the concrete slab containing existing conduits was cut out resulting in rerouting new raceways to go around the cutout and back to the disconnecting means utilizing Bulletin No 142 Table 3 for rewiring existing conduits only.	306-308 East 38h Street New York NY	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0657	Real Power Engineers, LLC 41 Samantha Drive Morganville NY	Requested approval for the electric service equipment proposed to be installed	55 5th Avenue New York NY	Denied	\$650.00
1) Drawings to be in Advisory Board format. 2) Provide exact detailed report of the scope of work to be performed on the service and feeders.						
54104	16A0658	Hatzel & Buehler, Inc. 230 Park Avenue, Suite 925 New York NY 10169	Requested approval for the electric service equipment proposed to be installed	388 Greenwich Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54103	16A0659	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	475 Fifth Avenue, 11th Floor New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

	16A0661	New York Empire Electrical Contracting 1236 Jerome Avenue Bronx NY 10460	Requested approval for the electric service equipment proposed to be installed	558 Grand Concourse Bronx NY	Pending	\$650.00
--	---------	--	--	---------------------------------	---------	----------

1) Verify service entrance and feeder conductors to fire pump. 2) Provide disconnect for fire pump emergency feeder. 3) Cut sheet of fire pump not provided. 4) Fire alarm ATS to be 2 pole type. 5) Verify emergency feeder size to fire pump. 6) Emergency fire alarm not to be bonded. 7) Verify fire rating of the room. 8) Provide short circuit calculation at the emergency panel with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer.

	16A0662	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	160 Leroiy Street New York NY	On Hold	\$650.00
--	---------	--	--	----------------------------------	---------	----------

1) Verify the feeder size off SS#1 and SS#4. 2) Feeder to Switchboard -1A is undersized. 3) Service entrance conductors undersized. 4) Emergency fire alarm switch bonded and grounded on a separately derived system and not identified as fire alarm switch. 5) Cut sheet of fire pump controller not submitted and available short circuit at controller. 6) Add fire rated stipulation for the fire pump. 7) Verify SS#2, SS#1 with down stream equipment with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0663	Stantec Consulting Service Inc. 50 West 23rd Street New York NY 10010	Requesting permission to utilize Wheatland extra heavy black galvanized steam, water, gas and air line conduits installed as per Table 300.5 under a roadway that will contain electrical conductors as specified by Con-Edison.	603 West 29th Street New York NY	On Hold	\$0.00
1) Designer to appear at Advisory Board meeting to explain installation. 2) Will conduits be used as just sleeves or will conductors be pulled directly into the conduits. 3) Conductors to be listed for wet, oil, gas resistant. 4) Provide wire fill calculations. 5) More information required.						
54125	16A0665	Schneider Associates 866 Johnston Drive Watchung NJ 07069	Requesting permission to leave as installed certified FPLP fire alarm cable in 1/2" conduit for fire alarm circuits where it will be a hardship to replace with it 3/4" conduit.	230 West 38th Street New York NY	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54107	16A0668	Dooley Electric Co., Inc. 4014 Third Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	710 West 168th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54180	16A0670	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	145 West Street Brooklyn NY	Approved	\$650.00
S.S. conductors for main #4 undersized. 10/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54178	16A0671	Hi-Tech Wiring Electrical Services 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	550 Fifth Avenue New York NY	Approved	\$650.00
Fire alarm grounding electrode conductor undersized. 10/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0672	Accurate Electrical Service Corp. 11-07 43rd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	50 Sheffield Avenue Brooklyn NY	Pending	\$650.00
Show coordination study emergency side.						
54091	16A0673	Nas Electric Corp. 17 Micieli Place Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	79-17 Albion Avenue Elmhurst NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54310	16A0674	Sheridan Electric, Ltd. 213 West 35th Street, Suite 905 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	99 Washington Street New York NY	Approved	\$650.00
<p>1) Fire pump conductors undersized, lug rated for 75 degrees. 2) How far away are the generator disconnect switches from the generator.. 3) Verify if service is 120/208 or 277/480 volt. 4) Review stopped. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Fire Rated Enclosure's must comply with the following: 1/10/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> <p>1. A P.E. or R.A. must file a PWI as an AIT 3.</p> <p>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</p> <p>3. The fire proofing must be performed by a certified fire proofing installer. 1/10/17 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Fire Rated Enclosure's must comply with the following: 1/10/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p> <p>1. A P.E. or R.A. must file a PWI as an AIT 3.</p> <p>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</p> <p>3. The fire proofing must be performed by a certified fire proofing installer.</p>						
54174	16A0675	Shorr Electrical Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	422 Fulton Street Brooklyn NY	Approved	\$650.00
<p>Provide ground fault detection listed for ungrounded system in accordance with 250.21(B). 10/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0677	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	28 Liberty Street New York NY	On Hold	\$650.00
1) Generator notes not on drawing. 2) Manufacturer's cut sheets of equipment not provided. 3) Switchboard to comply with 230.64(B)(4) and 408.60(F).						
54114	16A0678	M.R. Electrical Service LLC 204 Walworth Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	41-21 28th Street Long Island City NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54106	16A0679	Gotham Wiring Inc. 649 East 183rd Street Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	666 West End Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54218	16A0680	I.K.E. Electrical Corp. 601 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1601 Avenue J Brooklyn NY	Approved	\$650.00
1) Fire pump emergency side breaker undersized. 2) Equipment grounding conductors to DP-CNA undersized, 3) Show size of OCPD's emergency side of ATS, 5, 2 from 3rd fusing from 3rd fusing. 11/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0681	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	110 East 42nd Street New York NY	Administrative Closure	\$650.00
1) Show fault current at fire pump controller. 2) Withstand rating of fire pump controller. 10/27/16 Void as per Submission 16A0787, Approval #54179 10/19/16.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54317	16A0682	Top Shelf Electric 4386 Victory Blvd. State Island NY 10314	Requested approval for the electric service equipment proposed to be installed	1835 Sterling Place Brooklyn NY	Approved	\$650.00
1) One Line and room layout doesn't match physical for 600A fuse switches. 2) Fire pump service switch #8 EGC undersized. 3) Verify size of Trans 400A feeders. 11/28/16 Rejected. None of previous comments addressed. 1/12/17 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0683	AMRA Electrical Corporation 47 Buffalo Avenue Brooklyn NY 11233	Requested approval for the electric service equipment proposed to be installed	325 Lafayette Avenue Brooklyn NY	Rejected	\$650.00
1) Fire pump service switch to comply with 695.4(B)(3). 2) Panelboard information not complete, cut sheet not provided, fuse or circuit breaker types not shown. 3) 225A panels taps are undersized. 1/11/17 Items 2 and 3 not addressed, not typical. 2) Correct typo on revision block 1B, sheet 1 of 3.						
54226	16A0684	Kleinberg Electric Inc. 174 Hudson Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	330 Furman Street Brooklyn NY	Approved	\$650.00
1) Service entrance conductors are undersized. 2) Provide short circuit and coordination for SS#3. 11/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54115	16A0685	M.C. Electrical NY, Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	10 East 53rd Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0688	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	485 7th Avenue New York NY	Rejected	\$650.00
<p>1. Verify that service rooms are mechanically ventilated 2. All new work in service room and 1 line to be bubbled 3. Show clearance in front of LV switch boards 1 & 2 4. Fuse types not shown on 1 line drawings 5. MI transition to be on each 1 line diagram, not chart 6. ATS – 2 EM side OCPD to coordinate downstream with elevator panel. 11/23/16 Rejected. 1) The bus feeding service switch 4 and 5 are undersized. 2) Will the transition conductor be in conduit? 3) Note (6) not addressed.</p>						
54221	16A0690	Allstate Electric Corp. 555 Eight Avenue, Suite 809 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	2 Park Avenue New York NY	Approved	\$650.00
<p>1 Grounding electrode conductors can't be connected to grounding bus when the main bonding jumper is connected to the switch frame. 2) Tapped conductor to 800 amp switch undersized. 3) Provide signage on each service room. 11/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
	16A0691	Verde Electric Corp. 1402 Blondell Avenue Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	5100 Kings Plaza Brooklyn NY	On Hold	\$650.00
<p>1) Not enough information on certification a commission of the generators and transformer. 2) 5KV switches lack back work space and indicate front of equipment. 3) Show cable/conduit routing between transformer and switches and transformer and gen set.</p>						
54092	16A0692	Lizardos Engineering Associates, P.C. 200 Old Country Road Mineola NY 11501	Requested approval for the electric service equipment proposed to be installed	100 East 77th Stret New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0693	Hi-Tech Wiring Electrical Services 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	23 East 22nd Street New York NY	Pending	\$650.00
<p>OR 1) room needs mechanical ventilation. 2) Verify clearance in front of Trans "S".</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0694	Atore Campisi & Sons Lic. Electl Contrs, 18-31 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	88 Greenwich Street New York NY	On Hold	\$650.00
<p>SANDY Note: This client paid for sandy job by mistake. manufactures' cut sheet</p> <p style="text-align: right;">1. Verify that metal trough installed in a wet location underground, is listed for the purpose. Provide</p> <p>2. Switch boards to comply with 408.60(F) & 230.64(B)(4)</p> <p>3. Show 5' front clearance in front of service panel 1200 A-SS #31B</p> <p>4. Switches above 12 x 12 trough to comply with 110.26(A)(B)</p> <p>5. 1st Floor service room B1, doors to open outwards</p> <p>6. 1st Floor service room 5' clearance required in front of service switches, show clearance in front of new distribution panels</p> <p>7. There are 32 current carrying conductors, neutrals to be included in trough calculations</p> <p>8. DWG 2, verify ratings pf existing MDP – A distribution board 2000 amp W/3000 amp fusing</p> <p>9. DWG 2 300 KVA transformer over fused at 800 amps, TAP rules apply</p> <p>10. DWG 2 Trapped conductor from 300KVA transformer to 400 amp switch under sized</p> <p>11. Where is the 400 Amp portable generator switch located in conjunction with the roll up generator</p> <p>12. Are any disconnect switches in new main Distribution board section B feeding ATS, if yes, what type</p> <p>13. Roll up portable generator not to be a separately derived system</p>						
54089	16A0696	R.S. Covello Electric 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	21 East 1st Street New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54090	16A0697	Fresh Meadow Electrical Contractors, LLC 65-01 Fresh Meadow Lane Fresh Meadows NY 11365	Requested approval for the electric service equipment proposed to be installed	254 West 54th Street New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54352	16A0698	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	726 Broadway New York NY	Approved	\$650.00
<p>1) Show bonding and grounding of existing switchboard, bus sizes, fuse types. 2) 2000 CT and 2000A F.P. service switch, T2 transformer and fire pump not shown on 1 Line. 3) Fuse type not shown in 2000A service switch. 4) A new submittal is required showing the complete service 1st and 2nd fusing; equipment cut sheets. As per note on 1 Line drawing. This new submittal will void out approval 53871. 2/6/17 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54234	16A0699	EDM Electric, Inc. 32-51 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	34-11 Beach Channel Drive Far Rockaway NY	Approved	\$650.00
<p>1) Service entrance conductors undersized. 2) Bus feeding service switch #1 undersized, correct bus bar note 800 amp sq". 3) Meterbank cut sheets not provided, show circuit breaker types. 4) Correct notes on fire pump and fire alarm service switches to neutral bonded to enclosure 250.64 D(3). 5) Neutral conductor to fire pump service switch required. 6) Provide fused disconnect for ATS. 7) Verify that fire pump is not required to be connected to generator with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54116	16A0700	RCM Technologies 99 Bauer Drive, STE 101 Oakland NY 07436	Requested approval for the electric service equipment proposed to be installed	18-39 20th Avenue Astoria NY	Approved	\$0.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
54109	16A0702	Net Power Electric Corp. 1568 62nd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	1520 Fulton Street Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54117	16A0703	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	239 10th Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54093	16A0704	Atlas-Acon Electric 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	151 West 34th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54095	16A0705	FSM Electrical Corp. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	500 West 30th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54118	16A0706	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	294 East 162nd Street Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54119	16A0707	Marcel Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	2149 Ralph Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54096	16A0708	Response Electric, Inc. 36 Frost Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1 East 66th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54120	16A0709	Response Electric, Inc. 36 Frost Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	7 Gouverneur Slip East New York NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
54108	16A0711	A. Wilco Electric, LLC 36 East 20th Street, 6th Floor New York NY 10003	Requested approval for the electric service equipment proposed to be installed	200 West 15th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54121	16A0712	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	550 Vanderbilt Avenue Brooklyn NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54233	16A0713	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	685 1st Avenue New York NY	Approved	\$650.00
<p>1) Block off rear of switchboard "B" on both ends. 2) Special service fire pump feeder not fire rated, where is the pump located? Fusing undersized. 3) Verify retail sprinkler booster pump fire pump switch. 4) 1200 amp disconnect switch for chiller #2 to be ground fault protected. 5) Secondary of transformer DPLS overfused. 6) Show lengths of transformer taps with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
54148	16A0714	DeSantis Electric Inc. 1457 Bassett Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	90-15 Queens Blvd Elmhurst NY	Approved	\$650.00
OR The unfused interior of service switch #3 to be removed. 10/13/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
54097	16A0715	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	31-25 Downing Street Flushing NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54100	16A0716	AL-Lectric Electrical Contracting Inc. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	1377 6th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54183	16A0717	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	1 West 37th Street New York NY	Approved	\$650.00

Fire pump fuse is undersized on emergency side(typo)This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.
 The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.
 NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.
 With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer. 11/1/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer.

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54099	16A0718	Albros Electric Corporation 58-35 Utopia Parkway Fresh Meadow NY 11365	Requested approval for the electric service equipment proposed to be installed	409 Gateway Drive South Brooklyn NY	Approved	\$650.00
OR With the stipulation that 1000V Solar Edge three phase SE20 KUS inverters can be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54098	16A0719	Albros Electric Corporation 58-35 Utopia Parkway Fresh Meadow NY 11365	Requested approval for the electric service equipment proposed to be installed	410 Gateway Drive North Brooklyn NY	Approved	\$650.00
OR With the stipulation that 1000V Solar Edge three phase SE20KUS inverters can be installed. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54101	16A0720	Cedar Electrical Contractors, Inc. 317 Madison Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	30-30 47th Avenue Long Island City NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54105	16A0721	Stanco Systems Electrical Contracting 4061 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	IS 71 Holy Trinity School 215 Heyward Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54137	16A0722	Circle D Electrical Contracting Inc. 3525 Rombouts Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	545 8th Avenue New York NY	Approved	\$650.00
1) Service switch #4 feeder is undersized. 2) Verify compliance with 110.26(A)(3). 10/7/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/6/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54128	16A0724	Gilston Electrical Contracting Corp. 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	PS 28Q 109-10 47th Avenue Queens NY	Approved	\$650.00
OR Show coordination between 1st and 2nd fuse. 9/29/15 Electrotech call and verified fuse atype 3000 A4BQ, added to drawing. Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/1/16 Swapped drawing A-Revision 1.						
	16A0725	Gilston Electrical Contracting Corp. 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital Ctr. 1650 Grand Concourse Bronx NY	Pending	\$650.00
<p>1.ELSB-CR 1 Line Doesn't match Physical HSBA – 1line doesn't match Physical</p> <p>2.Feeder to transformer T-A1 not fire rated – DWG C</p> <p>3.EHSB 1200 Amp switches not ground fault protected DWG C</p> <p>4.Section Bus in EHSB, A1, HSCA, HSBA undersized DWG C, E</p> <p>5.TAP conductors to 800 switch undersized DWG C</p> <p>6.Can an additional door be added to the server room</p> <p>7.Fire Alarm conductors over fused DWG E</p> <p>with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
54122	16A0727	Roz-A-Lite Electrical Contracting Inc. 159 20th Street, Room 401 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	505 Pacific Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
54222	16A0728	Spectrum Electric, LLC 195 Bay 19th Street Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	185 Broadway Brooklyn NY	Approved	\$650.00
1) General notes not on drawing. 2) Correct but density notes on TDP distribution boards. 3) Manufacturer's cut sheets of equipment not provided. 11/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

September 21, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54123	16A0729	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	611 Fifth Avenue New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0732	Cedar Electrical Contractors, Inc. 64 Fulton Street, Suite 602 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	169 Columbia Heights Brooklyn NY	On Hold	\$650.00
Provide coordination study.						