

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

MEA 1-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Bakers Pride Oven Company, Inc., 30 Pine Street, New Rochelle, New York 10801.

Trade Name - Bakers Pride.

Product - Gas fired commercial charbroilers.

Pertinent Code Section(s) - 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Test(s) - RS 14-6 (ANSI Z83.11).

Laboratory – Canadian Standards Association.

Test Report(s) – Certificate No. 167971-2500004558.

Description - Gas fired commercial open top charbroilers, as tabulated below. Units are equipped with gas burners, manual valves and a gas pressure regulator.

Open Top Broiler Model No.	Oven		Input Rating BTUH
C(L,S,T)(G,R)B-3	CSRM-3	(F,C,L)(L,T,C)B-24(R,GS)	3 at 20,000
C(L,S,T)(G,R)B-4,(A)	CSRM-4(A)	(F,C,L)(L,T,C)B-30(R,GS)	4 at 20,000
C(L,S,T)(G,R)B-5	CSRM-5	(F,C,L)(L,T,C)B-36(R,GS)	5 at 20,000
C(L,S,T)(G,R)B-6,(A)	CSRM-6(A)	(F,C,L)(L,T,C)B-42(R,GS)	6 at 20,000
C(L,S,T)(G,R)B-7	CSRM-7	(F,C,L)(L,T,C)B-48(R,GS)	7 at 20,000
C(L,S,T)(G,R)B-8,(A)	CSRM-8(A)	(F,C,L)(L,T,C)B-54(R,GS)	8 at 20,000
C(L,S,T)(G,R)B-9	CSRM-9	(F,C,L)(L,T,C)B-60(R,GS)	9 at 20,000
C(L,S,T)(G,R)B-10,(A)	CSRM-10(A)	(F,C,L)(L,T,C)B-66(R,GS)	10 at 20,000
C(L,S,T)(G,R)B-11	CSRM-11	(F,C,L)(L,T,C)B-72(R,GS)	11 at 20,000

Note: Clearances of 0 inches on sides and 0 inches in rear to non-combustible locations only, for use on non-combustible flooring.

Recommendation - That the above commercial charbroiler, be accepted, when fired by natural gas only, under the following conditions:

1. Unit shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code and New York City Building Code requirements.

2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standards RS-13-2 and RS-13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
4. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
5. For grease removal, suitable baffle type grease filters, MEA accepted, shall be installed in the exhaust duct.
6. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning and servicing, and shall be MEA accepted for such use.
7. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
8. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
9. All shipments and deliveries of such equipment shall be provided with a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
10. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

8/21/2000

Examined by

S.M. Prasad