



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 10-05-E

Manufacturer: Pacific Energy Fireplace Products, Ltd., 2975 Allenby Road, Duncan, BC V9L 6V8.

Trade Name(s): Town 2 Country Fire Place.

Product: Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s): RS 14-6 (ANSI Z21.50a).

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): No. 476-3060673-8/04, dated August 31, 2004; revised November 30, 2004.

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. Units are equipped with electric ignition.

Model No.	Description	Rating BTUH
TC36-BSTE2	Direct vent, zero clearance fireplaces, control box and battery spark ignition	42,000
TC36-BARE2	Direct vent, zero clearance fireplace, control box and battery spark ignition	42,000

Clearances: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electric equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 29, 2005

Examined by Shyam Prasad SD