

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49863CO	09A0503CO	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	The Claremont 1421 College Avenue Bronx NY	Approved	\$0.00
Carry over from December 16, 2009 meeting. Job finalized 10/25/10.						
50037CO	10A0107CO	Sant-Tec Electric Inc. 305 East 110th Street New York NY 10029	Requested approval for the electric service equipment proposed to be installed	75 Clinton Street Brooklyn NY	Approved	\$0.00
Carry over from April 14, 2010 meeting. Series rating w/800A fuse not permitted. Job finalized 9/27/12.						
50107CO	10A0169CO	A.T.J. Electrical Co., Inc. 122-13 15th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	121st Police Precinct 970 Richmond Avenue Staten Island NY	Approved	\$0.00
Carry over from May 19, 2010 meeting. 1) No fusing for FACO on portable generator side, , key interlock scheme required to FACO system. 2) Emergency system to be automatic instead of interlocks for fire alarm system. Job finalized 2/4/11.						
50162CO	10A0210CO	Joseph Marchese Electric 5801 Amboy Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	700 Rosewood Street Bronx NY	Approved	\$0.00
Carry over from June 16, 2010 meeting						
50184CO3	10A0232CO3	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Lincoln Center Theatre 3 150 West 65th Street New York NY	Approved	\$0.00
Carry over from September 15, 2010 meeting. 1) 2500 amp service switch not bonded and grounded. 2) 2500 amp service switch overfused. 3) EGC undersized on load side of 2500A service switch. 4) How do #3 conductors terminate on 30 amp switch? 5) FACO to be switches. Job finalized 4/4/11. 1/21/14 Swapped sheet 1 of 3 Rev 7						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50203CO	10A0245CO	I.K.E. Electrical Corp. 601 West 26th Street, Suite 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 Fifth Avenue New York NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. 1) Provide sequence of operations. 2) Provide short circuit calculations. 3) Switchboard bus not adequate for capacity of service fuse and generator supply.						
50204CO	10A0246CO	Five Stars Electrical Contracting NY Inc. 82-31 51 Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	3120 Corlear Avenue Bronx NY	Approved	\$0.00
Carry over from July 14, 2010 meeting.						
50210CO2	10A0252CO2	J.A. Lee Electric, Inc. 23-55 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Basketball City USA Pier 36 @ South Street New York NY	Approved	\$0.00
Carry from September 15, 2010 meeting.						
50221CO	10A0263CO	Hugh O Kane Electric Company, Inc. 90 White Street New York, NY NY 11377	Requested approval for the electric service equipment proposed to be installed	1221 Sixth Avenue New York NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. 1) Fire pump branch circuits to be fire rated. 2) Does emergency board feed life safety loads?						
50222CO	10A0264CO	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	River II 600 West 42nd Street New York NY	Hold	\$0.00
Carry over from July 14, 2010 meeting. Fire Pump Info						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50257CO	10A0295CO	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Standard Charter Bank 1095 6th Avenue New York NY	Approved	\$650.00
Carry over from August 11, 2010 meeting. 1) Is service switch #5 rear accessible? 2) Does emergency board feed life safety loads. 3) Designer to appear and explain job details. Job finalized 10/26/10.						
50293CO	10A0323CO	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	McCarren Pool 776 Lormier Street Brooklyn NY	Hold	\$0.00
1) notes and detail of service entrance bus not clear. 2) Provide trough size. 3) Verify that generator is not a separately derived source. 4)FACO to be a switch. 5) Indicate all fuse types. 6) Ground connection to water main to be on line side of neutral link, 7) MI service conductors undersized and must be in 2 hour enclosure outside service room. 8) Indicate service values at service. 9) Show FA disconnect at generator. 10) SI						
50326	10A0347	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	La Casa De La Luna South 3rd Avenue & East 167th Str. Bronx NY	Approved	\$650.00
50327	10A0348	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	77 Reade Street New York NY	Approved	\$650.00
50328	10A0349	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	The Regent Tower 900 Eighth Avenue New York NY	Approved	\$650.00
Room layout only.						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50329	10A0350	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	U.S. Citizenship & Immigration 27-37 Jackson Avenue Long Island City NY	Ok, but	\$650.00
Indicate termination detail at end box for new service conductors.						
50330	10A0351	Matros Automated Electl Constn Corp. 5-33 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	344 Third Avenue New York NY	Approved	\$650.00
50331	10A0352	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	246 Spring Street New York NY	Hold	\$650.00
1) Fire pump service equipment not remote from other service equipment. 2) FACO to be a switch. 3) #8 lug needed. 4) Confirm SS#3A adequate for inrush current on transformer T2.						
50332	10A0353	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Queens Museum of Art 52-01 Grand Central Parkway Queens NY	Approved	\$650.00
1) Generator to be grounded as non-separately grounded source. 2) Clarify incoming service if Con Ed show end box and confirm 600 KCM size. 3) Confirm coordination of 600A CB with 1000A MCB and service fuse. Job finalized 3/25/13.						
50333	10A0354	Kleinknecht Electric Co., Inc. 252 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	NYU SCPS 7 East 12th Street New York NY	Approved	\$650.00
1) Conductors feeding FA panel not shown. 2) Emergency circuit for fire pump not fire rated. 3) Grounded conductor to be bonded and grounded at generator. Job finalized 11/19/10.						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50334	10A0335	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	PS29Q 125-10 23rd Avenue College Point NY	Approved	\$650.00
50335	10A0356	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Tishman Speyer 610 5th Avenue New York NY	Approved	\$650.00
50336	10A0357	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	MF Global 55 East 52nd Street, Bsmt New York NY	Approved	\$650.00
50337	10A0358	Queensboro Electrical Contracting Corp. 14-34 150th Street Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	270 Nevins Street Brooklyn NY	Approved	\$650.00
50338	10A0359	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	2-25 50th Avenue Long Island City NY	Approved	\$650.00
Who will be installing new copper bus detail? Job finalized 11/3/10.						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50339	10A0360	Contact Electric Corp. 1275 43rd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	958 Nostrand Avenue Brooklyn NY	Approved	\$650.00
Who will be installing new copper bus detail? Job finalized 11/3/10.						
50340	10A0361	Patriot Electric Corporation 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	212-01 26th Avenue Bayside NY	Approved	\$650.00
Who will be installing new copper bus detail? Job finalized 11/3/10.						
50341	10A0362	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Langone Medical Center 530-540 First Avenue New York NY	Approved	\$650.00
50342	10A0363	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	1140 6th Avenue New York NY	Approved	\$650.00
1) Tap to 200 amp disconnect switch undersized. 2) Neutrals at generator not to be bonded or all ATS w/neutral to be 4 pole. 3) FA connections to be sw/fu. Job finalized 5/18/11.						
50343	10A0364	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	2278 Frederick Douglas Blvd. New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50344	10A0365	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$650.00
1) Submission not in Advisory Board format. 2) Designer to appear to explain job details.						
50345	10A0366	T & R Alarm and Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Lehman College 250 Bedford Park Blvd West Bronx NY	Hold	\$650.00
1) 2000 amp service switch bus undersized. 2) Vertical bus size in distribution panel not shown. 3) 5' clearance needed in front of service switch circuit. 4) 3' clearance needed at the end of the switchboard. 5) Is existing board rear accessible?						
50346	10A0367	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	389 5th Avenue New York NY	Approved	\$650.00
50347	10A0368	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	West 40th Street a.k.a. 1065 Broadv New York NY	Approved	\$650.00
50348	10A0369	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	436 West 149th Street Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50349	10A0370	Positive Electrical Associates Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYC School Construction Auth. 44-24 Vernon Boulevard Long Island City NY	Ok, but	\$650.00
1) Service conductors undersized for southeast service switchboard. 2) Service cable in MI cable must be concrete encased, due to remote end-line box..						
50350	10A0371	C.Q. Electrical Contracting Corp. 31-19 37th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	260 East 161st Street Bronx NY	Approved	\$650.00
50351	10A0372	Mac Electrical Contractors 8023 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	238 Atlantic Avenue Brooklyn NY	Hold	\$650.00
1) Fire pump branch circuit conductors are not fire rated. 2) Block off rear of switchboard. 3) Correct voltage on switchboards. 4) Service bus undersized. 5) Provide physicals of equipment. 6) Provide fuse types.						
50352	10A0373	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
50353	10A0374	Levis Electrical Contractors Corp. 28-17 31st Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Kaled Management 94-11 59th Avenue Rego Park NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50354	10A0375	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Navy Green 45 Clermont Avenue Brooklyn NY	Approved	\$650.00
Service entrance conductors feeding 2000 amp service not shown. Job finalized 2/4/11.						
50355	10A0376	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	269 East Burnside Avenue Bronx NY	Approved	\$650.00
Service room to have 2 doors. Job finalized 2/23/11.						
50356	10A0377	Jen Electrical Contractors, Inc. 853 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	26 Broadway New York NY	Approved	\$650.00
50357	10A0378	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hostos Community College 500 Grand Concourse Bronx NY	Approved	\$650.00
1) Fire pump service switch tapped from cubicle that contains overcurrent protective devices. 2) Equipment grounding conductors for fire pump circuit undersized. Job finalized 11/29/11.						
50358	10A0379	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Brookfield Properties One Liberty Plaza New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50359	10A0380	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1585 Broadway New York NY	Approved	\$650.00
<p>1) Switch blades are energized on switches. 2) Feeder bus to switchboard 13" undersized. 3) Show detail of service entrance conductors. 4) Switchboard sections to be coordinated with the floor plan.</p>						
50360	10A0381	Star Delta Electric, LLC 17 Battery Place, Suite 203 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Hold	\$650.00
50361	10A0382	RNH Electric Company, Inc. 45-46 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	561 7th Avenue New York NY	Approved	\$650.00
50362	10A0383	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	1016 5th Avenue New York NY	Approved	\$650.00
<p>Tap conductor undersized. Job finalized 11/3/10.</p>						
50363	10A0384	Roz-A-Lite Electrical Contracting, Inc. 164 20th Street, Suite 2D Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Brooklyn Brewery 79 North 11th Street Brooklyn NY	Approved	\$650.00
<p>1) Show detail of service bus. 2) Service entrance conductors feeding 1200 amp service switch undersized. 3) Vertical bus size in 1200 amp switchboard not shown. 4) Service entrance and feeder conductors not shown to 125 amp service switch. 5) Verify 800 amp fuse type, coordination. Job finalized 2/7/11.</p>						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50364	10A0385	A.K. Electrical Group Inc. 6815 8th Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	85 East End Avenue New York NY	Approved	\$650.00
1) More than 40 conductors in auxiliary gutter. 2) Service room doors to open outwards. Job finalized 8/4/11.						
50365	10A0386	Brandl Electric Inc. 1927 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	744 Madison Avenue New York NY	Approved	\$650.00
1) Second fusing not shown in MLO panel. 2) Grounded conductor required in fire pump service switch, clarify conductor size. 3) Conductors on load side of 2500 service switch not shown. 4) Fuse types not shown. 5) No neutral link of ground permitted at Trans S. Job finalized 7/6/12.						
50366	10A0387	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Medical Science Bldg. 550 First Avenue New York NY	Hold	\$650.00
1) Tapped conductors to terminate in fused switch within conductor rating. 2) Provide lengths of the taps. 3) Confirm new equipment is not in emergency service room. 4) Provide connection detail at pull box. 5) Provide GFP on new switches GFP if standby, indication only if emergency.						
50367		T & R Alarm & Electric Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requesting permission due to a new wall built around the new service equipment to leave a front clearance in front of the service equipment at 3'1" and 3'7".	Lehman College 250 Bedford Park Boulevard West Bronx NY	Denied	\$0.00
50368		Kings Electric Co., Inc. 2113 West 6th Street Brooklyn NY 11223	Requesting permission due to lack of space inside of the existing service room to install new service equipment in the adjacent room.	2837 Valentine Avenue Bronx NY	Approved	\$0.00
With signage						

ADVISORY BOARD CALENDAR

October 13, 2010

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50369		L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requesting permission to replace a 1200 amp CT, 1200 amp service switch, and distribution panel on a 1000 KVA service without filing Advisory Board drawings.	136 Madison Avenue New York NY	Denied	\$0.00