

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49349CO4	09A0136CO4	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 240 East 38th Street New York NY	Approved	\$0.00
Carry over from September 16, 2009 meeting.						
49583CO2	09A0298CO2	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 101 141 East 111th Street New York NY	Approved	\$0.00
Carry over September 16, 2009 meeting.						
49584CO	09A0299CO	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Elmhurst Hospital Center 79-01 Broadway Elmhurst NY	Hold	\$0.00
Carry over from July 15, 2009 meeting. 1) Provide secondary protection on transformers. 2) Show ground correctly on transformers. 3) ATS Gen-B to be 4 pole. 4) FDRS from Gen GB & GA undersized. 5) FDR from GEN GC undersized. 6) Explain how SEP. DER SYS @ GB works w/case GND @ GEN GC when connected to EN-SWBD-BB. 7) What does mater control section in EM-SWBD-BB do? 8) Provide interlock to prevent simultaneous closure of generator breakers for gen. Ga &GL on EM-SWBD-BB. 9) Match transformer sizes between plans & single line. 10) Feeders from GIF, G2F, G3F, G4F undersized.						
49623CO	09A0326CO	A.C. Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requested approval for the electric service equipment proposed to be installed	355 West 52nd Street New York NY	Approved	\$0.00
Carry over from August 19, 2009 meeting.						
49730	09A0403	Polyphase Electrical Contractors, Inc. 2201 Neptune Avenue Brooklyn NY 11224	Requested approval for the electric service equipment proposed to be installed	150 William Street New York NY	Approved	\$650.00
Verify 4- 1/4x4 bus size in existing switchboard. Job finalized 2/16/10.						

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49731	09A0404	Linphill Electrical Contractors Inc. 4850 White Plains Road, 2nd Floor Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	19 Hyatt Street Staten Island NY	Approved	\$650.00
49732	09A0405	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	1650 Grand Concourse Bronx NY	Approved	\$650.00
Relocate new ss to maintain 36" at end of SEB. Job finalized 11/10/09.						
49733	09A0406	New Grand Electric Inc. 71-73 Allen Street #302 New York NY 10002	Requested approval for the electric service equipment proposed to be installed	500 8th Avenue New York NY	Approved	\$650.00
1) Provide bus size on line side of 4000 amp service switch. 2) New switch is not configured as a service switch,. Clarify intent. Job finalized 11/10/09.						
49734	09A0407	Citywide Electrical Wiring Inc. 30-73 Crescent Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	775 Lafayette Avenue Brooklyn NY	Approved	\$650.00
49735	09A0408	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	795 Columbus Avenue New York NY	Approved	\$650.00
1) Fire pump branch circuit to be fire rated. 2) Verify bus size z line side of 2000 amp service switch. 3) Provide pull out fuse types. 4) Clarify need for 2-FACP? Job finalized 10/21/09.						

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49736	09A0409	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Beekman School 8 Spruce Street New York NY	Approved	\$650.00
49737	09A0410	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC-IT Data Room 125 West End Avenue New York NY	Approved	\$650.00
49738	09A0411	B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Marshall;s @ East River Plz 517 East 117th Street New York NY	Approved	\$650.00
49739	09A0412	Accu-Glo Electric of New York, Inc. 38-26 30th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1430 Broadway New York NY	Approved	\$650.00
49740	09A0413	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hahn Kock Chiller 460 Park Avenue New York NY	Approved	\$650.00
Swing doors out if possible. Job finalized 2/16/10.						

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49741	09A0414	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Paramount Hotel 235 West 46th Street New York NY	Approved	\$650.00
1) Fire pump branch circuit not fire rated, verify FLA of fire pump. 2) SW/fuse backwards on main switch for MDP. 3) 800A fuse does not coordinate w/400A feeder fuses. Job finalized 3/31/10.						
49742	09A0415	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	154-158 4th Avenue Brooklyn NY	Approved	\$650.00
1) Doors on fence not shown. 2) Bus sizes in 400 amp service switch section not shown. 3) Transformer secondary not grounded. 4) Equipment shall be weatherproof. 5) Provide separation from non-electrical equipment(I.e.fencing). Job finalized 2/16/10.						
49743	09A0416	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Battery Park City Authority North West Corner Murray St. & West New York NY	Approved	\$650.00
1) Correct size of fuse or switch for ss 3000/3500A. 2) Concrete pad to be shortened to 6" in front of equipment or extended to minimum of 36" in front of switchboards. Job finalized 12/29/10.						
49744	09A0417	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	Columbia Hicks 414 Hicks Street Brooklyn NY	Approved	\$650.00
2 switches ahead of fire pump on emergency side. Job finalized 10/29/09.						
49745	09A0418	T & T Electrical Corp. 24-30 47th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	Long Island City Hotel 11-01 43rd Avenue Long Island City NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49746	09A0419	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Williamsburg Charter H.S. 198 Varet Street Brooklyn NY	Approved	\$650.00
49747	09A0420	AK Electrical Group Inc. 6815 8th Avenue Brooklyn NY 10220	Requested approval for the electric service equipment proposed to be installed	98 Riverside Drive New York NY	Approved	\$650.00
1) Service entrance conductors to 4000 amp service switch undersized. 2) Line and load bus on 4000 amp service switch undersized. 3) Install drip pan over end box. 4) Provide 2 means of egress 5) Second door to swing out w/platform. Job finalized 12/28/09.						
49748	09A0421	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU Warner Weaver Cogen Plnt 251 Mercer Street New York NY	Approved	\$650.00
Installation shall conform with clearances of 110.33. Why aren't rooms bigger to allow renewal of equipment? Job finalized 3/4/10.						
49749	09A0422	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Con Edison Fire Water Supply 4 Irving Place New York NY	Hold	\$650.00
1) Verify that room is mechanically ventilated. 2) Provide limited lugs on line side of equipment. 3) Verify that emergency feed for fire pump is supplied from the paralleling gear with dedicated overcorrect devices feeder.						
49750	09A0423	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	2000 Tremont Avenue Bronnx NY	Approved	\$650.00
Show detail of room. Job finalized 11/3/10.						

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49751	09A0424	Ace Electrical Expert Corp. 40-04 73rd Street, 2nd Floor Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1 Astoria Plaza Astoria NY	Approved	\$650.00
49752	09A0425	Triboro Electrical Contracting Corp. 39-02 29th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	313 West 37th Street New York NY	Approved	\$650.00
Service room door to open outwards w/panic hardware. Job finalized 2/16/10.						
49753	09A0426	Eric & NG Electrical Inc. 153 Suffolk Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	367 Vandervoort Avenue Brooklyn NY	Approved	\$650.00
Verify that sets of conductors are being installed. Job finalized 10/20/09.						
49754	09A0427	Alef Electrical Contracting Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	450 West 37th Street New York NY	Approved	\$650.00
49755	09A0428	A. Ceriello Electric, Inc. 15 Carroll Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	78-14 Roosevelt Avenue Queens NY	Approved	\$650.00
1) Install signage on 4000 amp service switch indicating that maximum for size is 3000 amps. 2) Verify that parallel conductors to existing service switch are identical. Job finalized 11/10/09.						

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49756	09A0429	Capitol Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Time Warner Cable 350 Broadway New York NY	Approved	\$650.00
With a stipulation that fire departmental approval is needed for the automatic transfer switching scheme.						
49757	09A0430	Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Fordham Place 400 East Fordham Road Bronx NY	Approved	\$650.00
49758	09A0431	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	186 Joralemon Street Brooklyn NY	Approved	\$650.00
49759	09A0432	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	522 5th Avenue New York NY	Approved	\$650.00
49760	09A0433	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Best Buy @ East River Plaza 517 East 117th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49761	09A0434	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	808 Columbus Avenue New York NY	Approved	\$650.00
Provide 1 line diagram. Job finalized 10/21/09.						
49762	09A0435	Coast 2 Coast Electric Cabling, Inc. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Pure Yoga 344 Amsterdam Avenue New York NY	Approved	\$650.00
New feeder is overfused. Job finalized 2/16/10.						
49763	09A0436	Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	Curtis High School 105 Hamilton Avenue Staten Island NY	Hold	\$650.00
1) Tap of a tap not allowed. 2) Size of existing feeder off of 2500 amp service switch not shown. 3) Existing bus sizes in service equipment not shown. 4) Grounding and bonding of existing service equipment not shown.						
49764	09A0437	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Verizon 1745 Richmond Avenue Staten Island NY	Approved	\$650.00
49765	09A0438	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	John Adams High School 101-02 Rockaway Boulevard Ozone Park NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49766	09A0439	Consolidated Edison Co. of NY, Inc. 4 Irving Place, 10th Floor S.W. New York NY 10003	Requested approval for the electric service equipment proposed to be installed	31-01 20th Avenue Astoria NY	Approved	\$650.00
49767	09A0440	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	One World Trade Center New York NY	Hold	\$650.00
1) Submittal not complete (generator and paralleling gear). 2) Designer to appear at meeting to explain job. 3) Drawings must be submitted up to second point of utilization equipment 480 volt.						
49768		Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requesting permission to leave as installed a 200 amp service switch with a front clearance of 49 1/2 inches on a 1000 KVA service	673 Morris Avenue New York NY	Approved	\$0.00
49769		A.C. Morgan Electric 3601 Riverdale Avenue Bronx NY 10463	Requesting permission to leave as installed an electrical service room in an existing underground room accessible through a sidewalk hatch	355 West 52nd Street New York NY	Approved	\$0.00
49770		Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requesting permission to leave as installed a 800 amp service switch with a front clearance of 51 inches on an 1000KVA service.	1595 Lexington Avenue New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49771		Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requesting permission to install 15K concrete encased service entrance conductors in reinforced thermosetting resin conduit from the Con Ed manhole to a roof transformer vault.	111 8th Avenue New York NY	Approved	\$0.00
49772		Hirschel Electrical Inc. 411 Beach 30th Street Far Rockaway NY 11598	Requesting permission to install overhead service entrance conductors in non metallic conduit in a corrosive environment, Far Rockaway, Queens.	Willow Court Queens NY	Approved	\$0.00
49773		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission due to extreme field conditions preventing concrete encasement of RGS service entrance conductors, to allow the usage of a 2 hour fire rated ceiling enclosure in a building where the structure can not support concrete	West 44th Street Hospital New York NY	Approved	\$0.00
49774		M & M Control Wiring and Electrical, Inc. 1952/2954 Richmond Terrace Staten Island NY 10314	Requesting permission to install a service switch on the outside of a commercial building where the 4 existing service switches are located in each store.	1805 Forest Avenue Staten Island NY	Approved	\$0.00
49775		Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requesting permission due to lack of space in a half basement to install a new 800 amp service switch and distribution on the outside of a single unit commercial building inside of a structure.	166 Kings Highway Brooklyn NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49776		Quantum Electric Corporation 36-24 34th Street Long Island City NY 11106	Requesting permission to leave an existing 1600 amp service switch fed with 4 sets of 500 MCM and 4 #6 neutrals in a situation where no neutrals will be installed on the load side of the service switch.	Zurich 105 East 17th Street New York NY	Denied	\$0.00
49777		AARCO Electric Inc. 5902 Avenue N Brooklyn NY 11234	Requesting permission to leave as installed old Federal Pacific backboxes that were retro fitted with new Cutler Hammer circuit breaker interiors, due to the enclosure being imbedded in cement walls in 260 apartments.	301 West 53rd Street New York NY	Approved	\$0.00
49778		A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requesting permission to leave as installed in a new apartment building air conditioning load calculated at 50%	1275 & 1269 Grant Avenue Bronx NY	Approved	\$350.00
49779		William F. Weber, P.C. Consulting Engineer 18 East 41st Street, Suite 1504 New York NY	Concept review for device refurbishing in lieu of a complete replacement	390 Park Avenue New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49780		Jones Group 305 Lost Creek Drive NW Atlanta GA 30152	Requesting concept approval to utilize existing busways that were partially fire damaged on the load side of the service switchgear where the defective portions of the busways will be removed and allowing the use of fabricated custom busway transition connections from the existing undamaged busways to either new busways or raceways that will be routed back to the load side of the new service switchgear.	NY Presbyterian Hospital 635 West 165th Street New York NY	Approved	\$0.00
<p>With the stipulation that the existing busways proposed to be reused be isolated, tested, and certified as suitable for reuse by a recognized licensed testing agency. That all remaining busway joints and fittings are rendered accessible. That a full Advisory Board submission including detailed drawings of the fabricated custom busway transition and the testing agency's report is submitted for approval prior to any associated remedial work.</p>						
49781		Jones Group 305 Lost Creek Drive NW Atlanta GA 30152	Requesting concept approval to install a temporary electrical service switchboard outdoors near the customer's property line boxes for a building where the electrical service was fire damaged.	NY Presbyterian Hospital 635 West 165th Street New York NY	Approved	\$0.00
<p>With the stipulation that either outdoor rated electrical equipment is installed or a waterproof structure is installed to contain electrical equipment, installation shall comply with Articles 230.2(E) and 590.</p>						
49782		L.N. Consulting Inc. P.O. Box 65178 Burlington VT 05406	Requested concept approval	Roosevelt Island 888 Main Street New York, NY	Approved	\$0.00
<p>1) Comply w/load data compilation per 220-87. 2) Confirm adequacy of 800A fuses should fuel cell be off-line. 3) Confirm selectivity of 3500A fuse 2/5000A service fuse. 4) Confirm adequacy of 5000A fuse should fuel cell be off-line. With the stipulations: 1) Provide full submission as per Advisory Board rules. 2) Compliance with load data compilation as per Article 220.87. 3) Confirm selectivity of 350 amp fuse with 5000 amp service switch fuse. 4) Confirm adequacy of 800 amp fuse should fuel cell be off-line. 5) Confirm adequacy of 500 amp fuse should fuel cell be off-line. 6) Confirm 2000 amp switch can accept additional sets(20 750 KCM).</p>						
49783	9A0441	Online Power Incorporated 5701 Smithway Street Commerce CA 90040	Requested approval for use in New York City of your UL924 Listed Emergency Lighting UPS/ Inverter. Model Series Numbers: PW3.0A0100N1 thru PW062H0500T3-VA.		Approved	\$200.00

ADVISORY BOARD CALENDAR

October 14, 2009

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49784	09A0442	Teknion, LLC 350 Fellowship Road Mt. Laurel NJ 08054	Requested approval for use in New York City of your Teknion District Office Furniture System		Approved	\$200.00
<p>With the stipulation that the conductors of the wiring system is #12 AWG. The partition interconnections shall be flexible assemblies listed and approved for use with wired partitions or metallic raceways that do not exceed 610mm (2ft) in length. Fixed type partitions shall be permanently connected to the building electrical system by one of the wiring methods in NYC amendments to Chapter 3. Where liquidtight flexible metal conduit is used, the maximum length shall be 457 mm (18 in.).</p>						
49785	09A0443	Teknion, LLC 350 Fellowship Road Mt. Laurel NJ 08054	Requested approval for use in New York City of your Teknion Expansion Desking Furniture System		Approved	\$200.00
<p>With the stipulation that the conductors of the wiring system is #12 AWG. The partition interconnections shall be flexible assemblies listed and approved for use with wired partitions or metallic raceways that do not exceed 610mm (2ft) in length. Fixed type partitions shall be permanently connected to the building electrical system by one of the wiring methods in NYC amendments to Chapter 3. Where liquidtight flexible metal conduit is used, the maximum length shall be 457 mm (18 in.).</p>						