

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44828	03A0200	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	St. George Ferry Terminal 1 Richmond Terrace Staten Island NY	Approved	\$250.00
Carryover from April 16, 2003 meeting.						
45139	03A0481	Arc Electrical & Mechanical Cont. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Hunter College 695 Park Avenue New York NY	Hold	\$250.00
Carryover from August 13, 2003 meeting. Status for 10/15/2003, hold. 1. Provide code required clearances around equipment. 2. Show the routing on new service tap conductors. 3. Clearly indicate between new and existing equipment.						
45140	03A0482	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Chelsea Residency 202 West 24th Street New York NY	Approved	\$250.00
Carryover from August 13, 2003 meeting.						
45182	03A0511	Solar Electric Systems, Inc. 452 West 55th Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Park Avenue Place 60 East 55th Street New York NY	Approved	\$250.00
Carryover from September 17, 2003 meeting.						
45201	03A0530	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Calhoun School 433 West End Avenue New York NY	Approved	\$250.00
Carryover from September 17, 2003 meeting.						

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45218	03A0547	Big Shot Electric Corp. 710 East 135th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Spirit of New York City 530-542 West 27th Street New York NY	Approved	\$250.00
Carryover from September 17, 2003 meeting.						
45230	03A0563	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Queens Center Mall 90-15 Queens Boulevard Queens NY	Approved	\$250.00
45231	03A0503	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Mass Mutual 2 World Financial Center New York NY	Ok, but	\$250.00
1. Confirm normal & emergency connections to ATS's. 2. Clarify the use of 3 conduits for ATS emergency supply.						
45232	03A0564	Jacoby Electric Corp. 10-40 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	New School University 55 West 13th Street New York NY	Hold	\$250.00
1. Show complete 1-line diagram. Indicate the new from the existing equipment.						
45233	03A0565	Dooley Electric 45-54 37th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Long Island Jewish Hillside Hospital Queens NY	Hold	\$250.00
1. Clarify the site plan& source of utility feed. 2. Provide short circuit information. 3. Identify generator grounding method. 4. Show means of egress from new electric room.						

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45234	03A0560	North Point Electrical Corporation 651 Bay Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	Bird S. Coler Memorial Hospital 900 Main Street Roosevelt Island NY	Hold	\$250.00
1. Must bring neutral conductor to new 800 amp service switch. 2. Show existing main bus size. 3. Show adequacy of 10 kaic rating of new circuit breaker panel. 4. Show new bus tap detail & indicate which existing switchboard is being tapped.						
45235	03A0557	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	420 East 26th Street New York NY	Hold	\$250.00
1. Feeder to 1000 kva transformer undersized (service A). 2. Feeders to 1000 amp ATS undersized (service A). 3. Show feeder size to " DP-GEN". 4. Tap for jockey pump can not be in main fire pump controller. 5. Show feeder size from 800 amp switch on secondary of transformer * service A& B). 6. ATS #5 undersized (service C). 7. Bus sizing to be per NYCEC. 700 amps per square inch for service bus. 8. Provide generator cuts & generator distribution submission. 9. Maximum distance from front of " front access" switchboard is 30" for all connections. 10. Verify clearance under service bus tie enclosures. 11. 3 foot clearance is required on both sides of service switchboard.						
45236	03A0571	Stasi/Dallas Electrical Contracting, Inc. 79-06 Jamaica Avenue Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	Dew Hamilton 220 West 143rd Street New York NY	Approved	\$250.00
45237	03A0577	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NY Dialysis 65 West 13th Street New York NY	Approved	\$250.00
45238	03A0578	Rockmor Electric Enterprise, Inc. 1042 39th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Commerce Bank 1995 Broadway New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45239	03A0589	Flemington Electrical Maintenance Inc. 207 West 25th Street-7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Ultra Flex Packaging Corp. 494 Wortman Street Brooklyn NY	Hold	\$250.00
1. Provide bus sizing as per NYCEC, 700 amps per square inch for service bus. 2. Standard notes are missing. 3. Provide better detail of the floor plan: elevation of new service define limits of service space & working clearances. 4. Show better detail of service bus tie connection.						
45240	03A0592	Electric Light & Power Inc. 463 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Target-Atlantic Terminal 139 Flatbush Avenue Brooklyn NY	Approved	\$250.00
45241	03A0593	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bloomingdales 502 Broadway New York NY	Ok but	\$250.00
1. Indicate available short circuit current at circuit breaker panel.						
45242	03A0558	Knight Electrical Services Corp. 111 Eighth Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	North Fork Bank 424 Madison Avenue New York NY	Ok	\$125.00
With the stipulation that signage must be provided in each service room indicating that there is another service and it's location.						
45243	03A0554	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Cornestone Midrise 2235 Frederick Douglas Boulevard New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45244	03A0594	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	224 West 18th Street New York NY	Hold	\$250.00
1. The room layout and the one line diagram do not correspond. Room layout shows 2 meter banks one with 12 meters and one with 15 meters and the one line shows only one meter bank with 15 meters.						
45245	03A0562	Alef Electrical Contracting Inc. 247 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	475 Tenth Avenue New York NY	Approved	\$250.00
45246	03A0561	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	1156 Avenue of the Americas New York NY	Approved	\$250.00
45247	03A0555	Judd Electric, Inc. 1097 Second Avenue, Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	475 Park Avenue New York NY	Approved	\$250.00
45248	03A0559	Quantum Electric Corporation 30-30 Northern Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bellevue Hospital 462 1st Avenue New York NY	Hold	\$250.00
1. Provide fused disconnect switch on secondary of transformer. 2. Panel bus might be undersized. 3. Relocate 800 amp switch. 4. Change panel fuses to FRN.						

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45249	03A0570	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	Fulton Fish Market at Hunts Point 801 Food Center Drive Bronx NY	Approved	\$250.00
45250	03A0566	Robert-Allen Associates, Inc. 37-36 61st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	51 Madison Avenue New York NY	Approved	\$250.00
45251	03A0567	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	New York Stock Exchange 11 Wall Street New York NY	Hold	\$250.00
<p>1. Provide signs at normal & emergency switches to read: May be energized at all times due to backfeed. 2. Provide sizes of the conductors that feed the existing 2000 amp BPS and the 2500 amp BPS (1000 kva transformer area). 3. Change the size of load side conductors at the (A) 2500 amp switch or lower the fuse size.</p>						
45252	03A0568	Plus One Electric 213 East 84th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	250 West 54th Street New York NY	Approved	\$250.00
45253	03A0569	ICOR Associates, LLC 21 Commerce Drive Cranford NJ 07016	Requested approval for the electric service equipment proposed to be installed	1710 Broadway New York NY	Hold	\$250.00
<p>1. Verify the size of service entrance conductors (2-1000 mcm). 2. Verify the tap size for the distribution panel. 3. Provide the tap length for the 1600 amp switch.</p>						

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45254	03A0572	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	629 West 54th Street New York NY	Approved	\$250.00
45255	03A0573	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	85 10th Avenue New York NY	Approved	\$250.00
45256	03A0574	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	44-02 11th Street Long Island City NY	Approved	\$250.00
45257	03A0575	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	307 West 38th Street New York NY	Approved	\$250.00
45258	03A0576	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Macy's Building 47-44 31st Street Long Island City NY	Hold	\$250.00
Request special permission for the 10 foot taps not to meet the 10 % rating (10 % of the 2500 amp service switch).						

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45259	03A0579	Innovative Engineering, Inc. 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	300 Park Avenue South New York NY	Approved	\$250.00
45260	03A0580	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	New Fire Alarm System 9 West 57th Street New York NY	Hold	\$250.00
1. If keeping the 200 amp cut-out than it requires special permission. A 200 amp cut-out is not allowed , 90 amps is the maximum cut-out allowed.						
45261	03A0581	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	Brooklyn Law School 250 Joralemon Street Brooklyn NY	Approved	\$250.00
45262	03A0582	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Site 7 Residential Development West 145th Street & Bradhurst Avenue New York NY	Approved	\$250.00
45263	03A0583	Jashar Engineering Corp. 118 East 28th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	331 Madison Avenue-Basement New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45264	03A0584	Savery S. Manfredonia, PEPC 14 Ponds Lane Purchase NY 10577	Requested approval for the electric service equipment proposed to be installed	1775 Broadway New York NY	Approved	\$250.00
45265	03A0585	Amko Electrical Construction & Maint. 32-17 College Point Boulevard Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	435 7th Avenue New York NY	Approved	\$250.00
45266	03A0586	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested concept approval for the electric service equipment room proposed to be installed	Tump "F" 140 Riverside Drive Blvd. New York NY	Approved	\$250.00
Concept approval of the electrical room layout, not for the electrical equipment.						
45267	03A0587	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	300 West 20th Street New York NY	Ok, but	\$250.00
1. Check the fuse and bus sizes for service switches # 2 & 3.						
45268	03A0588	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	780 8th Avenue New York NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45269	03A0590	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Public School 66-K 850 Rockaway Parkway Brooklyn NY	Approved	\$250.00
45270	03A0591	Levest Electric Corp. 325 West 37th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1501 Broadway New York NY	Approved	\$250.00
45271	000000000000000000	Diane Electric, Inc. 1371 Seabury Avenue Bronx NY 10461	Requesting permission to install a 100 amp service switch fused at 55 amps lieu of a fuse cut out for a fire alarm system	Verizon 228 East 56th Street New York NY	APPROVED	\$0.00
Subject to other jurisdictions approval.						
45272	000000000000000000000000	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requesting permission to leave as installed one service entrance standpipe that feeds a 2 gang meter pan that supplies power to two one family buildings.	21-23 and 25-27 Linda Court Staten Island NY	Denied	\$0.00
Section 27-3045(k) of the New York City Electrical Code prohibits service entrance conductors from feeding one building to another.						
45273	0000000000000000000000	Innovative Engineering, Inc 1144 Hooper Avenue-Suite 205 Toms River NJ 08753	Requesting permission add a new 200 amp service switch without reinforcing the existing 4000 amp service bus.	300 Park Avenue South New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45274	0000000000000 000000000	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requesting permission to install service switchboard with a front clearance of 4'9".	Bloomingdales 502 Broadway New York NY	Approved	\$0.00
45275	000000	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requesting permission not to group together service equipment due to a wall being built between services after they were installed.	36 Heberton Avenue Staten Island NY	Approved	\$0.00
That signage must be provided at each service switch indicating where the other service switch is located.						
45276	00000000000	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requesting permission not to file Advisory Board Submittal for the installation of 100 amp service switch fused at 30 amps to supply power to Time Warner Cable equipment.	Time Warner Cable TV Service 140 Broadway New York NY	Approved	\$0.00
With the stipulation that no electrical equipment clearances are compromised.						
45277	00000000	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requesting permission to install a seventh switch where two of the service switches are for a manual and automatic fire pumps (Cal. #45182).	Park Avenue Place 60 East 55th Street New York NY 10022	Approved	\$0.00
45278	0000000	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requesting permission to distribute 585, 120 volt lighting circuits through a central dimmer room, in on 24" x 8", on 18" x 12", on 8" x 8" and one 6" x 6" wiring troughs, filled no greater than 20% as per submitted specifications and calculations.	Biltmore Theatre 261-65 West 47th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45279	000000000	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requesting permission to install tow horizontal busways where one busway run will have two locations where the bus is installed 86" off the floor and the other run will have five locations where the bus is installed 81" to 91" off the floor. (Cal. #45071)	333 East 102nd Street New York NY	Approved	\$0.00
With the stipulation that bumpers are installed next to the bus to protect them from mechanical injury.						
45280	0000	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to leave as installed for two locations, 40 sets of utility service conductors consisting of 4-500 MCM in 4" fiberglass reinforced epoxy conduit (FRE) without grounding conductors.	Glen Oaks Campus Queens NY	Approved	\$0.00
With the stipulation that that the wire racks & manhole rings must be properly grounded.						
45281	000	Daniel Borriello Electric Inc. 1468 86th Street Brooklyn NY 11228	Requesting permission to install a GFCI receptacle in a bath area to provide power to a television mounted in front of the receptacle, option two will be to install a glass door in front of the television.	383 Avenue T Brooklyn NY	Denied	\$0.00
Section 410-57(c) of the National Electrical Code prohibits the installation of receptacles within a bathtub or shower area.						
45282	03A0595	Krueger International 1220 Bellevue Street Green Bay WI 54302	Requesting approval for use in New York City of your Office Furnishings. PowerUp, Series 46-1487.		Approved	\$75.00
Restricted to NEC article 605 and NYC's local amendments for installations. Furniture must be fixed in place.						
45283	03A0596	Myers Power Products, Inc. 2000 Highland Avenue Bethlehem NY 18020	Requested approval for use in New York City of your Compact, Modular Emergency Lighting Inverter. Model/Series Numbers: CM-1, CM-2, CM-3 & CM-4.		Approved	\$75.00

ADVISORY BOARD CALENDAR

October 15, 2003

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45284	03A0597	High Lites, Inc. 2142 Thomaston Avenue Waterbury CT 06704	Requested approval for use in New York City of your Emergency Sign, Emergency Lighting. Model REFO.		approved	\$75.00
Model REFO approved. Model ES denied, metal guage must be 20 minimum.						
45285	03A0598	Thomas & Betts Corp. 8155 T & B Blvd. Memphis TN 38125	Requested approval for use in New York City of your Die Cast Edge-Lit Exit Sign. Model/Series Nos. LX & LXN Series. (Alternate Cat. No. to Lightalarms Cat. No. 8S Series).		Approved	\$75.00
45286	03A0599	Nienkamper Furniture and Accessories 257 Finchdene Square Toronto Ontario Canada MFX1B	Requested approval for use in New York City of your Relocatable Power Tap.		Denied	\$75.00
The 1999 National Electrical code and NYC's local amendments are silent on the approval and usage of relocateable power taps. The 1999 NEC 400-8(I) state that flexible cords and cables are not to be used as a substitute for the fixed wiring of a structure.						
45287	00	Hannington Engineering Consultants 501 Fifth Avenue, Suite 1809 New York NY 10017	Requesting permission not to file full Advisory Board drawings for the addition of a 200 amp second fusing disconnect switch on a existing 1000 KVA service. A drawing showing the service room layout and a partial one line diagram are included.	Hendon Residence 14 East 90th Street-Apartment 3A New York NY 10128	Approved	\$0.00