

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

**BOARD MEMBERS PRESENT: BOGAD, BUNK, CANGEMI, COHEN, LORENZ, MARCOVICI, MAZZEO, MILLER, MONIZ, PACE, PANARIELLO, PESCATORE, PETROU, TRONGONE, XANTHOS AND CHAIRMAN COLUCCIO.**

44383 Forest Electric Corp. Sub. #02A0622  
Two Penn Plaza  
New York, NY 10121 **Approved**

Requested approval for the electric service equipment proposed to be installed in the building at:

Lehman Brothers  
85 10<sup>th</sup> Avenue-7<sup>th</sup> Floor  
New York, NY

44384 Unisys Electric Inc. Sub. #02A0623  
19 Irving Place  
Staten Island, NY 10304 **Hold**

Requested approval for the electric service equipment proposed to be installed in the building at:

Chelsea Recreation Center  
430-444 West 25<sup>th</sup> Street  
New York, NY

44385 Mage Electrical Contractors Sub. #02A0624  
158 Perry Street  
New York, NY 10014 **Hold**

Requested approval for the electric service equipment proposed to be installed in the building at:

619 West 54<sup>th</sup> Street  
New York, NY

44386 Mike Lewkowicz, Licensed Electrical Contractor Sub. #02A0625  
8412 Foster Avenue **OK**  
Brooklyn, NY 11236 **Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building at:

45 West 21<sup>st</sup> Street  
New York, NY

44387 Zwicker Electric Co., Inc. Sub. #02A0626  
200 Park Avenue South **OK**  
New York, NY 10003 **Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building at:

70 West 38<sup>th</sup> Street  
New York, NY

44388 Galaxy Tri-State Electric Inc. Sub. #02A0627  
211-07 Jamaica Avenue  
Queens Village, NY 11428 **Approved**

Requested approval for the electric service equipment proposed to be installed in the building at:

140 West 62<sup>nd</sup> Street  
New York, NY

-1-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44389 Adco Electrical Corporation  
380 Chelsea Road  
Staten Island, NY 10314

Sub. #02A0628

**Deny**

Requested approval for the electric service equipment proposed to be installed in the building at:

Ballpark at St. George  
75 Richmond Terrace  
Staten Island, NY

44390 Joseph Sgroi & Sons, Inc.  
34-06 44<sup>th</sup> Street  
Long Island City, NY 11101

Sub. #02A0629

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

19 Rector Street  
New York, NY

44391 Hugh O'Kane Electric Co., LLC  
30-40 48<sup>th</sup> Avenue-2<sup>nd</sup> Floor  
Long Island City, NY 11101

Sub. #02A0630

**OK  
Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building located at:

60 Hudson Street  
New York, NY

44392 Fischbach & Moore Electric, Inc.  
19-02 Whitestone Expressway  
Whitestone, NY 11357

Sub. #02A0631

**OK  
Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building located at:

South Street Seaport Museum  
207 Front Street  
New York, NY

44393 H & L Electric Inc.  
41-11 28<sup>th</sup> Street  
Long Island City, NY 11101

Sub. #02A0632

**Approved**

Requested approval for the electric

service equipment proposed to be installed in the building located at:

2 Metro Tech  
Brooklyn, NY

44394 Lite-Up Associates Inc.  
511 West 20<sup>th</sup> Street  
New York, NY 10011

**OK**  
**Revision Pending**

Sub. #02A0633

Requested approval for the electric service equipment proposed to be installed in the building located at:

150 5<sup>th</sup> Avenue  
New York, NY

-2-

**ADVISORY BOARD CALENDAR**  
**OCTOBER 16, 2002**

44395 O-H-M Electrical Corp.  
39-40 21<sup>st</sup> Street  
Long Island City, NY 11101

**Approved**

Sub. #02A0634

Requested approval for the electric service equipment proposed to be installed in the building located at:

Boston Properties  
5 Times Square  
New York, NY

44396 Albin Gustafson Company  
5 Tudor City Place  
New York, NY 10017

**Approved**

Sub. #02A0635

Requested approval for the electric service equipment proposed to be installed in the building located at:

T.I.A.A./CREF  
750 Third Avenue  
New York, NY

44397 High-Tech Electrical Services Corp.  
36-33 23<sup>rd</sup> Street  
Long Island City, NY 11106

**Approved**

Sub. #02A0636

Requested approval for the electric service equipment proposed to be installed in the building located at:

BJ's Wholesale Club @ Gateway Ctr.  
339 Gateway Drive  
Brooklyn, NY

44398 Linear Electric Inc.  
630 Ninth Avenue-Suite 1001  
New York, NY 10036

**OK**  
**Revision Pending**

Sub. #02A0637

Requested approval for the electric service equipment proposed to be installed in the building located at:

St. James Theatre  
246 West 44<sup>th</sup> Street  
New York, NY

44399 Charan Electrical Enterprises, Inc.

Sub. #02A0638

27-14 39<sup>th</sup> Avenue  
Long Island City, NY 11101

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

Polo Grounds Tower  
2975 Eighth Avenue  
New York, NY

Sub. #02A0643

44400 Campbell and Dawes Ltd.  
84-48 129<sup>th</sup> Street  
Kew Gardens, NY 11415

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

New York Public Library  
11 West 40<sup>th</sup> Street  
New York, NY

-3-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44401 Campbell and Dawes Ltd.  
84-48 129<sup>th</sup> Street  
Kew Gardens, NY 11415

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #02A0644

120 Broadway-3<sup>rd</sup> Basement  
New York, NY

44402 MJC Electric Inc.  
10-11 46<sup>th</sup> Avenue  
Long Island City, NY 11101

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #02A0648

Chase Branch #733  
2551 Broadway  
New York, NY

44403 Adco Electrical Corporation  
380 Chelsea Road  
Staten Island, NY 10314

**OK  
Revision Pending**

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #02A0649

201 Edward Curry Avenue  
Staten Island, NY

44404 Unity Electric Co., Inc.  
65-21 Fresh Meadow Lane  
Flushing, NY 11365

**Approved**

Requested approval for the electric

Sub. #02A0650

Lehman Brothers

service equipment proposed to be installed in the building located at:

745 7<sup>th</sup> Avenue  
New York, NY

44405 L.K. Comstock & Company, Inc.  
294 Amsterdam Avenue  
New York, NY 10023

**Approved**

Sub. #02A0651

Requested approval for the electric service equipment proposed to be installed in the building located at:

New York Life  
51 Madison Avenue  
New York, NY

44406 Robert B. Samuels Inc.  
48 West 25<sup>th</sup> Street  
New York, NY 10010

**OK**  
**Revision Pending**

Sub. #02A0652

Requested approval for the electric service equipment proposed to be installed in the building located at:

330 West 34<sup>th</sup> Street  
New York, NY

-4-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44407 Michael Mazzeo Electric Corp.  
41-24 24<sup>th</sup> Street  
Long Island City, NY 11101

**OK**  
**Revision Pending**

Sub. #02A0653

Requested approval for the electric service equipment proposed to be installed in the building located at:

Verizon  
193 Manhattan Ave.-Bsmt. Level  
New York, NY

44408 Unity Electric Co., Inc.  
65-45 Fresh Meadow Lane  
Flushing, NY 11365

**OK**  
**Revision Pending**

Sub. #02A0654

Requested approval for the electric service equipment proposed to be installed in the building located at:

J.P. Morgan Chase  
277 Park Avenue  
New York, NY

44409 Consolidated Electric Construction Co.  
201 East 42<sup>nd</sup> Street-11<sup>th</sup> Floor  
New York, NY 10017

**Approved**

Sub. #02A0655

Requested approval for the electric service equipment proposed to be installed in the building located at:

Pace University  
163 William Street-Basement  
New York, NY

44410 Forest Electric Corp.

Sub. #02A0656

Two Penn Plaza  
New York, NY 10121

**Hold**

Requested approval for the electric service equipment proposed to be installed in the building located at:

LIJ-Energy Center  
267-25 76<sup>th</sup> Avenue  
Queens, NY

44411 Caruso & Sons Electrical Contracting Inc.  
1489 Blondell Avenue  
Bronx, NY 10461

**Approved**

Sub. #-02A0657

Requested approval for the electric service equipment proposed to be installed in the building located at:

Time Warner Cable of New York  
350 Broadway  
New York, NY

44412 Egg Electric, Inc.  
26 West 17<sup>th</sup> Street  
New York, NY 10011-5710

**Approved**

Sub. #02A0658

Requested approval for the electric service equipment proposed to be installed in the building located at:

NYU Hospital Center  
530 1<sup>st</sup> Avenue, Tisch Ground  
New York, NY

-5-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44413 Spieler & Ricca Electrical Co., Inc.  
52-09 Van Dam Street  
Long Island City, NY 11101

**Approved**

Sub. #02A0659

Requested approval for the electric service equipment proposed to be installed in the building located at:

NYU  
194 Mercer Street  
New York, NY

44414 H.P. Electrical Designs Inc.  
321 West 44<sup>th</sup> Street, Suite 405  
New York, NY 10036-5404

**Hold**

Sub. #02A0660

Requested approval for the electric service equipment proposed to be installed in the building located at:

Jacon Reingold Pavillion  
5901 Palisade Avenue  
Bronx, NY

44415 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121

**Hold**

Sub. #02A0661

Requested approval for the electric

C.S.F.B. Generator

service equipment proposed to be installed in the building located at:

1 Madison Avenue  
New York, NY

Sub. #02A0662

44416 Izzo Electric, Inc.  
2522 E. Tremont Avenue  
Bronx, NY 10461

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

1787 Madison Avenue  
New York, NY

Sub. #02A0663

44417 Blasko Electrical Contractors, Inc.  
36-38 35<sup>th</sup> Street  
Long Island City, NY 11106

**Approved**

Requested approval for the electric service equipment proposed to be installed in the building located at:

Swingline Building  
3200 Skillman Avenue  
Long Island City, NY

Sub. #02A0664

44418 Athens Electric, Inc.  
2009 63<sup>rd</sup> Street  
Brooklyn, NY 11204

**Hold**

Requested approval for the electric service equipment proposed to be installed in the building located at:

80 Wall Street  
New York, NY

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

- 44419 Dynamic Electric Service Inc. Sub. #02A0665  
14-17 110<sup>th</sup> Street  
College Point, NY 11356 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 439 East 51<sup>st</sup> Street  
New York, NY
- 44420 K & G Electric Co., Inc. Sub. #02A0666  
3925 Broadway  
New York, NY 10032 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 525 West End Avenue  
New York, NY
- 44421 Urban Servwell Inc. Sub. #02A0667  
856 East 136<sup>th</sup> Street  
Bronx, NY 10454 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 301 West 45<sup>th</sup> Street  
New York, NY
- 44422 Robert Garcia Electrical Contracting Corp. Sub. #02A0668  
550 Trinity Avenue-Suite 18  
Bronx, NY 10466-3610 **Approved**
- Requested approval for the electric service equipment proposed to be installed in the building located at: 224 West 18<sup>th</sup> Street  
New York, NY
- 44423 Elco Electrical Contracting Corp.  
35-43 37<sup>th</sup> Street  
Long Island City, NY 11101 **Approved**
- Requesting permission to leave as installed the light switches inside the master bedroom walk-through closet, as per submitted sketch, in a building located at: 10 East 73<sup>rd</sup> Street  
New York, NY
- 44424 John F. Cordes, Licensed Electrician  
353 Mill Road  
Staten Island, NY 10306 **Approved**
- Requesting permission to leave as installed a service switch that is not grouped together with two others in two three-family houses located at: 38 and 40 Garibaldi Avenue  
Staten Island, NY

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44425 P & M Electrical Contracting Corp.  
1921 McDonald Avenue  
Brooklyn, NY 11223

**OK**  
**Revision Pending**

Requesting permission to leave as installed a 200A service switch under the outside entrance steps and next to an existing 400A service switch, as per submitted photos, in a building located at:

2508 Adam Clayton Powell Blvd.  
New York, NY

44426 Kleinknecht Electric Company, Inc.  
940 Eighth Avenue  
New York, NY 10019-4287

**Hold**

Requesting permission to install a 100A main circuit breaker in each of the existing 25 main lug panels, to conform with the "twenty-five rule", in a building located at:

750 3<sup>rd</sup> Avenue  
New York, NY

44427 Atkinson Koven Feinberg Engineers, LLP  
1501 Broadway, Suite 700  
New York, NY 10036

**Deny**

Requesting a one-time, one location special permission to install attachment plug receptacles around a pool perimeter at a distance, from the inside walls, smaller than the allowed ten feet, at the:

Boys Club of New York  
133-01 41<sup>st</sup> Road  
Flushing, NY

44428 Atkinson Koven Feinberg Engineers, LLP  
1501 Broadway, Suite 700  
New York, NY 10036

**Approved**

Requesting permission to install a 4.16KV fuse protected secondary conductors in a Schedule 40 PVC conduit, in soil 3 feet deep without encasement, in a building located at:

Fordham University Campus  
Bronx, NY

44429 GB Electrical Corp.  
1874 Clove Road  
Staten Island, NY 10304

**Approved**

Requesting permission to leave as installed a 100A rainproof combo panel mounted on the outside wall, as per submitted

15 Shaina Ct.

sketch, of a building located at:

Staten Island, NY

44430 Laser Lite Electrical, Inc.  
40 Gaton Street  
Staten Island, NY 10309

**OK**  
**Revision Pending**

Requesting permission not to group together the service equipment, due to lack of common area, in eight two-family houses located at:

781/783, 785/787, 789/791 and  
793/795 Rossville Avenue  
Staten Island, NY

-8-

**ADVISORY BOARD CALENDAR**  
**OCTOBER 16, 2002**

44431 Ko-Bar Electrical Contracting Corp.  
38-08 Astoria Blvd. So.  
Astoria, NY 11103

**Approved**

Requesting permission to leave as installed a 100 amp disconnect switch, mounted approximately twelve feet from power source (400A disconnect switch), due to obstructions in the service room, as illustrated in attached photos, in a building located at:

MS 17  
328 West 48<sup>th</sup> Street  
New York, NY

44432 W.T.G. Electric, Inc.  
115-14 Beach Channel Drive  
Rockaway Park, NY 11694

**Approved**

Requesting permission not to group together the 400A service equipment for a new car wash with the 200A service equipment at an existing gas station, as per submitted sketch, located at:

1149 Utica Avenue  
Brooklyn, NY

44433 Forest Electric Corp.  
Two Penn Plaza  
New York, NY 10121

**Approved**

Requesting permission to replace in kind the portion of the fire alarm feeder that was damaged on September 11, 2001 and to add local battery back-up at the fire alarm panels in place of the UPS system, as per submitted sketch,

Winter Garden  
World Financial Center  
120 Marginal Street  
New York, NY

44434 All Electric Service Corp.  
1751 Stillwell Avenue  
Brooklyn, NY 11223

**Approved**

Requesting permission to leave as installed two 200A service switches in a waterproof enclosure mounted on the outside building wall of an AT & T cell located at:

70 Father Capitano Blvd.  
Staten Island, NY

44435 Taft Electric Company, Inc.  
31-31 123<sup>rd</sup> Street  
Flushing, NY 11354

**Hold**

Requesting permission to leave as installed a new PLP meter and equipment in a new 2 hour rated partition with door, separate from the existing meter room, as per submitted sketch, in a building located at:

111 West 72<sup>nd</sup> Street  
New York, NY

-9-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44436 H.J. Martin Associates, Inc.  
14-31 110<sup>th</sup> Street  
College Point, NY 11356-1444

**Approved**

Requesting permission to leave as installed a new 800A service disconnect switch, distribution panel and CT cabinet outside the existing service room due to space restrictions, as per submitted sketch, in a building located at:

108 Moore Street  
Brooklyn, NY

44437 Rolf Jensen & Associates Professional Engineers, P.C.  
360 West 31<sup>st</sup> Street, Suite 1104  
New York, NY 10001-4092

**Hold**

Requesting permission to leave as installed a 600A automatic transfer switch for the emergency power system in the same room as the primary service equipment, as per submitted sketch, at the:

Richmond County Ballpark  
75 Richmond Terrace  
Staten Island, NY

44438 Big Beam Emergency Systems, Inc.  
P.O. Box 518  
Crystal Lake, IL 60039

**Approved**

Requested approval for use in New York City of your Emergency Exit Lighting Fixtures. Models: XFL-NY, EXFL-NY, DXLS-NY, EDXLS-NY.

Sub. #02A0617

44439 Day-Brite Lighting, a Div. of Genlyte Thomas Group LLC  
776 S. Green Street  
Tupelo, MS 38802

**Approved**

Requested approval for use in New York City of your Exit Sign, 60 Line.

Sub. #02A0618

44440 Day-Brite Lighting, a Div. of Genlyte Thomas Group LLC  
776 S. Green Street  
Tupelo, MS 38802 **Approved** Sub. #02A0619

Requested approval for use in New York City of your  
Exit Sign, ER60 Line.

44441 Benshaw, Inc.  
1659 East Sutter Road  
Glenshaw, PA 15116 **Hold** Sub. #02A0620

Requested approval for use in New York City of your  
Electrical Components. Redi-Start Series.

-10-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44442 Rackware, Inc.  
4210 Metro Parkway-Suite 118  
Fort Myers, FL 33916 **Approved-Cabinet Only** Sub. #02A0639

Requested approval for use in New York City of your  
Server Cabinet. Model No. DB-782842-CR.

44443 Rackware, Inc.  
4210 Metro Parkway-Suite 118  
Fort Myers, FL 33916 **Deny** Sub. #02A0640

Requested approval for use in New York City of your  
Temperature Control Module. Model No. TM-AG10.

44444 Rackware, Inc.  
4210 Metro Parkway-Suite 118  
Fort Myers, FL 33916 **Deny** Sub. #02A0641

Requested approval for use in New York City of your  
Power Distribution Unit. Model No. 00-953-0000-XXX.

44445 Herman Miller, Inc.  
P.O. Box 302-855 E. Main Avenue  
Zeeland, MI 49464-0302 **Approved** Sub. #02A0642

Requested approval for use in New York City of your  
Office Furnishing Electrical Distribution and Lighting  
Accessories. Model Nos. QNP, QTP, QTPBD, QTGP,

QBF, QPJ, QXPAK4, QBEL1342, QXPAK4-180, QJB  
and QCE Series; Q6123 and QLT Series Portable Lamps.

44446 Technical Systems Sub. #02A0616  
P.O. Box 1206  
Pryor, OK 74362 **Approved**

Requested approval for use in New York City of your  
Air Cooled Water Chiller. Model 30AOLM104-SPFC.

44447 USM U. Schaerer Sons Inc. Sub. #02A0621  
28-30 Greene Street  
New York, NY 10013 **Approved**

Requested approval for use in New York City of your  
Wiring Components for Office Furnishings. Model  
Nos. NY Box USM-No. 50789/Dekko-No. 225210;  
Distribution Harness USM-No. 50745/Dekko-No. 225034;  
Jumper USM-No. 50751/Dekko-No. 225057; Duplex  
Receptacles USM No. 50746-50749/Dekko No. 225561-1 to 4.

-11-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44448 Focalor, Inc. Sub. #02A0645  
3495 Edison Way  
Menlo Park, CA 94025 **Deny**

Requested approval for use in New York City of your  
Indoor Lighting, Low Voltage Monorail. Model: Arcano.

44449 Erco Lighting, Inc. Sub. #02A0646  
160 Raritan Center Parkway-Suite 10  
Edison, NJ 08837 **Hold**

Requested approval for use in New York City of your  
Outdoor Lighting Fixtures. Series Beamer, Focalflood  
and Parscoop (Lightscoop).

44450 Comverge Technologies Inc. Sub. #02A0647  
23 Vreeland Rd.  
Florham Park, NJ 07923 **OK**  
**Revision Pending**

Requested approval for use in New York City of your  
External Remote Meter Unit. Model NYC-RMU-02.

44451 Belimo Aircontrols USA, Inc. Sub. #02A0669  
43 Old Ridgebury Road-P.O. Box 2928

Danbury, CT 06813-2928

**Approved**

Requested approval for use in New York City of your Electric Actuator for Fire and Smoke Dampers Models: FSNF120(-S) and FSNF24(-S) US.

44452 Kullman Industries

One Kullman Corporate Campus Drive  
Lebanon, NJ 08833

**Approved**

Requesting permission to place the electrical service equipment for the modular classroom, outside of the building walls, as per submitted drawings, in a building located at:

P.S. 40R  
91 Henderson Avenue  
Staten Island, NY

44453 Action Consultants

120 Greenwich Street, Suite 3J  
New York, NY 10006

**Approved**

Requesting permission to leave as installed a fire pump electrical feeder in three inch threaded rigid galvanized conduit, and encase if in a two hour rated cementitious fireproofing, trowelled on metal mesh, in lieu of two inch concrete encasement, in a building located at:

25 North Moore Street  
New York, NY

-12-

**ADVISORY BOARD CALENDAR  
OCTOBER 16, 2002**

44454 Action Consultants

120 Greenwich Street, Suite 3J  
New York, NY 10006

**OK**

**Revision Pending**

Requesting permission to leave as installed a fire pump electrical feeder three inch threaded rigid galvanized conduit, and encase if in a two hour rated cementitious fireproofing, trowelled on metal mesh, in lieu of two inch concrete encasement, in a building located at:

280 Broadway  
New York, NY

44455 Kullman Industries

One Kullman Corporate Campus Drive  
Lebanon, NJ 08833

**Approved**

Requested approval for **modular building** electrical wiring proposed to be installed in a building located at:

Sub. #02A0670

PS-40R  
91 Henderson Avenue  
Staten Island, NY

44456 Louis Baldinger & Sons Inc.  
1902 Steinway Street

Sub. #02A0671

Astoria, NY 11105

**Approved**

Requested approval for use in New York City of your  
Lighting Fixture Wall Sconce. Model: B30923.

<b><u>Cal. #</u></b>	<b><u>Original Meeting Date</u></b>	<b><u>Disposition</u></b>
44189	7/17/02(Service)	Hold
44215	7/17/02(Equipment)	Approved
44237	8/14/02(Service)	Approved
44305	9/18/02(Service)	Approved
44315	9/18/02(Service)	Hold
44356	9/18/02(Special Permission)	Approved
44373	9/18/02(Service)	Approved
44374	9/18/02(Service)	Approved
44375	9/18/02(Service)	Deny
44380	9/18/02(Equipment)	Deny
44381	9/18/02(Equipment)	Approved

Note-Advisory Board approvals are specific to the condition and specification detailed in the request and should not be construed as precedent for other installations.